

**HP 1500**

# Valori inregistrate MIR-IS HP-1500

Data:03/01/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.67	5.64	141.11	15.90	2.67	2.77
VMJH	07:59	1.50	5.58	140.10	15.98	2.66	2.72
VMJH	08:29	1.10	5.46	141.08	15.74	2.68	2.78
VMJH	08:59	0.93	5.41	139.84	15.71	2.77	2.76
VMJH	09:29	0.90	5.69	141.02	15.60	2.64	2.75
VMJH	09:59	1.20	5.51	139.96	15.74	2.70	2.77
VMJH	10:29	1.77	5.58	139.96	15.60	2.64	2.68
VMJH	10:59	1.10	5.40	140.35	15.81	2.69	2.75
VMJH	11:29	1.10	5.38	140.40	15.85	2.64	2.77
VMJH	11:59	1.33	5.58	139.68	15.61	2.64	2.75
VMJH	12:29	1.47	5.67	140.26	15.76	2.63	2.76
VMJH	12:59	1.53	5.65	140.28	15.86	2.64	2.70
VMJH	13:29	1.43	5.57	140.55	15.72	2.63	2.78
VMJH	13:59	1.23	5.49	140.90	15.77	2.65	2.77
VMJH	14:29	1.50	5.46	139.67	15.73	2.75	2.71
VMJH	14:59	1.83	5.38	140.80	15.66	2.71	2.75
VMJH	15:29	1.37	5.56	140.41	15.93	2.75	2.76
VMJH	15:59	1.40	5.43	140.25	15.88	2.69	2.68
VMJH	16:29	1.50	5.60	138.77	15.81	2.58	2.79
VMJH	16:59	1.60	5.62	140.36	16.01	2.67	2.79
VMJH	17:29	1.70	5.46	140.69	15.88	2.63	2.71
VMJH	17:59	2.00	5.53	139.72	15.54	2.69	2.75
VMJH	18:29	1.67	5.53	140.33	15.66	2.75	2.70
VMJH	18:59	1.73	5.24	140.36	15.83	2.69	2.76
VMJH	19:29	1.60	5.71	139.63	15.93	2.68	2.77
VMJH	19:59	1.93	5.41	140.55	16.04	2.62	2.75
VMJH	20:29	2.13	5.62	141.68	15.56	2.70	2.74
VMJH	20:59	1.90	5.58	140.10	16.07	2.75	2.74
VMJH	21:29	2.13	5.46	140.02	15.68	2.73	2.77
VMJH	21:59	0.97	5.54	140.71	15.68	2.66	2.73
VMJH	22:29	1.00	5.58	139.16	15.73	2.66	2.80
VMJH	22:43	2.50	5.68	139.94	15.61	2.73	2.83
VMZ		1.51	5.53	140.27	15.78	2.68	2.75



# Valori inregistrate MIR-IS HP-1500

Data:04/01/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	2.23	5.43	140.12	15.71	2.76	2.70
VMJH	07:59	1.73	5.46	140.63	15.90	2.54	2.75
VMJH	08:29	2.93	5.55	139.27	15.84	2.65	2.83
VMJH	08:59	3.23	5.51	138.71	15.76	2.66	2.72
VMJH	09:29	2.90	5.59	140.70	15.67	2.71	2.77
VMJH	09:59	3.00	5.61	142.65	15.97	2.66	2.73
VMJH	10:29	3.13	5.76	141.20	15.95	2.74	2.79
VMJH	10:59	2.77	5.56	139.63	15.51	2.61	2.69
VMJH	11:29	2.63	5.55	141.64	15.85	2.75	2.74
VMJH	11:59	2.77	5.30	142.03	15.75	2.70	2.71
VMJH	12:29	1.37	5.43	139.62	15.71	2.69	2.75
VMJH	12:59	0.50	5.59	140.76	15.90	2.70	2.75
VMJH	13:29	1.00	5.50	140.88	15.51	2.70	2.75
VMJH	13:59	0.40	5.58	142.20	16.11	2.69	2.74
VMJH	14:29	0.57	5.44	138.86	15.83	2.68	2.74
VMJH	14:59	1.03	5.36	141.94	15.58	2.73	2.81
VMJH	15:29	1.07	4.89	141.09	15.98	2.49	2.79
VMJH	15:59	0.60	4.08	141.55	15.47	2.33	2.90
VMJH	16:29	2.47	4.06	141.01	14.98	2.30	2.91
VMJH	16:59	1.03	4.16	142.53	15.59	2.37	2.83
VMJH	17:29	1.73	4.23	142.07	15.74	2.33	2.83
VMJH	17:59	2.00	3.93	143.46	15.57	2.32	2.81
VMJH	18:29	2.50	4.25	141.91	15.74	2.32	2.82
VMJH	18:59	0.27	4.25	141.04	15.80	2.34	2.83
VMJH	19:29	1.17	4.31	141.73	15.59	2.34	2.86
VMJH	19:59	1.17	4.29	141.40	15.57	2.28	2.87
VMJH	20:29	0.70	4.10	142.35	15.80	2.34	2.91
VMJH	20:59	0.83	4.07	141.72	15.56	2.35	2.86
VMJH	21:29	1.43	4.11	142.85	15.43	2.30	2.87
VMJH	21:59	0.23	4.22	142.69	15.67	2.31	2.90
VMJH	22:29	0.27	4.18	142.98	15.40	2.30	2.88
VMJH	22:50	0.67	4.24	141.35	15.26	2.37	2.77
VMZ		1.58	4.87	141.33	15.68	2.51	2.80

# Valori inregistrate MIR-IS HP-1500

Data:05/01/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.93	4.24	143.03	15.49	2.31	2.88
VMJH	07:59	0.97	4.05	140.37	15.67	2.30	2.85
VMJH	08:29	0.30	4.06	142.75	15.25	2.36	2.80
VMJH	08:59	0.67	4.11	141.50	14.84	2.30	2.80
VMJH	09:29	0.93	4.31	142.99	15.61	2.32	2.85
VMJH	09:59	0.33	4.20	142.50	15.52	2.35	2.86
VMJH	10:29	0.50	3.99	142.81	15.41	2.30	2.81
VMJH	10:59	0.23	4.12	141.22	15.75	2.33	2.82
VMJH	11:29	0.57	4.05	142.54	15.28	2.35	2.92
VMJH	11:59	0.57	4.31	142.55	15.72	2.30	2.82
VMJH	12:29	0.53	4.11	142.46	15.94	2.32	2.84
VMJH	12:59	0.40	4.29	143.77	15.47	2.33	2.82
VMJH	13:29	0.13	4.14	142.63	15.62	2.32	2.80
VMJH	13:59	1.90	4.26	140.53	15.66	2.30	2.85
VMJH	14:29	2.80	4.14	142.41	15.24	2.34	2.85
VMJH	14:59	0.67	4.06	143.13	15.43	2.33	2.82
VMJH	15:29	0.43	4.10	142.08	15.51	2.34	2.83
VMJH	15:59	0.87	4.15	141.89	15.65	2.34	2.84
VMJH	16:29	0.97	4.08	140.23	15.61	2.30	2.82
VMJH	16:59	0.60	4.35	143.32	15.34	2.30	2.83
VMJH	17:29	0.97	4.26	142.84	15.40	2.33	2.94
VMJH	17:59	0.87	4.13	140.80	15.23	2.34	2.80
VMJH	18:29	0.90	4.11	141.74	15.65	2.30	2.80
VMJH	18:59	0.43	3.98	142.51	15.58	2.29	2.86
VMJH	19:29	0.43	4.44	142.71	15.46	2.33	2.86
VMJH	19:59	0.67	4.30	141.80	15.66	2.28	2.86
VMJH	20:29	0.67	4.04	143.18	15.71	2.34	2.88
VMJH	20:59	0.67	4.08	143.51	15.54	2.35	2.82
VMJH	21:29	1.50	4.11	142.87	15.58	2.25	2.79
VMJH	21:59	0.10	4.23	141.22	15.39	2.35	2.92
VMJH	22:29	0.57	4.20	141.42	15.77	2.33	2.92
VMJH	22:44	0.07	4.22	143.27	14.83	2.32	2.88
VMZ		0.73	4.16	142.25	15.50	2.32	2.84



# Valori inregistrate MIR-IS HP-1500

Data:06/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH	07:29	0.33	4.21	141.95	15.06	2.32	2.77
VMJH	07:59	0.47	5.02	160.17	17.31	2.32	2.80
VMJH	08:29	0.30	5.55	169.74	17.75	2.32	2.92
VMJH	08:59	1.13	5.58	170.57	17.82	2.35	3.00
VMJH	09:29	0.27	5.92	170.12	18.02	2.30	2.92
VMJH	09:59	1.17	5.68	170.77	18.04	2.32	2.95
VMJH	10:29	0.53	5.55	171.53	17.59	2.32	3.05
VMJH	10:59	1.60	5.44	171.02	17.61	2.33	2.94
VMJH	11:29	2.83	5.85	170.92	18.04	2.35	3.04
VMJH	11:59	2.03	5.60	168.84	17.56	2.29	2.98
VMJH	12:29	2.00	5.74	170.44	17.86	2.33	2.89
VMJH	12:59	3.00	5.82	167.48	17.64	2.35	2.85
VMJH	13:29	2.27	5.35	169.48	18.18	2.35	2.88
VMJH	13:59	2.80	5.96	169.96	17.54	2.30	3.03
VMJH	14:29	2.33	6.10	168.71	17.95	2.36	3.02
VMJH	14:59	2.60	5.67	170.52	17.79	2.32	2.93
VMJH	15:29	2.67	6.00	170.02	18.06	2.33	2.92
VMJH	15:59	2.87	5.93	171.18	17.70	2.36	3.05
VMJH	16:29	1.93	5.64	168.20	18.17	2.36	2.92
VMJH	16:59	2.37	5.69	170.98	17.94	2.29	2.90
VMJH	17:29	1.43	5.80	167.54	17.68	2.34	2.97
VMJH	17:59	1.97	6.06	169.25	17.60	2.32	3.05
VMJH	18:29	1.80	6.08	169.99	17.62	2.32	2.93
VMJH	18:59	2.37	5.78	171.68	17.88	2.36	2.96
VMJH	19:29	2.20	5.94	169.04	17.74	2.34	2.94
VMJH	19:59	1.73	5.88	171.09	17.19	2.30	2.94
VMJH	20:29	1.93	5.82	171.73	17.86	2.35	2.89
VMJH	20:59	2.43	5.94	167.45	17.80	2.34	2.87
VMJH	21:29	2.27	5.86	169.64	17.76	2.27	3.01
VMJH	21:59	1.90	5.72	170.52	17.47	2.34	2.95
VMJH	22:29	0.93	5.80	169.58	17.87	2.31	3.02
VMJH	22:42	0.54	6.62	171.81	17.47	2.36	2.80
VMZ		1.80	5.72	168.76	17.68	2.33	2.94

# Valori inregistrate MIR-IS HP-1500

Data:09/01/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	12:49	0.43	5.63	172.26	17.25	2.33	2.95
VMJH	13:19	0.73	5.94	170.19	18.24	2.32	2.91
VMJH	13:49	1.93	5.74	170.95	18.11	2.35	2.95
VMJH	14:19	1.17	5.57	168.73	17.42	2.30	3.00
VMJH	14:49	1.13	5.75	167.51	17.22	2.31	2.87
VMJH	15:19	0.63	5.68	173.46	17.57	2.31	2.97
VMJH	15:49	0.83	5.78	171.06	17.78	2.32	3.06
VMJH	16:19	1.30	5.69	166.83	18.17	2.32	3.04
VMJH	16:49	1.43	5.98	171.04	17.03	2.33	2.80
VMJH	17:19	1.57	5.52	169.37	18.06	2.30	3.03
VMJH	17:49	1.90	5.78	167.10	17.78	2.33	2.89
VMJH	18:19	0.90	6.11	168.48	17.99	2.36	3.00
VMJH	18:49	1.97	5.71	171.23	17.63	2.35	2.89
VMJH	19:19	1.13	6.14	170.57	18.39	2.28	2.93
VMJH	19:49	1.63	5.65	169.60	17.87	2.28	2.98
VMJH	20:19	1.30	5.91	171.78	18.09	2.35	2.93
VMJH	20:49	1.70	5.96	170.81	17.45	2.35	3.04
VMJH	21:19	2.03	5.79	163.04	17.56	2.23	3.04
VMJH	21:49	1.67	2.50	114.75	13.38	1.63	2.76
VMJH	22:19	2.20	2.52	113.38	13.19	1.59	2.81
VMJH	22:44	0.24	2.58	113.90	13.42	1.64	2.75
VMZ		1.33	5.35	162.09	17.15	2.22	2.93



# Valori inregistrate MIR-IS HP-1500

Data:10/01/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.70	2.57	112.80	13.33	1.70	2.78
VMJH	07:59	1.97	2.55	115.44	12.87	1.73	2.67
VMJH	08:29	1.23	2.62	115.50	13.19	1.61	2.75
VMJH	08:59	1.77	2.53	113.20	12.77	1.61	2.67
VMJH	09:29	1.07	2.54	112.25	12.98	1.74	2.77
VMJH	09:59	1.77	2.60	114.14	13.63	1.69	2.78
VMJH	10:29	2.13	2.47	114.75	13.01	1.58	2.66
VMJH	10:59	1.60	2.54	115.46	12.83	1.64	2.76
VMJH	11:29	1.50	2.52	113.59	13.02	1.75	2.82
VMJH	11:59	0.87	2.55	114.98	12.83	1.59	2.81
VMJH	12:29	1.87	2.68	113.35	13.18	1.61	2.74
VMJH	12:59	2.23	2.54	113.71	13.02	1.64	2.75
VMJH	13:29	1.43	2.58	113.35	13.27	1.59	2.81
VMJH	13:59	1.47	2.60	114.89	13.56	1.64	2.70
VMJH	14:29	1.97	2.56	116.51	13.42	1.67	2.79
VMJH	14:59	1.73	2.45	112.48	12.77	1.69	2.74
VMJH	15:29	1.07	2.58	117.17	13.38	1.71	2.77
VMJH	15:59	1.53	2.51	114.24	13.70	1.70	2.82
VMJH	16:29	1.20	2.49	113.22	12.73	1.62	2.85
VMJH	16:59	1.37	2.56	115.01	12.77	1.61	2.78
VMJH	17:29	1.10	2.42	114.45	13.36	1.71	2.75
VMJH	17:59	2.03	2.61	116.07	13.22	1.68	2.79
VMJH	18:29	0.97	2.53	115.52	13.66	1.73	2.69
VMJH	18:59	1.83	2.57	116.51	13.08	1.76	2.78
VMJH	19:29	2.60	2.57	113.88	13.21	1.65	2.79
VMJH	19:59	1.77	2.58	115.21	13.41	1.65	2.77
VMJH	20:29	1.17	2.47	115.22	13.48	1.63	2.75
VMJH	20:59	1.37	2.55	114.09	12.54	1.71	2.78
VMJH	21:29	0.87	2.56	113.98	13.17	1.58	2.75
VMJH	22:00	1.06	2.59	114.30	13.07	1.63	2.81
VMZ		1.54	2.55	114.51	13.15	1.66	2.76

# Valori inregistrate MIR-IS HP-1500

Data:11/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.67	2.54	114.56	13.18	1.61	2.83
VMJH	07:59	1.43	2.56	114.77	13.78	1.71	2.78
VMJH	08:29	0.50	2.55	113.94	13.22	1.68	2.78
VMJH	08:59	0.93	2.60	115.61	12.95	1.60	2.82
VMJH	09:29	0.40	2.55	115.67	12.91	1.68	2.77
VMJH	09:59	0.63	2.55	114.69	13.76	1.67	2.82
VMJH	10:29	1.00	2.56	113.69	13.28	1.64	2.81
VMJH	10:59	1.07	2.59	116.40	14.07	1.70	2.69
VMJH	11:29	0.57	2.57	112.78	13.33	1.70	2.70
VMJH	11:59	0.37	2.61	114.65	13.20	1.60	2.76
VMJH	12:29	1.47	2.60	112.79	13.17	1.60	2.76
VMJH	12:59	0.40	2.63	115.13	12.84	1.69	2.75
VMJH	13:29	0.73	2.59	110.91	13.49	1.69	2.82
VMJH	13:59	1.03	2.53	115.61	13.54	1.72	2.74
VMJH	14:29	0.43	2.54	114.10	13.16	1.64	2.80
VMJH	14:59	0.97	3.48	114.85	13.41	1.84	2.98
VMJH	15:29	1.53	3.44	113.64	13.96	1.97	3.04
VMJH	15:59	1.07	3.67	114.42	13.72	1.85	3.02
VMJH	16:29	0.57	3.63	114.23	13.59	1.84	2.92
VMJH	16:59	0.67	3.49	116.50	14.01	1.96	2.95
VMJH	17:29	0.90	3.66	113.32	13.98	1.97	2.93
VMJH	17:59	2.30	3.43	116.79	13.36	2.02	2.88
VMJH	18:29	1.50	3.65	115.30	14.02	1.81	3.04
VMJH	18:59	2.50	3.70	115.81	13.83	1.81	2.98
VMJH	19:29	2.73	3.66	113.05	13.91	1.82	3.09
VMJH	19:59	1.30	3.41	111.06	13.07	1.79	3.03
VMJH	20:29	2.00	3.27	114.41	14.25	1.92	2.91
VMJH	20:59	2.83	3.71	112.67	13.48	1.97	3.05
VMJH	21:29	2.23	3.59	115.66	13.51	1.90	3.03
VMJH	21:59	2.47	3.73	114.94	13.92	1.93	3.02
VMJH	22:29	2.73	3.74	113.86	13.67	1.82	3.09
VMJH	22:36	1.29	3.82	112.36	11.86	1.97	2.85
VMZ		1.29	3.10	114.36	13.52	1.78	2.89



# Valori inregistrate MIR-IS HP-1500

Data:12/01/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 100 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 07:29	2.27	3.47	113.89	14.04	1.93	3.04
VMJH 07:59	2.87	3.61	112.44	13.41	1.94	2.94
VMJH 08:29	2.57	3.29	113.09	13.38	1.89	2.89
VMJH 08:59	2.30	3.39	111.68	13.51	1.89	2.90
VMJH 09:29	2.33	3.55	113.18	13.99	1.82	2.83
VMJH 09:59	3.63	3.61	112.09	13.68	1.99	2.97
VMJH 10:29	3.17	3.61	115.29	14.09	1.97	3.01
VMJH 10:59	2.33	3.61	114.14	14.15	1.88	2.99
VMJH 11:29	3.23	3.54	114.96	13.78	1.88	2.97
VMJH 11:59	2.73	3.62	110.39	14.05	1.88	2.98
VMJH 12:29	3.13	3.71	113.35	13.73	1.76	2.91
VMJH 12:59	2.83	3.52	113.68	13.64	1.81	3.05
VMJH 13:29	2.30	3.79	117.41	14.22	1.96	2.93
VMJH 13:59	1.23	3.54	111.55	12.24	1.78	2.95
VMJH 14:29	1.70	3.73	113.99	13.33	1.81	2.96
VMJH 14:59	1.13	3.92	113.15	13.89	1.92	2.76
VMJH 15:29	1.20	3.68	113.86	14.15	1.89	2.84
VMJH 15:59	0.53	3.83	112.42	13.92	1.89	2.97
VMJH 16:29	0.60	3.44	111.01	13.49	1.83	3.08
VMJH 16:59	0.53	3.78	113.85	12.87	1.95	3.03
VMJH 17:29	0.40	3.39	113.14	13.56	1.92	2.92
VMJH 17:59	0.27	3.48	111.66	14.08	1.96	3.03
VMJH 18:29	0.70	3.61	114.96	13.19	1.76	2.88
VMJH 18:59	0.50	3.53	113.99	13.84	1.81	2.91
VMJH 19:29	0.53	3.80	113.51	13.82	1.80	3.00
VMJH 19:59	1.20	3.69	114.51	13.31	1.81	2.93
VMJH 20:29	1.17	3.22	116.94	13.63	1.87	2.92
VMJH 20:59	0.33	3.55	115.72	13.74	1.98	2.99
VMJH 21:29	0.37	3.52	110.74	13.61	1.83	2.99
VMJH 21:59	0.87	3.48	110.85	14.04	1.94	2.85
VMJH 22:26	0.74	3.85	111.41	13.86	1.98	2.93
VMZ	1.61	3.59	113.32	13.68	1.88	2.95

# Valori inregistrate MIR-IS HP-1500

Data:13/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	11:53	0.33	4.07	119.38	14.52	2.06	3.10
VMJH	12:23	0.47	6.79	169.77	20.77	3.76	3.18
VMJH	12:53	0.83	6.73	169.73	19.62	3.77	3.26
VMJH	13:23	0.57	7.21	170.89	20.33	3.86	3.09
VMJH	13:53	0.77	7.15	171.69	20.01	3.78	3.15
VMJH	14:23	2.27	7.29	170.14	20.18	3.76	3.29
VMJH	14:53	1.00	7.60	167.23	20.62	3.66	3.06
VMJH	15:23	0.87	8.01	172.04	20.78	3.97	3.27
VMJH	15:53	0.57	7.24	170.21	20.75	3.72	3.23
VMJH	16:23	0.73	7.27	172.20	20.24	3.83	3.34
VMJH	16:53	0.53	7.27	169.48	20.38	3.95	3.20
VMJH	17:23	0.77	6.74	170.90	20.80	3.96	3.20
VMJH	17:53	0.63	6.85	170.02	20.80	3.74	3.22
VMJH	18:23	0.40	7.20	172.65	19.65	3.93	3.11
VMJH	18:53	0.33	7.53	171.25	20.15	3.70	3.22
VMJH	19:23	0.57	7.43	171.29	19.99	3.75	3.23
VMJH	19:53	1.40	7.50	168.77	20.98	3.95	3.29
VMJH	20:23	1.00	7.09	168.61	20.10	3.91	3.03
VMJH	20:53	0.40	7.25	168.62	20.49	3.78	3.39
VMJH	21:23	0.87	7.39	171.45	20.68	3.77	3.39
VMJH	21:53	0.67	7.14	168.51	20.52	3.94	3.09
VMJH	22:23	0.80	7.29	169.75	20.71	3.84	3.18
VMJH	22:42	0.32	7.44	168.29	21.79	3.94	3.07
VMZ		0.75	7.10	167.94	20.19	3.75	3.20



# Valori inregistrate MIR-IS HP-1500

Data:14/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.40	7.34	169.80	20.49	3.80	3.25
VMJH	07:59	0.60	7.10	169.27	19.58	3.88	3.11
VMJH	08:29	0.20	6.86	172.82	20.91	3.90	3.34
VMJH	08:59	0.30	6.93	171.33	20.28	4.02	3.24
VMJH	09:29	0.53	7.27	169.44	20.92	3.88	3.31
VMJH	09:59	0.53	6.86	171.27	20.13	4.01	3.11
VMJH	10:29	0.77	6.80	167.71	19.52	4.04	3.32
VMJH	10:59	1.00	6.99	168.72	20.64	3.85	3.24
VMJH	11:29	1.20	6.73	169.78	20.62	3.98	3.27
VMJH	11:59	0.43	7.27	168.41	21.72	3.90	3.22
VMJH	12:29	0.33	6.91	172.69	20.58	3.91	3.28
VMJH	12:59	0.33	6.92	170.47	19.49	3.95	3.23
VMJH	13:29	0.37	7.37	170.44	19.50	3.86	3.35
VMJH	13:48	0.16	6.69	164.97	20.21	3.77	3.26
VMZ		0.52	7.01	169.92	20.33	3.91	3.25

# Valori inregistrate MIR-IS HP-1500

Data:16/01/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 13:09	1.20	7.21	170.20	19.56	3.86	3.11
VMJH 13:39	0.27	7.82	170.11	20.56	3.89	3.19
VMJH 14:09	1.23	7.51	169.88	19.99	3.72	3.38
VMJH 14:39	1.00	7.35	169.24	20.75	3.96	3.06
VMJH 15:09	0.93	6.86	168.97	20.05	3.99	3.26
VMJH 15:39	0.57	6.47	171.74	20.37	3.85	3.23
VMJH 16:09	0.40	7.51	166.91	21.05	3.74	3.33
VMJH 16:39	0.43	6.94	170.37	20.68	3.74	3.11
VMJH 17:09	0.50	6.93	168.88	20.07	3.88	3.29
VMJH 17:39	0.57	7.35	170.72	20.42	3.98	3.32
VMJH 18:09	0.27	7.20	173.12	20.48	3.86	3.21
VMJH 18:39	0.40	7.49	170.73	21.33	3.86	3.23
VMJH 19:09	0.63	6.37	159.88	18.66	3.37	3.13
VMJH 19:39	0.33	5.44	142.89	17.11	2.87	3.01
VMJH 20:09	0.63	5.27	141.52	16.68	2.91	3.16
VMJH 20:39	1.33	5.49	145.74	17.03	2.77	3.00
VMJH 21:09	0.50	5.77	141.99	16.69	2.92	3.20
VMJH 21:39	1.27	5.60	143.02	17.34	2.84	3.09
VMJH 22:09	1.50	5.60	142.35	17.42	2.90	3.06
VMJH 22:24	0.27	5.23	141.02	17.65	2.80	3.17
VMZ	0.72	6.60	160.43	19.23	3.50	3.18

# Valori inregistrate MIR-IS HP-1500

Data:17/01/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 100 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	07:29	1.20	4.96	140.96	17.01	2.76	3.05
VMJH	07:59	0.53	5.57	142.63	17.21	2.90	3.16
VMJH	08:29	0.40	5.31	141.62	17.27	2.85	3.04
VMJH	08:59	0.40	5.24	141.73	17.23	2.85	3.13
VMJH	09:29	0.97	5.07	138.25	17.07	2.87	3.12
VMJH	09:59	0.70	5.67	143.18	16.63	2.86	3.08
VMJH	10:29	1.63	5.38	142.35	17.08	2.96	3.14
VMJH	10:59	1.20	5.10	143.57	17.54	2.88	3.15
VMJH	11:29	1.10	5.65	141.34	16.97	2.80	3.08
VMJH	11:59	1.63	5.39	140.75	16.85	2.71	3.02
VMJH	12:29	0.43	5.56	141.22	16.94	2.93	3.17
VMJH	12:59	0.47	5.74	142.72	17.12	2.83	3.16
VMJH	13:29	1.17	5.26	141.48	17.33	2.83	3.12
VMJH	13:59	0.23	5.47	141.72	17.29	2.90	3.15
VMJH	14:29	0.30	5.61	141.21	16.52	2.81	3.09
VMJH	14:59	0.20	5.46	141.45	17.02	2.85	3.09
VMJH	15:29	0.43	5.52	143.80	17.11	2.81	3.05
VMJH	15:59	0.60	5.17	141.04	17.39	2.91	3.09
VMJH	16:29	0.97	5.19	140.85	17.23	2.91	3.10
VMJH	16:59	1.10	5.17	141.16	17.13	2.79	3.10
VMJH	17:29	0.87	5.30	143.74	17.60	2.79	3.07
VMJH	17:59	1.60	5.21	140.71	17.41	2.85	3.19
VMJH	18:29	1.53	5.62	140.12	16.95	2.98	3.11
VMJH	18:59	0.63	5.42	141.98	17.65	2.91	3.03
VMJH	19:29	0.87	5.54	139.97	17.04	2.84	3.12
VMJH	19:59	1.77	5.22	143.36	16.81	2.81	3.14
VMJH	20:29	0.57	5.33	141.22	16.85	2.95	3.17
VMJH	20:59	0.67	5.30	140.78	16.86	2.93	3.06
VMJH	21:29	0.40	5.39	142.45	16.89	2.93	2.96
VMJH	21:59	0.30	5.58	139.85	16.84	2.81	3.25
VMJH	22:29	0.80	5.24	141.99	16.86	2.85	3.06
VMJH	22:36	0.57	5.28	140.42	16.47	2.95	3.31
VMZ		0.83	5.38	141.58	17.08	2.86	3.11



# Valori inregistrate MIR-IS HP-1500

Data:18/01/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	07:29	0.80	5.34	141.66	17.10	2.85	3.02
VMJH	07:59	0.43	5.41	141.17	17.26	2.86	3.09
VMJH	08:29	0.50	5.43	141.93	16.29	2.81	3.06
VMJH	08:59	0.60	5.34	142.59	17.45	2.91	3.08
VMJH	09:29	0.23	5.41	142.89	17.24	2.93	3.09
VMJH	09:59	0.40	5.29	142.25	17.24	2.77	3.09
VMJH	10:29	1.23	5.23	142.58	17.37	2.77	3.12
VMJH	10:59	0.73	5.43	139.83	17.50	2.84	3.02
VMJH	11:29	1.23	5.16	143.06	16.72	2.92	3.05
VMJH	11:59	1.60	5.15	137.81	16.99	2.70	3.14
VMJH	12:29	0.80	3.65	99.73	12.52	2.08	3.04
VMJH	12:59	1.07	3.55	102.44	12.12	2.21	2.98
VMJH	13:29	0.67	3.38	101.61	12.06	2.01	3.03
VMJH	13:59	0.83	3.53	99.53	12.20	2.35	2.90
VMJH	14:29	0.63	3.35	103.52	11.89	2.15	3.05
VMJH	14:59	0.43	3.76	101.80	12.58	2.03	3.01
VMJH	15:29	0.60	3.50	103.44	12.84	2.29	2.92
VMJH	15:59	0.57	3.24	102.92	12.41	2.19	3.06
VMJH	16:29	0.43	3.47	103.06	12.10	2.07	2.87
VMJH	16:59	0.30	3.67	101.35	12.21	2.13	3.04
VMJH	17:29	0.60	3.69	102.01	11.78	2.16	3.13
VMJH	17:59	0.77	3.55	96.99	11.93	1.96	2.82
VMJH	18:29	0.53	3.68	103.81	12.33	2.23	2.97
VMJH	18:59	1.57	3.50	103.59	12.37	2.11	2.94
VMJH	19:29	1.87	3.59	99.75	11.99	2.21	3.00
VMJH	19:59	1.07	3.44	103.37	12.12	2.15	3.01
VMJH	20:29	1.00	3.79	101.70	12.27	2.29	3.01
VMJH	20:59	1.93	3.68	103.35	12.54	2.02	3.07
VMJH	21:29	1.47	3.67	102.09	12.13	2.19	2.99
VMJH	21:59	1.30	3.42	106.19	12.32	2.29	3.02
VMJH	22:29	0.80	3.77	104.79	12.08	2.18	2.99
VMJH	22:50	0.57	3.86	102.31	12.11	1.95	2.84
VMZ		0.86	4.12	114.65	13.77	2.37	3.02



# Valori inregistrate MIR-IS HP-1500

Data:19/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.77	3.54	96.81	12.12	2.04	2.99
VMJH	07:59	1.00	3.50	97.75	11.89	2.13	3.01
VMJH	08:29	0.83	3.56	103.31	12.39	2.17	3.08
VMJH	08:59	2.53	3.71	106.50	12.26	2.25	2.92
VMJH	09:29	0.93	3.56	105.33	12.21	2.23	2.94
VMJH	09:59	2.00	3.79	103.91	12.35	2.12	3.01
VMJH	10:29	1.13	3.51	106.75	12.15	2.19	2.95
VMJH	10:59	1.23	3.76	102.35	12.45	2.19	2.94
VMJH	11:29	0.63	3.78	101.06	12.35	2.19	3.04
VMJH	11:59	0.37	3.48	99.70	12.16	2.04	2.97
VMJH	12:29	0.40	3.37	106.20	12.51	2.07	2.97
VMJH	12:59	0.50	3.61	103.03	12.20	2.18	2.89
VMJH	13:29	0.23	3.56	101.13	12.52	2.36	3.03
VMJH	13:59	0.17	3.63	102.57	12.57	2.25	2.77
VMJH	14:29	0.97	3.67	104.54	12.55	2.18	2.89
VMJH	14:59	1.17	3.56	104.72	12.44	2.23	3.04
VMJH	15:29	0.43	3.51	100.95	11.94	2.20	2.91
VMJH	15:59	1.37	3.41	104.78	12.33	2.14	3.00
VMJH	16:29	0.43	3.87	105.50	12.25	2.24	2.90
VMJH	16:59	0.63	3.79	102.01	12.52	2.01	2.95
VMJH	17:29	0.30	3.68	105.17	11.99	2.14	2.96
VMJH	17:59	0.73	3.49	105.57	12.05	2.30	2.81
VMJH	18:29	0.77	3.59	104.70	12.25	2.12	2.93
VMJH	18:59	0.47	3.45	100.94	11.78	2.18	2.90
VMJH	19:29	0.83	3.61	104.89	12.33	2.23	3.01
VMJH	19:59	0.77	3.57	103.44	12.33	2.14	3.12
VMJH	20:29	0.50	5.80	158.36	16.61	3.66	3.63
VMJH	20:59	2.13	6.16	171.29	17.15	3.80	3.72
VMJH	21:29	0.73	6.11	169.32	18.31	4.03	3.67
VMJH	21:59	0.37	6.50	170.67	18.12	3.78	3.52
VMJH	22:29	1.30	6.42	166.81	17.69	3.83	3.80
VMJH	22:48	2.21	5.85	169.60	18.01	4.10	3.92
VMZ		0.92	4.06	114.69	13.22	2.47	3.09

# Valori inregistrate MIR-IS HP-1500

Data:20/01/2023

	Ora	Pulberi mg/Nm <sup>2</sup>		SO <sub>2</sub> L1 mg/Nm <sup>3</sup>		NO <sub>x</sub> L1 mg/Nm <sup>3</sup>		CO L1 mg/Nm <sup>3</sup>		COT L1 mg/Nm <sup>3</sup>		HCL L1 mg/Nm <sup>3</sup>	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	100	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.37		6.73		168.72		18.83		3.89		3.65	
VMJH	07:59	0.67		6.28		170.61		18.24		3.67		3.79	
VMJH	08:29	0.20		6.43		171.42		17.63		3.69		3.50	
VMJH	08:59	0.80		6.29		168.03		18.47		3.82		3.34	
VMJH	09:29	0.33		6.64		171.13		17.86		3.84		4.02	
VMJH	09:59	0.73		6.58		169.84		17.70		3.62		3.52	
VMJH	10:29	0.37		6.41		169.23		17.80		4.06		3.75	
VMJH	10:59	0.70		6.02		168.73		17.94		3.83		3.60	
VMJH	11:29	0.47		6.47		173.09		18.54		3.81		3.76	
VMJH	11:59	0.43		6.56		171.07		18.22		3.99		3.66	
VMJH	12:29	0.57		6.32		171.46		18.39		3.91		3.79	
VMJH	12:59	0.70		6.22		170.82		18.09		3.86		3.63	
VMJH	13:29	0.77		6.33		171.05		18.90		3.63		3.72	
VMJH	13:59	1.30		6.42		170.60		18.24		3.82		3.76	
VMJH	14:29	1.80		6.42		169.47		18.28		3.77		3.62	
VMJH	14:59	2.40		6.62		170.68		18.63		3.81		3.75	
VMJH	15:29	1.90		5.99		169.88		18.35		3.80		3.78	
VMJH	15:59	2.07		6.58		170.30		17.92		3.92		3.81	
VMJH	16:29	2.20		6.80		170.03		18.02		3.81		3.42	
VMJH	16:59	2.00		6.21		168.36		18.24		4.02		3.73	
VMJH	17:29	1.70		5.77		168.84		18.53		3.85		3.52	
VMJH	17:59	1.53		6.73		171.16		18.58		3.71		3.46	
VMJH	18:29	1.87		6.01		168.20		18.11		3.93		3.64	
VMJH	18:59	2.00		6.50		170.04		18.26		3.74		3.64	
VMJH	19:29	3.07		6.60		168.75		17.89		4.00		3.80	
VMJH	19:59	2.20		6.20		168.93		18.23		3.74		3.80	
VMJH	20:29	1.93		6.66		170.66		17.97		3.86		3.64	
VMJH	20:59	1.53		6.55		172.01		18.53		3.79		3.73	
VMJH	21:29	1.57		6.48		169.51		18.07		3.81		3.86	
VMJH	21:59	1.93		6.08		169.15		17.56		3.76		3.58	
VMJH	22:29	1.80		6.50		171.48		18.36		3.77		3.85	
VMJH	22:50	2.76		6.32		171.49		18.24		3.64		3.74	
VMZ		1.38		6.40		170.14		18.21		3.82		3.68	



# Valori inregistrate MIR-IS HP-1500

Data:20/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.80	6.47	169.31	18.08	3.76	3.82
VMJH	07:59	2.27	5.91	172.60	18.08	3.83	3.68
VMJH	08:29	3.07	6.03	170.36	18.57	3.83	3.89
VMJH	08:59	1.47	6.63	170.78	17.94	3.91	3.71
VMJH	09:29	1.97	6.45	169.59	18.27	3.83	3.88
VMJH	09:59	2.27	6.58	169.33	18.34	3.89	3.48
VMJH	10:29	1.33	6.64	169.97	18.10	3.83	3.75
VMJH	10:59	2.80	6.92	171.23	17.56	3.69	3.60
VMJH	11:29	2.47	5.98	166.80	18.02	3.75	3.88
VMJH	11:59	2.60	6.63	170.34	18.05	4.01	3.70
VMJH	12:29	2.13	6.30	169.56	17.62	3.97	3.67
VMJH	12:59	1.67	4.50	144.14	16.59	3.64	3.67
VMJH	13:29	1.60	4.37	142.07	16.20	3.49	3.50
VMJH	13:59	1.67	4.27	144.47	16.18	3.54	3.54
VMJH	14:29	1.00	4.67	142.70	16.30	3.44	3.46
VMJH	14:59	1.63	4.37	144.00	16.63	3.57	3.38
VMJH	15:29	1.67	4.52	143.30	16.03	3.44	3.50
VMJH	15:59	2.13	4.52	142.99	16.05	3.42	3.44
VMJH	16:29	2.23	4.38	143.50	16.17	3.53	3.39
VMJH	16:59	2.27	4.60	145.01	16.35	3.73	3.54
VMJH	17:29	1.93	4.42	142.92	15.95	3.47	3.48
VMJH	17:59	1.53	4.50	143.64	16.55	3.63	3.44
VMJH	18:29	1.70	4.38	143.22	16.61	3.53	3.52
VMJH	18:59	1.40	4.48	143.29	16.50	3.64	3.40
VMJH	19:29	2.03	4.46	141.99	16.28	3.45	3.34
VMJH	19:59	1.90	4.39	143.79	16.32	3.50	3.53
VMJH	20:29	2.53	4.38	142.49	15.74	3.38	3.30
VMJH	20:59	1.87	4.48	143.72	16.55	3.63	3.50
VMJH	21:29	1.53	4.43	143.10	16.01	3.54	3.64
VMJH	21:59	0.87	4.53	143.16	16.58	3.55	3.41
VMJH	22:29	1.50	4.21	143.20	15.61	3.70	3.47
VMJH	22:47	2.00	4.47	143.29	16.22	3.56	3.39
VMZ		1.90	5.13	152.61	16.89	3.65	3.56

# Valori inregistrate MIR-IS HP-1500

Data:25/01/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	14:09	1.70	4.44	143.45	16.20	3.37	3.46
VMJH	14:39	1.13	4.54	141.58	15.85	3.66	3.62
VMJH	15:09	0.37	4.30	141.92	16.14	3.56	3.61
VMJH	15:39	0.33	4.44	143.27	16.76	3.55	3.42
VMJH	16:09	0.30	4.28	143.27	15.92	3.55	3.50
VMJH	16:39	1.03	4.50	143.17	17.02	3.79	3.37
VMJH	17:09	0.13	4.50	143.28	16.45	3.65	3.46
VMJH	17:39	0.20	4.31	143.88	16.63	3.39	3.42
VMJH	18:09	0.47	4.41	143.50	16.69	3.49	3.42
VMJH	18:39	0.13	4.48	142.96	16.80	3.53	3.54
VMJH	19:09	0.40	4.29	145.16	16.35	3.46	3.54
VMJH	19:39	0.23	4.37	142.88	16.25	3.55	3.51
VMJH	20:09	0.50	4.45	144.41	16.68	3.57	3.60
VMJH	20:39	0.43	4.61	143.52	16.03	3.32	3.55
VMJH	21:09	0.17	4.35	143.34	16.05	3.58	3.49
VMJH	21:39	0.20	4.37	141.61	16.29	3.44	3.46
VMJH	22:09	1.17	4.49	143.11	16.01	3.47	3.53
VMJH	22:39	0.27	4.46	142.60	15.81	3.47	3.44
VMJH	22:44	0.20	4.25	143.28	16.50	3.26	3.19
VMZ		0.51	4.42	143.16	16.33	3.52	3.49



# Valori inregistrate MIR-IS HP-1500

Data:26/01/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:29	0.37	4.42	143.03	16.08	3.61	3.57
VMJH	15:59	0.50	4.50	143.29	16.57	3.70	3.38
VMJH	16:29	0.30	4.50	142.87	16.34	3.44	3.55
VMJH	16:59	0.37	4.39	142.31	16.33	3.54	3.47
VMJH	17:29	0.63	4.54	143.04	16.66	3.61	3.50
VMJH	17:59	0.77	4.59	144.76	16.27	3.57	3.45
VMJH	18:29	0.60	4.45	143.09	16.34	3.64	3.29
VMJH	18:59	0.67	4.43	141.63	16.82	3.61	3.47
VMJH	19:29	0.33	4.34	143.02	15.94	3.54	3.36
VMJH	19:59	0.40	5.30	167.55	20.34	4.56	4.05
VMJH	20:29	0.30	5.35	169.30	20.39	4.57	3.67
VMJH	20:59	0.37	5.39	170.74	21.07	4.37	3.91
VMJH	21:29	0.43	5.11	170.28	19.98	4.28	3.88
VMJH	21:59	0.40	5.19	168.50	21.30	4.64	3.61
VMJH	22:29	0.20	5.37	169.66	20.02	4.61	3.75
VMJH	22:41	0.08	5.33	171.18	19.62	4.46	3.91
VMZ		0.43	4.81	154.02	18.07	3.97	3.60

# Valori inregistrate MIR-IS HP-1500

Data:27/01/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.03	5.40	170.92	20.16	4.64	3.78
VMJH	07:59	1.13	5.56	168.06	20.17	4.53	3.98
VMJH	08:29	0.47	5.34	169.38	20.76	4.54	3.81
VMJH	08:59	1.30	5.29	172.21	20.23	4.34	4.14
VMJH	09:29	0.47	5.40	170.66	20.17	4.36	3.89
VMJH	09:59	0.37	5.37	168.88	21.22	4.18	4.17
VMJH	10:29	1.00	5.33	169.27	20.71	4.44	3.86
VMJH	10:59	0.73	5.21	170.29	20.41	4.60	3.78
VMJH	11:29	0.87	5.36	173.03	19.31	4.67	3.62
VMJH	11:59	0.30	5.24	169.09	21.08	4.41	3.87
VMJH	12:29	1.07	5.28	171.83	20.56	4.32	3.78
VMJH	12:59	0.40	5.15	169.10	21.05	4.21	3.84
VMJH	13:29	0.97	5.50	170.63	20.55	4.53	3.86
VMJH	13:59	0.80	5.39	171.35	19.80	4.69	3.82
VMJH	14:29	0.70	5.34	170.45	19.91	4.54	3.80
VMJH	14:59	0.47	5.19	168.46	20.43	4.21	3.95
VMJH	15:29	0.37	5.49	170.75	19.75	5.05	3.69
VMJH	15:59	0.90	5.21	169.02	19.86	4.51	3.74
VMJH	16:29	0.47	5.50	170.96	19.79	4.58	3.87
VMJH	16:59	0.37	5.38	168.84	20.22	4.93	3.86
VMJH	17:29	0.90	5.24	169.40	21.02	4.49	4.23
VMJH	17:59	0.30	5.05	170.46	20.24	4.56	3.95
VMJH	18:29	0.07	5.29	171.53	19.77	4.52	3.69
VMJH	18:59	0.20	5.10	169.89	20.07	4.40	3.83
VMJH	19:29	1.03	4.89	169.61	19.52	4.69	4.17
VMJH	19:59	0.27	5.25	171.41	21.16	4.44	4.02
VMJH	20:29	0.97	5.19	170.53	20.70	4.74	3.71
VMJH	20:59	0.73	5.35	169.82	19.59	4.64	3.91
VMJH	21:29	0.60	5.39	167.00	20.49	4.38	3.90
VMJH	21:59	1.47	5.39	166.29	21.39	4.34	4.08
VMJH	22:29	0.37	5.22	170.35	20.99	4.51	3.57
VMJH	22:43	1.79	5.02	166.60	20.70	4.45	3.99
VMZ		0.70	5.29	169.93	20.36	4.51	3.88

# Valori inregistrate MIR-IS HP-1500

Data:30/01/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.33	5.33	172.21	19.36	4.59	3.90
VMJH	07:59	0.63	5.20	166.25	20.94	4.46	4.13
VMJH	08:29	0.83	5.46	168.92	20.42	4.24	3.90
VMJH	08:59	0.63	5.33	172.41	20.62	4.01	3.85
VMJH	09:29	0.33	5.32	171.58	21.11	4.48	4.03
VMJH	09:59	0.47	5.33	169.77	21.21	4.72	4.11
VMJH	10:29	0.57	5.35	172.51	19.87	4.47	3.95
VMJH	10:59	0.67	5.53	171.60	19.93	4.46	3.93
VMJH	11:29	0.50	5.24	170.57	21.30	4.62	3.95
VMJH	11:59	0.87	5.37	170.72	21.20	4.64	3.77
VMJH	12:29	0.73	3.96	128.37	14.13	3.14	3.36
VMJH	12:59	0.50	3.40	116.77	12.16	2.75	3.07
VMJH	13:29	1.13	3.56	117.04	12.64	2.72	3.15
VMJH	13:59	1.97	3.50	115.81	12.33	2.61	3.03
VMJH	14:29	0.23	3.92	117.65	11.62	2.40	3.26
VMJH	14:59	0.57	3.48	117.44	12.92	2.50	3.07
VMJH	15:29	0.53	3.70	116.75	12.22	2.64	3.06
VMJH	15:59	0.77	3.81	116.15	12.57	2.69	2.96
VMJH	16:29	0.50	3.51	117.56	11.65	2.80	2.95
VMJH	16:59	0.77	3.72	115.41	12.37	2.52	3.02
VMJH	17:29	0.30	3.59	117.21	12.27	2.54	3.01
VMJH	17:59	1.40	3.69	116.90	12.36	2.67	3.21
VMJH	18:29	0.27	3.44	115.03	12.24	2.56	3.19
VMJH	18:59	0.83	3.58	117.39	11.97	2.53	3.17
VMJH	19:29	0.80	3.35	117.40	12.84	2.61	3.07
VMJH	19:59	0.53	3.55	116.84	12.26	2.66	3.34
VMJH	20:29	0.60	3.51	117.30	12.95	2.76	3.25
VMJH	20:59	0.47	3.62	116.28	12.91	2.71	3.10
VMJH	21:29	0.57	3.71	117.91	12.35	2.67	3.05
VMJH	21:59	0.33	3.57	115.38	12.18	2.83	3.00
VMJH	22:30	0.35	3.65	116.67	11.73	2.73	3.13
VMZ		0.56	3.57	116.90	12.40	2.69	3.14



# Valori inregistrate MIR-IS HP-1500

Data:31/01/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	08:53	0.63	3.68	115.61	12.06	2.49	3.11
VMJH	09:23	0.83	3.48	116.02	12.61	2.55	3.13
VMJH	09:53	0.40	3.59	115.39	11.91	2.67	3.01
VMJH	10:23	0.67	3.51	115.98	12.36	2.55	3.16
VMJH	10:53	0.77	3.59	114.78	11.94	2.77	3.01
VMJH	11:23	0.37	3.55	115.80	11.59	2.85	3.23
VMJH	11:53	0.37	3.51	115.47	12.12	2.74	3.22
VMJH	12:23	0.93	3.61	116.32	11.77	2.91	3.28
VMJH	12:53	1.17	3.65	114.99	11.30	2.52	3.12
VMJH	13:23	0.43	3.33	116.80	11.42	2.76	3.05
VMJH	13:53	0.83	3.80	115.06	11.61	2.74	3.23
VMJH	14:23	1.50	3.24	116.49	12.36	2.33	3.09
VMJH	14:53	0.70	3.58	118.03	12.60	2.47	3.20
VMJH	15:23	0.70	3.52	117.20	12.19	2.71	3.13
VMJH	15:53	1.13	3.98	116.06	12.64	2.60	3.23
VMJH	16:23	0.97	3.59	113.86	12.06	2.73	2.98
VMJH	16:53	0.80	3.63	117.55	11.90	2.50	3.31
VMJH	17:23	0.93	3.58	116.71	12.28	2.61	3.03
VMJH	17:53	0.83	3.52	117.70	11.80	2.92	3.08
VMJH	18:23	0.67	3.61	117.47	11.87	2.56	3.05
VMJH	18:53	0.37	3.41	117.79	12.06	2.55	3.03
VMJH	19:23	0.63	3.44	117.90	11.64	2.57	3.09
VMJH	19:53	0.50	3.61	115.53	12.06	2.61	3.05
VMJH	20:23	0.40	3.61	115.13	12.44	2.86	3.03
VMJH	20:53	0.30	3.66	115.64	12.59	2.43	3.17
VMJH	21:23	1.20	3.40	117.60	11.82	2.54	3.29
VMJH	21:53	1.03	3.50	117.57	11.98	2.77	3.09
VMJH	22:23	0.80	4.19	137.07	15.26	3.24	3.64
VMJH	22:36	0.69	4.40	142.27	16.01	3.84	3.48
VMZ		0.74	3.60	117.46	12.21	2.68	3.15

# Valori inregistrate MIR-IS HP-1500

Data:01/02/202

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.53	2.49	141.53	17.04	3.18	3.51
VMJH	07:59	1.67	2.49	142.97	16.43	3.19	3.53
VMJH	08:29	1.13	2.56	142.92	16.96	3.29	3.59
VMJH	08:59	1.40	2.56	143.05	16.66	3.24	3.25
VMJH	09:29	1.17	2.49	142.20	16.42	3.13	3.51
VMJH	09:59	1.30	2.48	144.80	16.50	3.22	3.43
VMJH	10:29	0.80	2.49	143.20	16.42	3.29	3.47
VMJH	10:59	1.67	2.49	142.28	17.01	3.20	3.48
VMJH	11:29	1.43	2.57	141.55	16.29	3.43	3.31
VMJH	11:59	0.87	2.47	141.84	16.32	3.37	3.42
VMJH	12:29	0.93	2.48	142.49	16.60	3.12	3.33
VMJH	12:59	1.60	2.50	143.37	16.45	3.35	3.44
VMJH	13:29	1.70	2.49	142.62	16.20	3.14	3.36
VMJH	13:59	1.43	2.44	141.37	16.40	3.28	3.45
VMJH	14:29	0.93	2.33	142.97	16.44	3.36	3.37
VMJH	14:59	1.57	2.42	143.40	16.67	3.16	3.36
VMJH	15:29	0.83	2.46	143.21	15.90	3.08	3.51
VMJH	15:59	1.57	2.50	141.61	16.75	3.22	3.49
VMJH	16:29	1.50	2.52	142.61	16.38	3.22	3.34
VMJH	16:59	1.10	2.45	141.35	17.17	3.39	3.34
VMJH	17:29	1.27	2.44	143.23	16.15	3.22	3.44
VMJH	17:59	1.10	2.46	143.02	16.58	3.15	3.44
VMJH	18:29	1.27	2.48	144.48	16.34	2.99	3.45
VMJH	18:59	1.13	2.53	142.53	16.35	3.01	3.41
VMJH	19:29	1.00	2.48	143.66	16.41	3.18	3.55
VMJH	19:59	1.17	2.48	143.09	16.60	3.26	3.35
VMJH	20:29	0.63	2.57	142.06	16.28	3.25	3.50
VMJH	20:59	1.60	2.50	142.85	15.89	3.19	3.45
VMJH	21:29	0.80	2.44	143.26	16.87	3.10	3.38
VMJH	21:59	1.23	2.54	142.99	16.57	3.41	3.35
VMJH	22:29	0.87	2.50	142.49	16.17	3.21	3.35
VMJH	22:45	0.88	2.48	143.79	16.28	3.24	3.46
VMZ		1.23	2.49	142.76	16.49	3.22	3.43



# Valori inregistrate MIR-IS HP-1500

Data:02/02/202

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.77	2.49	142.00	16.67	3.18	3.44
VMJH	07:59	1.67	2.49	143.49	16.31	3.36	3.51
VMJH	08:29	0.80	2.46	142.78	16.29	3.26	3.21
VMJH	08:59	1.67	2.51	142.70	16.51	3.32	3.46
VMJH	09:29	0.87	2.44	142.23	16.39	3.04	3.35
VMJH	09:59	1.47	2.49	142.76	16.72	3.37	3.50
VMJH	10:29	0.37	2.33	141.14	16.83	3.18	3.66
VMJH	10:59	1.47	2.46	143.70	16.47	3.24	3.41
VMJH	11:29	1.50	2.56	142.08	16.43	3.23	3.24
VMJH	11:59	1.37	2.38	142.08	16.64	3.31	3.34
VMJH	12:29	1.13	2.49	140.20	16.50	3.17	3.43
VMJH	12:59	1.73	2.47	143.29	16.20	3.33	3.42
VMJH	13:29	1.37	2.47	144.36	16.39	3.35	3.33
VMJH	13:59	1.67	2.50	141.90	16.33	3.44	3.30
VMJH	14:29	1.20	2.50	142.63	16.84	3.12	3.49
VMJH	14:59	1.57	2.48	142.48	16.17	3.22	3.35
VMJH	15:29	1.10	3.08	158.21	18.03	3.24	3.40
VMJH	15:59	1.73	3.52	172.09	21.27	3.07	3.55
VMJH	16:29	2.17	3.43	173.87	21.70	3.18	3.55
VMJH	16:59	1.33	3.47	171.77	21.10	3.32	3.68
VMJH	17:29	0.43	3.47	172.32	21.40	3.28	3.82
VMJH	17:59	1.80	3.41	173.94	20.94	3.32	3.73
VMJH	18:29	1.63	3.45	173.92	20.70	3.26	3.77
VMJH	18:59	1.37	3.49	170.89	20.66	3.42	3.53
VMJH	19:29	1.30	3.38	171.60	21.13	3.05	3.81
VMJH	19:59	1.07	3.42	171.48	20.85	3.16	3.62
VMJH	20:29	0.93	3.36	172.13	20.51	3.27	3.77
VMJH	20:59	0.97	3.50	174.72	21.27	3.20	3.75
VMJH	21:29	0.90	3.49	171.35	20.77	3.32	3.83
VMJH	21:59	0.80	3.50	171.45	20.26	3.27	3.69
VMJH	22:29	1.37	3.38	171.20	20.65	3.11	3.70
VMJH	22:48	0.74	3.37	168.08	21.16	3.06	3.69
VMZ		1.29	2.94	156.71	18.60	3.24	3.54



# Valori inregistrate MIR-IS HP-1500

Data:01/02/202

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	07:39	1.17	3.48	171.55	20.72	3.20	3.62
VMJH	08:09	1.43	3.55	172.26	20.10	3.24	3.65
VMJH	08:39	1.50	3.47	171.97	20.70	3.41	3.93
VMJH	09:09	0.80	3.39	172.08	20.56	3.24	3.53
VMJH	09:39	1.33	3.45	173.39	20.87	3.35	3.99
VMJH	10:09	1.27	3.37	171.19	20.94	3.25	3.82
VMJH	10:39	1.20	3.55	172.16	20.10	3.14	3.89
VMJH	11:09	0.90	3.41	171.94	20.26	3.33	3.68
VMJH	11:39	0.87	3.59	171.44	20.85	3.16	3.72
VMJH	12:09	0.90	3.47	172.14	20.75	3.32	3.72
VMJH	12:39	1.13	3.52	172.46	20.61	3.14	3.84
VMJH	13:09	1.67	3.56	169.74	21.33	3.37	3.65
VMJH	13:39	1.50	3.33	173.09	21.81	3.37	3.54
VMJH	14:09	1.40	3.47	172.14	22.14	3.19	3.72
VMJH	14:39	1.70	3.50	172.01	21.04	3.11	3.69
VMJH	15:09	2.13	3.54	173.10	20.88	3.40	3.71
VMJH	15:39	0.80	3.45	171.44	20.58	3.35	3.47
VMJH	16:09	1.33	3.44	173.71	21.60	3.15	3.47
VMJH	16:39	1.33	3.43	170.69	20.03	3.48	3.59
VMJH	17:09	1.37	3.50	169.39	20.82	3.10	3.60
VMJH	17:39	1.13	3.58	172.86	20.90	3.30	3.68
VMJH	18:09	0.80	3.47	172.30	20.35	3.27	3.63
VMJH	18:39	0.90	3.52	175.27	20.96	3.37	3.84
VMJH	19:09	1.07	3.60	172.35	20.67	3.26	3.84
VMJH	19:39	0.80	3.41	174.52	20.01	3.17	3.59
VMJH	20:09	1.73	3.52	173.21	20.66	3.24	3.93
VMJH	20:39	1.37	3.47	172.31	21.20	3.25	3.46
VMJH	21:09	1.40	3.44	173.33	20.38	3.28	3.39
VMJH	21:39	0.80	3.52	172.92	19.73	3.38	3.92
VMJH	22:09	1.53	3.59	173.42	20.05	3.38	3.73
VMJH	22:40	1.45	3.51	175.05	21.35	3.30	3.41
VMZ		1.25	3.49	172.44	20.74	3.27	3.69

# Valori inregistrate MIR-IS HP-1500

Data:04/02/202

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.53	3.55	172.39	21.56	3.20	3.54
VMJH	07:59	1.33	3.32	164.34	20.26	3.25	3.62
VMJH	08:29	1.30	2.23	139.76	17.24	2.81	3.52
VMJH	08:59	1.90	2.19	143.47	17.60	2.83	3.56
VMJH	09:29	1.17	2.20	141.66	17.57	2.79	3.51
VMJH	09:59	1.70	2.19	140.60	18.09	2.94	3.52
VMJH	10:29	1.30	2.22	141.26	17.90	2.84	3.41
VMJH	10:59	1.50	2.20	140.57	18.05	2.76	3.38
VMJH	11:29	1.13	2.19	141.72	17.38	2.77	3.44
VMJH	11:59	1.37	2.15	139.78	17.23	2.81	3.39
VMJH	12:29	1.60	2.18	140.43	16.81	2.83	3.33
VMJH	12:59	1.17	2.12	141.99	17.10	2.92	3.34
VMJH	13:24	0.80	2.12	140.44	17.89	2.82	3.21
VMZ		1.38	2.38	145.32	18.05	2.89	3.45

# Valori inregistrate MIR-IS HP-1500

Data:06/02/202

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	12:29	1.27	2.19	141.91	17.93	2.86	3.55
VMJH	12:59	1.30	2.18	141.22	18.00	2.79	3.38
VMJH	13:29	1.17	2.20	140.95	16.84	2.84	3.44
VMJH	13:59	1.10	2.10	140.61	18.22	2.85	3.49
VMJH	14:29	0.73	2.17	141.98	16.82	2.82	3.29
VMJH	14:59	0.93	2.21	142.21	17.22	2.86	3.35
VMJH	15:29	1.27	2.20	142.73	17.20	2.81	3.29
VMJH	15:59	1.53	2.17	142.27	17.56	2.74	3.53
VMJH	16:29	1.67	2.17	141.77	17.48	2.80	3.35
VMJH	16:59	1.23	2.19	142.13	17.78	2.95	3.42
VMJH	17:29	1.47	2.16	142.24	17.41	2.74	3.54
VMJH	17:59	1.37	2.22	142.06	17.64	2.73	3.41
VMJH	18:29	1.23	2.20	141.18	17.43	2.84	3.26
VMJH	18:59	1.23	2.18	141.33	17.37	2.87	3.28
VMJH	19:29	1.07	2.20	142.75	17.46	2.84	3.45
VMJH	19:59	0.80	2.23	141.21	17.99	2.78	3.50
VMJH	20:29	1.20	2.16	140.67	17.19	2.79	3.32
VMJH	20:59	0.87	2.15	142.19	16.92	2.79	3.46
VMJH	21:29	1.17	2.20	141.04	17.96	2.80	3.52
VMJH	21:59	1.27	2.18	141.97	17.98	2.81	3.32
VMJH	22:29	1.33	2.13	141.23	17.52	2.88	3.42
VMJH	22:36	0.57	2.22	141.68	16.85	2.88	3.74
VMZ		1.19	2.18	141.70	17.51	2.82	3.41



# Valori inregistrate MIR-IS HP-1500

Data:07/02/202

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.20	2.22	142.04	17.72	2.89	3.41
VMJH	07:59	1.43	2.18	141.36	17.40	2.80	3.35
VMJH	08:29	1.40	2.14	139.43	17.11	2.74	3.46
VMJH	08:59	1.27	2.19	141.10	17.12	2.83	3.52
VMJH	09:29	1.43	2.15	141.15	17.60	2.83	3.64
VMJH	09:59	1.23	2.24	140.69	17.19	2.81	3.43
VMJH	10:29	0.80	2.18	142.41	18.03	2.79	3.65
VMJH	10:59	1.70	2.17	141.04	17.76	2.93	3.44
VMJH	11:29	1.10	2.15	141.14	17.57	2.84	3.40
VMJH	11:59	0.97	2.16	141.03	17.77	2.85	3.29
VMJH	12:29	0.90	2.20	141.99	17.29	2.72	3.35
VMJH	12:59	0.97	2.20	141.93	17.43	2.89	3.51
VMJH	13:29	1.40	2.20	141.80	17.67	2.83	3.39
VMJH	13:59	1.17	2.14	141.31	17.75	2.83	3.29
VMJH	14:29	1.17	2.17	141.35	17.56	2.77	3.41
VMJH	14:59	1.07	2.33	148.92	18.25	2.97	3.46
VMJH	15:29	1.80	2.82	171.93	21.34	3.52	3.56
VMJH	15:59	1.83	2.82	171.77	21.42	3.48	3.79
VMJH	16:29	1.37	2.85	176.52	20.73	3.59	3.92
VMJH	16:59	1.67	2.80	172.14	21.46	3.48	3.78
VMJH	17:29	1.53	2.82	173.11	20.75	3.49	3.45
VMJH	17:59	1.77	2.81	171.24	20.58	3.43	3.71
VMJH	18:29	1.90	2.78	171.89	21.38	3.68	3.63
VMJH	18:59	1.27	2.84	171.20	21.50	3.38	3.59
VMJH	19:29	1.73	2.83	171.03	20.72	3.44	3.53
VMJH	19:59	1.30	2.75	170.83	20.83	3.41	3.77
VMJH	20:29	1.97	2.83	170.87	20.47	3.37	3.53
VMJH	20:59	1.27	2.81	172.20	20.36	3.43	3.85
VMJH	21:29	1.20	2.77	169.79	22.06	3.58	3.59
VMJH	21:59	1.23	2.79	172.84	20.23	3.48	4.08
VMJH	22:30	1.74	2.83	172.87	20.90	3.37	3.69
VMZ		1.38	2.49	156.43	19.23	3.14	3.56

# Valori inregistrate MIR-IS HP-1500

Data:08/02/202

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	2.27	2.81	172.23	21.11	3.45	3.88
VMJH	07:59	1.33	2.83	175.17	20.59	3.54	3.56
VMJH	08:29	1.60	2.82	173.06	19.29	3.65	3.62
VMJH	08:59	1.43	2.86	173.18	20.62	3.41	4.00
VMJH	09:29	2.30	2.79	171.67	20.54	3.39	3.75
VMJH	09:59	1.93	2.84	172.36	20.25	3.54	3.92
VMJH	10:29	2.07	2.84	171.60	19.60	3.49	3.53
VMJH	10:59	2.03	2.85	172.55	20.51	3.39	3.89
VMJH	11:29	1.53	2.80	173.61	20.78	3.51	3.61
VMJH	11:59	1.03	2.83	173.15	21.42	3.52	3.51
VMJH	12:29	1.17	2.75	170.54	21.57	3.58	3.73
VMJH	12:59	1.60	2.79	173.11	20.52	3.45	3.56
VMJH	13:29	1.10	2.83	173.20	20.67	3.51	3.48
VMJH	13:59	1.23	2.85	172.03	20.80	3.50	3.81
VMJH	14:29	1.00	2.80	172.40	21.24	3.44	3.51
VMJH	14:59	1.33	2.80	172.86	20.50	3.46	3.83
VMJH	15:29	0.73	2.86	173.72	21.16	3.54	3.55
VMJH	15:59	0.83	2.76	172.01	20.86	3.40	3.79
VMJH	16:29	0.77	2.78	172.68	20.95	3.55	3.58
VMJH	16:59	1.30	2.79	173.10	21.77	3.36	3.79
VMJH	17:29	0.97	2.84	173.72	20.82	3.61	3.53
VMJH	17:59	1.60	2.85	171.45	20.42	3.47	3.77
VMJH	18:29	1.00	2.78	171.55	20.60	3.56	3.75
VMJH	18:59	0.90	2.81	171.84	21.13	3.47	3.58
VMJH	19:29	0.47	2.86	172.57	20.04	3.38	3.57
VMJH	19:59	1.10	2.85	171.14	20.04	3.59	3.50
VMJH	20:29	0.70	2.85	172.65	20.15	3.58	3.82
VMJH	20:59	1.43	2.80	174.23	20.45	3.45	3.67
VMJH	21:29	0.87	2.83	173.86	21.19	3.55	3.79
VMJH	21:59	1.07	2.76	173.12	20.93	3.45	3.69
VMJH	22:24	0.76	2.80	171.62	20.73	3.60	3.59
VMZ		1.28	2.82	172.65	20.68	3.50	3.68



# Valori inregistrate MIR-IS HP-1500

Data:09/02/202

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.07		2.83		173.13		21.33		3.41		3.66	
VMJH	07:59	1.10		2.71		164.97		19.20		3.33		3.76	
VMJH	08:29	0.90		1.60		110.59		14.29		2.10		3.11	
VMJH	08:59	1.10		1.59		111.18		14.19		2.12		3.11	
VMJH	09:29	1.10		1.63		111.51		14.24		2.02		3.12	
VMJH	09:59	0.80		1.67		111.07		13.60		2.09		3.02	
VMJH	10:29	0.90		1.60		109.32		13.88		2.08		3.23	
VMJH	10:59	1.67		1.45		108.54		13.64		2.18		3.26	
VMJH	11:29	1.30		1.54		111.55		13.90		2.24		3.24	
VMJH	11:59	1.40		1.59		109.67		13.62		2.14		3.09	
VMJH	12:29	0.63		1.49		112.63		13.47		2.11		3.24	
VMJH	12:59	1.00		1.55		109.44		13.88		2.18		3.30	
VMJH	13:29	1.30		1.56		110.18		13.83		2.09		3.11	
VMJH	13:59	1.07		1.56		111.28		15.29		2.20		3.27	
VMJH	14:29	1.40		1.51		109.45		14.52		2.13		2.89	
VMJH	14:59	1.23		1.45		109.81		13.84		2.01		3.12	
VMJH	15:29	0.73		1.54		109.49		14.10		2.01		2.99	
VMJH	15:59	0.97		1.57		110.14		14.62		2.07		3.17	
VMJH	16:29	0.83		1.54		110.54		14.65		2.17		3.00	
VMJH	16:59	1.67		1.50		111.90		14.62		2.11		3.10	
VMJH	17:29	1.03		1.56		111.40		15.15		2.23		3.18	
VMJH	17:59	1.33		1.65		110.69		14.11		2.15		3.11	
VMJH	18:29	1.27		1.50		109.20		14.15		2.29		3.21	
VMJH	18:59	1.00		1.47		110.51		14.51		2.13		3.13	
VMJH	19:29	1.23		1.52		109.33		13.72		2.15		3.33	
VMJH	19:59	1.40		1.55		111.42		14.65		2.09		3.17	
VMJH	20:29	1.13		1.50		111.59		14.71		2.24		3.02	
VMJH	20:59	1.00		1.53		110.05		14.06		2.14		3.02	
VMJH	21:29	1.43		1.50		110.47		15.88		2.28		3.11	
VMJH	21:59	1.90		1.57		111.06		14.18		2.15		3.19	
VMJH	22:12	1.23		1.59		110.95		14.38		2.03		3.06	
VMZ		1.16		1.63		114.35		14.66		2.22		3.17	



# Valori inregistrate MIR-IS HP-1500

Data:10/02/202

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:40	1.93	1.51	112.20	14.52	2.11	3.05
VMJH	08:10	1.17	1.68	110.87	14.79	2.10	2.96
VMJH	08:40	1.13	1.51	111.73	15.05	2.12	3.07
VMJH	09:10	2.13	1.54	111.75	14.45	2.08	3.13
VMJH	09:40	1.17	1.61	109.58	15.81	2.10	3.06
VMJH	10:10	0.93	1.63	109.44	14.60	2.13	3.26
VMJH	10:40	2.30	1.65	109.22	13.95	2.23	3.22
VMJH	11:10	1.80	1.43	112.06	14.40	1.95	3.18
VMJH	11:40	1.13	1.58	110.79	14.46	2.12	3.19
VMJH	12:10	1.40	1.56	110.33	13.90	2.00	3.15
VMJH	12:40	0.97	1.59	109.47	14.59	2.17	3.17
VMJH	13:10	1.23	1.58	110.32	13.74	2.20	3.20
VMJH	13:40	1.27	1.58	109.96	13.80	2.34	3.26
VMJH	14:10	0.93	1.70	110.30	14.29	1.89	3.23
VMJH	14:40	1.33	1.62	110.39	14.15	2.16	3.04
VMJH	15:10	1.07	1.48	109.89	14.30	2.20	3.13
VMJH	15:40	1.07	1.55	111.59	13.47	2.22	3.28
VMJH	16:10	1.50	1.62	110.02	14.85	2.15	3.09
VMJH	16:40	1.47	1.50	109.16	14.69	2.15	3.06
VMJH	17:10	0.73	2.04	115.15	15.29	2.20	3.01
VMJH	17:40	1.60	2.27	116.25	15.27	2.05	3.15
VMJH	18:10	1.43	2.51	113.48	14.84	2.11	3.16
VMJH	18:40	1.23	2.33	113.83	15.10	1.86	3.22
VMJH	19:10	1.13	2.28	117.56	14.70	2.00	3.20
VMJH	19:40	1.67	2.40	113.24	14.98	1.98	3.16
VMJH	20:10	1.90	2.33	115.57	15.03	2.11	3.28
VMJH	20:40	0.90	2.45	114.75	14.92	2.14	3.12
VMJH	21:10	1.50	2.28	113.76	14.69	2.03	3.23
VMJH	21:40	2.10	2.41	115.84	15.12	2.10	3.25
VMJH	22:10	1.20	2.33	113.84	15.11	2.14	3.12
VMJH	22:42	1.28	2.31	112.34	14.72	2.11	3.20
VMZ		1.37	1.87	112.09	14.63	2.10	3.16

# Valori inregistrate MIR-IS HP-1500

Data:13/02/202

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	11:39	1.13	2.53	112.81	15.18	2.06	3.08
VMJH	12:09	1.77	2.40	115.32	15.17	2.00	3.27
VMJH	12:39	0.97	2.52	112.57	14.51	2.01	3.19
VMJH	13:09	1.53	2.25	114.60	15.38	2.05	3.13
VMJH	13:39	0.83	2.35	113.10	14.23	1.93	3.10
VMJH	14:09	1.33	2.31	114.69	14.86	2.14	2.99
VMJH	14:39	1.40	2.45	113.79	15.04	2.00	3.20
VMJH	15:09	0.93	2.53	113.22	15.15	2.00	3.31
VMJH	15:39	2.13	2.46	115.38	14.78	2.16	3.10
VMJH	16:09	0.70	2.26	112.14	15.00	2.04	3.03
VMJH	16:39	0.37	2.43	113.69	14.59	2.06	3.07
VMJH	17:09	0.47	2.29	116.05	15.58	2.13	3.05
VMJH	17:39	0.40	2.31	112.77	15.28	2.02	3.23
VMJH	18:09	0.57	2.37	113.72	15.61	1.90	3.19
VMJH	18:39	0.63	2.39	113.86	14.63	1.95	3.04
VMJH	19:09	0.77	2.44	113.01	14.84	2.06	3.14
VMJH	19:39	0.47	2.25	114.02	14.52	2.13	3.15
VMJH	20:09	0.37	2.40	116.02	15.22	2.24	3.08
VMJH	20:39	0.37	2.25	114.01	14.95	1.97	3.08
VMJH	21:09	0.67	2.43	114.48	15.22	2.17	3.06
VMJH	21:39	1.67	2.31	113.59	15.22	2.20	3.06
VMJH	22:09	1.53	2.30	113.08	15.09	1.95	3.22
VMJH	22:39	1.33	2.32	114.08	15.29	1.94	3.21
VMJH	22:45	1.83	2.46	112.01	14.97	1.78	3.07
VMZ		0.98	2.37	113.90	15.01	2.05	3.13



# Valori inregistrate MIR-IS HP-1500

Data:14/02/202

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.50	2.29	111.47	14.96	2.15	3.22
VMJH	07:59	2.10	2.37	112.24	14.59	2.17	3.21
VMJH	08:29	1.33	2.45	112.26	15.15	1.94	3.16
VMJH	08:59	1.63	2.39	114.84	14.73	2.18	3.14
VMJH	09:29	2.33	2.40	115.53	15.18	1.99	3.08
VMJH	09:59	1.57	2.30	114.35	15.23	2.03	3.06
VMJH	10:29	1.97	2.61	113.82	15.34	2.13	3.01
VMJH	10:59	1.50	2.34	113.89	14.97	2.14	3.16
VMJH	11:29	1.80	2.41	114.52	14.80	2.16	3.10
VMJH	11:59	1.80	2.45	112.68	15.21	2.09	3.08
VMJH	12:29	0.97	2.52	113.09	14.85	2.18	3.18
VMJH	12:59	1.60	2.33	111.27	14.83	2.24	2.95
VMJH	13:29	0.97	2.32	114.34	15.18	2.11	3.25
VMJH	13:59	2.50	3.13	138.34	17.33	2.72	3.30
VMJH	14:29	0.77	3.31	142.58	17.87	2.75	3.37
VMJH	14:59	1.93	3.20	143.19	18.19	2.71	3.49
VMJH	15:29	2.20	3.28	143.18	18.22	2.86	3.34
VMJH	15:59	1.80	3.44	143.91	17.61	2.76	3.26
VMJH	16:29	1.60	3.29	141.33	17.93	2.82	3.36
VMJH	16:59	1.67	3.23	143.07	18.47	2.70	3.22
VMJH	17:29	1.57	3.29	144.44	17.80	2.79	3.24
VMJH	17:59	1.60	3.26	143.81	18.31	2.76	3.36
VMJH	18:29	1.73	3.23	144.90	17.78	2.72	3.16
VMJH	18:59	2.23	3.26	143.47	17.94	2.88	3.20
VMJH	19:29	1.00	3.32	143.65	17.79	2.86	3.36
VMJH	19:59	0.90	3.33	141.98	18.04	2.78	3.23
VMJH	20:29	1.17	3.37	141.09	17.81	2.75	3.27
VMJH	20:59	1.50	3.26	143.64	18.48	2.69	3.31
VMJH	21:29	1.07	3.16	144.94	18.29	2.71	3.22
VMJH	21:59	1.53	3.25	143.06	17.44	2.90	3.33
VMJH	22:29	1.40	3.30	144.26	18.06	2.80	3.44
VMJH	22:42	1.46	3.40	143.23	17.71	2.70	3.20
VMZ		1.59	2.91	130.80	16.74	2.50	3.23



# Valori inregistrate MIR-IS HP-1500

Data:15/02/202

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH	07:29	1.47	3.39	142.41	17.07	2.66	3.37
VMJH	07:59	1.13	3.31	143.29	18.19	2.69	3.40
VMJH	08:29	2.10	3.36	142.72	18.18	2.78	3.22
VMJH	08:59	1.40	3.36	143.53	17.51	2.67	3.35
VMJH	09:29	1.17	3.29	142.22	17.73	2.73	3.35
VMJH	09:59	1.67	3.30	145.59	18.56	2.85	3.50
VMJH	10:29	1.80	3.39	144.16	17.62	2.75	3.36
VMJH	10:59	0.37	3.25	144.33	17.66	2.86	3.16
VMJH	11:29	1.70	3.27	144.06	17.75	2.69	3.44
VMJH	11:59	1.33	3.22	144.20	17.57	2.80	3.39
VMJH	12:29	1.23	3.37	144.02	17.81	2.79	3.18
VMJH	12:59	1.37	3.30	143.28	18.69	2.68	3.33
VMJH	13:29	1.13	3.28	143.10	17.23	2.85	3.28
VMJH	13:59	0.93	3.37	143.12	18.19	2.71	3.16
VMJH	14:29	0.67	3.38	143.29	17.61	2.79	3.23
VMJH	14:59	1.63	3.32	142.16	17.51	2.73	3.36
VMJH	15:29	1.03	3.26	142.84	17.93	2.71	3.42
VMJH	15:59	1.07	3.26	142.17	17.89	2.71	3.40
VMJH	16:29	1.20	3.38	140.93	17.63	2.85	3.41
VMJH	16:59	1.20	3.24	143.00	16.98	2.81	3.35
VMJH	17:29	1.77	3.23	143.08	18.29	2.73	3.41
VMJH	17:59	1.63	3.46	141.48	17.74	2.84	3.30
VMJH	18:29	1.43	3.34	144.36	17.42	2.82	3.31
VMJH	18:59	1.70	3.39	143.21	17.41	2.80	3.32
VMJH	19:29	1.50	3.35	143.66	18.19	2.83	3.42
VMJH	19:59	1.77	3.31	143.81	17.83	2.83	3.42
VMJH	20:29	2.03	3.32	144.77	17.48	2.71	3.38
VMJH	20:59	1.07	3.46	143.28	17.48	2.75	3.42
VMJH	21:29	1.90	3.29	144.02	17.87	2.78	3.32
VMJH	21:59	1.43	3.55	150.37	17.89	2.99	3.04
VMJH	22:29	1.77	4.16	167.36	19.40	3.56	3.22
VMJH	22:45	1.31	4.07	167.66	19.04	3.59	3.33
VMZ		1.40	3.37	144.72	17.84	2.81	3.33

# Valori inregistrate MIR-IS HP-1500

Data:16/02/202

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.57	4.37	166.36	19.81	3.52	3.18
VMJH	07:59	1.07	4.20	166.00	19.34	3.45	3.38
VMJH	08:29	1.30	4.22	166.79	18.64	3.36	3.24
VMJH	08:59	1.30	4.27	167.01	19.57	3.51	3.41
VMJH	09:29	1.03	4.25	167.44	18.66	3.44	3.23
VMJH	09:59	0.73	4.26	166.80	18.93	3.44	3.29
VMJH	10:29	0.87	4.18	168.65	19.55	3.55	3.24
VMJH	10:59	0.83	4.16	167.74	18.74	3.41	3.23
VMJH	11:29	1.23	4.01	167.14	19.28	3.55	3.44
VMJH	11:59	0.93	4.36	168.43	18.91	3.56	3.29
VMJH	12:29	1.57	4.03	167.89	19.01	3.52	3.31
VMJH	12:59	1.07	4.14	166.14	19.22	3.45	3.33
VMJH	13:29	0.87	4.43	168.00	19.50	3.30	3.17
VMJH	13:59	0.50	4.31	168.76	19.09	3.52	3.33
VMJH	14:29	1.03	4.21	167.42	19.02	3.64	3.17
VMJH	14:59	0.77	4.19	167.33	18.97	3.47	3.20
VMJH	15:29	1.50	4.36	167.72	18.99	3.45	3.33
VMJH	15:59	0.80	4.11	167.40	18.97	3.48	3.30
VMJH	16:29	1.10	4.29	167.29	19.64	3.51	3.26
VMJH	16:59	0.67	4.25	166.46	19.28	3.50	3.19
VMJH	17:29	1.10	4.18	168.58	18.32	3.57	3.42
VMJH	17:59	1.23	4.22	167.13	19.20	3.58	3.39
VMJH	18:29	0.77	4.39	165.85	18.55	3.45	3.26
VMJH	18:59	1.20	4.21	167.79	18.75	3.45	3.28
VMJH	19:29	1.10	4.18	165.67	19.27	3.55	3.20
VMJH	19:59	0.70	4.37	165.99	19.76	3.54	3.25
VMJH	20:29	1.23	4.38	168.55	19.40	3.46	3.27
VMJH	20:59	1.37	4.20	166.72	18.30	3.47	3.47
VMJH	21:29	1.67	4.21	166.80	19.13	3.50	3.36
VMJH	21:59	1.00	4.33	167.02	19.29	3.45	3.25
VMJH	22:29	0.70	4.15	167.21	18.64	3.68	3.37
VMJH	22:46	1.18	4.55	168.14	19.20	3.42	3.37
VMZ		1.06	4.25	167.24	19.09	3.49	3.29



# Valori inregistrate MIR-IS HP-1500

Data:17/02/202

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.07	2.49	117.28	13.82	2.01	2.71
VMJH	07:59	1.17	2.33	109.27	13.01	1.73	2.76
VMJH	08:29	1.47	2.12	112.30	14.24	1.69	2.72
VMJH	08:59	1.33	2.21	112.41	13.10	1.77	2.71
VMJH	09:29	0.67	2.18	110.56	13.31	1.78	2.78
VMJH	09:59	0.97	2.23	111.47	12.99	1.79	2.67
VMJH	10:29	0.50	2.15	112.33	12.97	1.71	2.77
VMJH	10:59	2.00	2.12	111.25	13.27	1.75	2.69
VMJH	11:29	0.93	2.23	114.73	13.77	1.82	2.69
VMJH	11:59	1.53	2.21	111.21	13.12	1.86	2.68
VMJH	12:29	0.77	2.13	113.57	12.96	1.82	2.69
VMJH	12:59	1.27	2.19	114.85	13.39	1.76	2.74
VMJH	13:29	0.93	2.23	113.61	13.32	1.66	2.72
VMJH	13:59	1.80	2.12	113.98	13.10	1.74	2.81
VMJH	14:29	1.20	2.27	110.59	13.64	1.69	2.72
VMJH	14:59	3.20	2.28	111.71	12.75	1.76	2.71
VMJH	15:29	1.93	2.27	114.19	13.60	1.72	2.68
VMJH	15:59	2.00	2.32	112.48	13.26	1.68	2.73
VMJH	16:29	1.60	2.20	113.28	12.95	1.91	2.76
VMJH	16:59	2.07	2.34	111.95	13.43	1.90	2.73
VMJH	17:29	2.07	2.20	110.58	13.56	1.73	2.65
VMJH	17:59	1.50	2.18	115.27	13.34	1.82	2.66
VMJH	18:29	1.63	2.20	112.46	13.20	1.84	2.81
VMJH	18:59	1.87	2.30	112.43	13.30	1.76	2.68
VMJH	19:29	1.00	2.39	111.68	12.60	1.80	2.67
VMJH	19:59	1.53	2.19	115.29	13.87	1.88	2.66
VMJH	20:29	1.43	2.19	113.71	12.75	1.78	2.62
VMJH	20:59	1.37	2.20	111.75	13.04	1.80	2.82
VMJH	21:29	1.50	2.18	112.29	13.39	1.80	2.75
VMJH	21:59	0.97	2.18	111.90	13.72	1.87	2.67
VMJH	22:29	0.53	2.25	113.58	13.21	1.76	2.71
VMJH	22:48	0.84	2.25	114.61	13.65	1.88	2.62
VMZ		1.40	2.23	112.75	13.30	1.79	2.71



# Valori inregistrate MIR-IS HP-1500

Data:18/02/202

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.00	4.06	167.33	18.61	3.46	3.22
VMJH	07:59	1.43	4.26	167.73	19.33	3.52	3.33
VMJH	08:29	1.50	4.08	167.64	19.12	3.45	3.00
VMJH	08:59	2.03	4.27	167.20	18.87	3.46	3.24
VMJH	09:29	1.73	4.33	166.94	19.28	3.40	3.18
VMJH	09:59	1.43	4.06	167.69	19.22	3.56	3.26
VMJH	10:29	1.93	4.28	167.19	18.86	3.46	3.33
VMJH	10:59	1.70	4.23	167.67	19.11	3.47	3.08
VMJH	11:29	1.83	4.48	167.54	19.06	3.50	3.32
VMJH	11:59	1.77	4.19	169.20	19.25	3.49	3.43
VMJH	12:29	2.17	4.14	167.74	18.64	3.52	3.21
VMJH	12:59	1.93	4.14	167.77	19.35	3.57	3.30
VMJH	13:29	1.57	4.43	168.40	18.85	3.44	3.41
VMJH	13:59	1.10	4.29	167.98	19.68	3.55	3.17
VMJH	14:15	0.56	4.41	168.18	18.70	3.53	3.28
VMZ		1.61	4.24	167.73	19.07	3.49	3.25

# Valori inregistrate MIR-IS HP-1500

Data:20/02/202

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
VMJH	09:44	0.83	2.22	113.59	13.77	1.73	2.65
VMJH	10:14	1.07	2.11	112.14	13.10	1.71	2.69
VMJH	10:44	0.57	2.18	114.17	12.96	1.64	2.64
VMJH	11:14	0.27	2.17	112.70	13.27	1.69	2.72
VMJH	11:44	1.40	2.17	113.49	13.09	1.79	2.67
VMJH	12:14	0.77	2.28	114.14	13.42	1.75	2.68
VMJH	12:44	1.40	2.12	112.58	13.22	1.81	2.72
VMJH	13:14	0.60	2.19	111.88	13.13	1.74	2.70
VMJH	13:44	0.47	2.15	115.43	13.02	1.71	2.70
VMJH	14:14	1.57	2.24	114.77	13.16	1.77	2.63
VMJH	14:44	1.70	2.21	114.02	13.31	1.78	2.74
VMJH	15:14	1.10	2.20	113.38	13.17	1.66	2.66
VMJH	15:44	1.53	2.26	112.99	13.53	1.65	2.82
VMJH	16:14	1.03	2.14	114.89	12.86	1.87	2.74
VMJH	16:44	1.33	2.24	113.25	13.37	1.71	2.68
VMJH	17:14	0.80	2.18	112.41	13.50	1.82	2.70
VMJH	17:44	1.80	2.53	129.80	15.77	2.50	2.90
VMJH	18:14	1.27	3.21	144.20	17.60	3.14	2.88
VMJH	18:44	0.90	3.07	143.06	17.52	3.15	3.00
VMJH	19:14	0.97	3.06	143.66	17.29	3.13	3.00
VMJH	19:44	1.70	3.07	142.35	17.97	3.15	2.95
VMJH	20:14	1.67	3.10	143.91	17.31	3.08	3.03
VMJH	20:44	1.33	3.06	143.29	17.31	3.18	2.93
VMJH	21:14	0.90	3.00	144.48	17.26	3.24	3.10
VMJH	21:44	1.63	3.12	144.35	17.58	3.13	3.04
VMJH	22:14	0.77	3.08	144.54	17.59	3.21	2.91
VMJH	22:44	1.57	3.10	144.29	16.69	3.31	2.99
VMZ		1.15	2.54	125.32	14.88	2.30	2.81

# Valori inregistrate MIR-IS HP-1500

Data:21/02/202

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
VMJH	07:29	1.50	3.12	144.45	17.53	3.25	2.97					
VMJH	07:59	1.17	3.07	143.02	17.63	3.20	3.02					
VMJH	08:29	1.27	3.06	143.50	17.68	3.25	3.05					
VMJH	08:59	1.03	3.09	143.81	16.67	3.13	3.07					
VMJH	09:29	1.03	3.08	144.27	17.55	3.12	3.02					
VMJH	09:59	1.37	3.08	143.18	17.46	3.12	3.01					
VMJH	10:29	1.20	3.03	143.33	17.51	3.18	2.92					
VMJH	10:59	0.93	3.05	144.74	17.58	3.13	3.07					
VMJH	11:29	1.73	3.13	143.62	17.44	3.19	2.90					
VMJH	11:59	1.40	3.04	144.79	17.73	3.20	2.92					
VMJH	12:29	1.30	3.07	142.53	17.73	3.23	3.01					
VMJH	12:59	1.03	3.07	144.46	16.88	3.11	2.96					
VMJH	13:29	1.10	3.04	143.85	17.60	3.14	3.14					
VMJH	13:59	1.17	3.12	144.95	17.47	3.15	3.09					
VMJH	14:29	0.97	3.07	143.69	17.00	3.23	3.05					
VMJH	14:59	1.43	3.08	143.62	18.06	3.03	2.97					
VMJH	15:29	0.73	2.99	144.20	17.53	3.17	3.00					
VMJH	15:59	0.83	3.05	145.04	18.24	3.11	2.93					
VMJH	16:29	1.17	3.09	144.17	16.40	3.11	2.97					
VMJH	16:59	1.70	3.08	142.93	17.29	3.34	3.04					
VMJH	17:29	1.70	3.14	144.88	16.53	3.17	3.05					
VMJH	17:59	0.80	3.10	144.37	17.30	3.27	2.96					
VMJH	18:29	1.63	3.01	143.07	17.40	3.03	3.06					
VMJH	18:59	0.90	3.10	144.07	16.87	3.11	2.99					
VMJH	19:29	1.43	3.01	145.18	18.06	3.13	3.09					
VMJH	19:59	0.43	3.08	143.67	16.59	3.09	3.00					
VMJH	20:29	1.43	2.97	145.04	17.11	3.18	2.98					
VMJH	20:59	1.60	3.04	144.56	17.53	3.26	3.00					
VMJH	21:29	1.20	3.04	143.53	16.74	3.23	3.04					
VMJH	21:59	1.17	3.15	143.34	17.20	3.13	2.87					
VMJH	22:29	1.83	2.96	143.41	17.18	3.13	3.03					
VMJH	22:42	1.31	3.05	141.55	17.82	3.10	3.08					
VMZ		1.23	3.07	143.94	17.35	3.16	3.01					



# Valori inregistrate MIR-IS HP-1500

Data:22/02/202

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
VMJH	07:29	1.87	3.05	143.85	17.72	3.18	2.89					
VMJH	07:59	0.80	3.04	143.24	17.34	3.16	2.97					
VMJH	08:29	1.77	3.13	144.08	17.98	3.08	2.96					
VMJH	08:59	1.03	3.04	143.50	17.33	3.33	2.97					
VMJH	09:29	1.73	3.08	144.24	17.85	3.31	2.96					
VMJH	09:59	1.53	3.02	144.34	17.79	3.11	3.00					
VMJH	10:29	2.20	3.91	166.45	21.54	4.08	3.30					
VMJH	10:59	0.63	3.74	168.65	21.27	4.33	3.31					
VMJH	11:29	1.30	3.89	169.19	21.89	4.11	3.19					
VMJH	11:59	1.83	3.95	167.27	22.67	4.19	3.10					
VMJH	12:29	1.27	3.82	168.13	20.34	4.08	3.24					
VMJH	12:59	1.53	3.96	169.06	21.30	4.34	3.17					
VMJH	13:29	1.27	3.88	168.09	21.31	4.31	3.20					
VMJH	13:59	0.87	3.96	167.17	21.77	4.27	3.15					
VMJH	14:29	1.13	3.80	170.20	21.19	4.03	3.26					
VMJH	14:59	0.60	3.90	167.53	21.00	4.18	3.26					
VMJH	15:29	0.93	3.86	167.82	21.46	4.06	3.23					
VMJH	15:59	1.13	3.91	167.53	22.04	4.08	3.20					
VMJH	16:29	0.93	3.92	167.87	21.00	4.33	3.25					
VMJH	16:59	1.43	3.85	168.98	20.89	4.22	3.33					
VMJH	17:29	1.30	3.86	169.09	20.78	4.10	3.24					
VMJH	17:59	0.70	4.05	169.08	20.92	4.06	3.21					
VMJH	18:29	1.37	3.89	169.59	20.91	3.99	3.24					
VMJH	18:59	1.20	3.73	167.50	21.82	4.08	3.24					
VMJH	19:29	1.33	3.58	168.81	21.46	4.12	3.19					
VMJH	19:59	1.50	3.90	169.34	21.53	4.09	3.17					
VMJH	20:29	0.97	3.91	169.33	22.11	4.31	3.26					
VMJH	20:59	1.33	3.84	168.25	21.89	4.14	3.13					
VMJH	21:29	1.00	4.01	169.20	21.67	3.89	3.37					
VMJH	21:59	1.43	3.96	170.02	20.97	4.12	3.11					
VMJH	22:29	1.03	3.87	169.36	21.97	4.16	3.09					
VMJH	22:44	1.00	3.83	169.10	21.38	4.19	3.39					
VMZ		1.25	3.72	163.85	20.71	3.97	3.17					

# Valori inregistrate MIR-IS HP-1500

Data:23/02/202

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
VMJH	13:49	0.87	3.93		170.45		21.49		4.42		3.29	
VMJH	14:19	0.87	4.04		168.17		21.31		4.09		3.32	
VMJH	14:49	1.17	3.96		168.46		21.34		4.15		3.21	
VMJH	15:19	1.63	3.88		168.11		21.35		4.08		3.17	
VMJH	15:49	1.47	3.93		169.12		22.19		4.08		3.39	
VMJH	16:19	1.47	3.95		169.36		21.01		4.16		3.20	
VMJH	16:49	1.67	3.87		167.35		21.64		4.32		3.07	
VMJH	17:19	2.13	3.94		168.36		21.37		4.44		3.34	
VMJH	17:49	0.80	3.86		169.40		21.62		4.34		3.16	
VMJH	18:19	1.33	3.86		168.36		21.67		4.09		3.33	
VMJH	18:49	1.33	3.99		168.99		20.60		4.29		3.31	
VMJH	19:19	1.37	3.78		169.12		20.90		3.96		3.25	
VMJH	19:49	1.13	3.78		169.01		21.60		4.04		3.36	
VMJH	20:19	0.80	4.00		167.36		21.81		4.04		3.31	
VMJH	20:49	0.90	3.86		168.36		20.97		4.19		3.47	
VMJH	21:19	1.07	3.90		169.05		21.61		4.17		3.26	
VMJH	21:49	0.80	4.07		169.40		22.29		4.40		3.42	
VMJH	22:19	1.73	3.88		168.84		20.48		4.02		3.27	
VMJH	22:50	1.42	3.99		168.23		22.36		4.11		3.31	
VMZ		1.26	3.92		168.71		21.45		4.18		3.29	

# Valori inregistrate MIR-IS HP-1500

Data:24/02/202

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
VMJH	07:29	1.30	3.93	168.78	22.44	4.34	3.20					
VMJH	07:59	0.80	3.92	168.94	20.20	4.30	3.28					
VMJH	08:29	1.53	3.90	167.13	20.39	4.19	3.33					
VMJH	08:59	1.50	3.09	144.57	17.68	3.22	3.02					
VMJH	09:29	1.47	2.20	121.53	13.76	2.22	2.79					
VMJH	09:59	1.20	2.34	120.28	14.03	2.20	2.83					
VMJH	10:29	1.53	2.36	121.03	13.73	1.99	2.76					
VMJH	10:59	1.87	2.24	118.07	13.55	2.29	2.85					
VMJH	11:29	1.00	2.13	118.92	13.50	2.15	2.78					
VMJH	11:59	1.70	2.33	119.11	12.90	2.18	2.75					
VMJH	12:29	1.17	2.27	120.20	13.18	2.07	2.60					
VMJH	12:59	1.63	2.33	123.13	14.14	2.19	2.73					
VMJH	13:29	1.27	2.19	122.06	14.23	2.26	2.81					
VMJH	13:59	1.43	2.20	118.81	13.22	2.24	2.84					
VMJH	14:29	1.43	2.24	119.04	13.10	2.22	2.80					
VMJH	14:59	1.30	2.29	119.64	13.45	2.19	2.74					
VMJH	15:29	0.97	2.20	120.87	13.65	2.21	2.75					
VMJH	15:59	1.07	2.24	119.61	13.46	2.23	2.61					
VMJH	16:29	1.30	2.30	121.52	13.99	2.17	2.67					
VMJH	16:59	1.20	2.31	121.60	13.91	2.23	2.74					
VMJH	17:29	1.07	2.24	117.74	13.58	2.16	2.81					
VMJH	17:59	0.73	2.09	118.73	13.01	2.12	2.72					
VMJH	18:29	0.93	2.12	117.24	13.77	2.12	2.63					
VMJH	18:59	1.33	2.24	119.43	13.16	2.25	2.74					
VMJH	19:29	1.47	2.18	120.68	13.29	2.34	2.69					
VMJH	19:59	1.67	2.13	119.33	13.63	2.08	2.80					
VMJH	20:29	1.23	2.23	118.55	12.97	2.17	2.86					
VMJH	20:59	1.47	2.23	119.60	13.64	2.24	2.70					
VMJH	21:29	1.37	2.08	119.68	13.48	1.96	2.81					
VMJH	21:59	1.23	2.20	119.64	13.25	2.23	2.74					
VMJH	22:29	1.33	2.24	120.50	13.58	2.16	2.76					
VMJH	22:40	1.27	2.09	121.19	14.41	2.02	2.75					
VMZ		1.31	2.41	125.30	14.38	2.41	2.81					



# Valori inregistrate MIR-IS HP-1500

Data:25/02/202

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
VMJH 07:29	0.77	2.26	120.14	13.80	2.16	2.70
VMJH 07:59	1.00	2.24	119.96	13.68	2.13	2.70
VMJH 08:29	1.10	2.23	118.80	13.36	2.26	2.75
VMJH 08:59	1.07	2.21	121.35	13.50	2.10	2.84
VMJH 09:29	1.27	2.28	118.53	13.26	2.15	2.80
VMJH 09:59	1.10	2.24	118.93	13.36	2.21	2.66
VMJH 10:29	1.23	2.25	120.79	13.93	2.15	2.87
VMJH 10:59	1.40	2.19	120.96	13.84	2.22	2.77
VMJH 11:29	1.10	2.23	118.13	13.55	2.24	2.78
VMJH 11:59	1.47	2.12	119.60	13.16	2.15	2.70
VMJH 12:29	1.17	2.12	117.50	13.78	2.26	2.85
VMJH 12:59	1.73	2.19	116.99	13.40	2.20	2.76
VMJH 13:29	1.57	2.22	119.40	14.19	2.22	2.85
VMJH 13:36	1.00	2.23	120.60	14.87	2.18	2.85
VMZ	1.22	2.21	119.34	13.63	2.19	2.77

# Valori inregistrate MIR-IS HP-1500

Data:27/02/202

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
VMJH	12:29	1.63	2.31	119.43	13.80	2.30	2.72
VMJH	12:59	1.57	2.16	119.19	13.39	2.31	2.77
VMJH	13:29	1.77	2.21	118.67	13.45	2.22	2.82
VMJH	13:59	1.87	2.09	119.87	13.85	2.27	2.77
VMJH	14:29	1.27	2.23	119.31	14.33	2.34	2.67
VMJH	14:59	1.73	2.27	119.09	13.61	2.23	2.72
VMJH	15:29	1.33	2.37	120.81	13.49	2.03	2.78
VMJH	15:59	1.93	2.17	118.89	14.12	2.17	3.36
VMJH	16:29	1.27	2.19	120.48	14.63	2.13	3.24
VMJH	16:59	1.20	2.42	119.32	15.10	2.23	3.20
VMJH	17:29	1.53	2.14	118.67	15.42	2.18	3.33
VMJH	17:59	1.50	2.35	118.90	14.18	2.16	3.31
VMJH	18:29	2.27	2.48	118.98	14.47	2.12	3.07
VMJH	18:59	1.33	2.22	119.55	15.38	2.13	3.38
VMJH	19:29	1.60	2.34	118.74	14.87	2.24	3.23
VMJH	19:59	1.43	2.18	120.42	14.38	2.18	3.18
VMJH	20:29	2.30	2.38	118.59	13.91	2.14	3.23
VMJH	20:59	1.93	2.32	121.10	15.31	2.28	3.12
VMJH	21:29	2.07	2.30	118.07	14.32	2.27	3.33
VMJH	21:59	2.03	2.27	118.57	15.23	2.44	3.06
VMJH	22:29	1.53	2.32	120.99	15.19	2.12	3.08
VMJH	22:48	1.42	2.38	119.63	14.39	2.20	3.34
VMZ		1.66	2.28	119.42	14.40	2.21	3.07

# Valori inregistrate MIR-IS HP-1500

Data:28/02/202

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
VMJH	07:29	1.07	2.32	118.23	13.89	2.29	3.22					
VMJH	07:59	1.27	2.36	119.77	14.18	2.33	3.07					
VMJH	08:29	1.07	2.40	121.41	14.84	2.12	3.11					
VMJH	08:59	1.13	2.20	120.13	14.69	2.27	3.31					
VMJH	09:29	1.60	2.30	119.86	14.75	2.28	3.36					
VMJH	09:59	1.30	2.23	120.37	15.41	2.03	3.31					
VMJH	10:29	1.87	2.35	120.00	14.53	2.11	3.27					
VMJH	10:59	1.97	2.38	118.54	14.59	2.36	3.22					
VMJH	11:29	1.70	2.28	118.05	14.73	2.19	3.37					
VMJH	11:59	1.80	2.31	119.83	14.37	2.20	3.19					
VMJH	12:29	1.87	2.10	118.43	14.66	2.14	3.24					
VMJH	12:59	1.13	2.21	118.36	14.32	2.16	3.16					
VMJH	13:29	1.87	2.36	119.53	14.64	2.17	3.30					
VMJH	13:59	1.63	2.24	120.05	14.42	2.21	3.25					
VMJH	14:29	1.37	2.32	118.94	14.59	2.24	3.22					
VMJH	14:59	0.73	2.29	120.11	14.36	2.11	3.14					
VMJH	15:29	1.37	2.22	119.90	14.54	1.92	3.31					
VMJH	15:59	0.43	2.33	118.90	13.92	2.23	3.08					
VMJH	16:29	0.73	2.21	120.15	15.08	2.18	3.11					
VMJH	16:59	0.17	2.28	119.29	14.83	2.10	3.24					
VMJH	17:29	1.27	2.54	120.21	15.09	2.15	3.16					
VMJH	17:59	1.50	2.22	119.35	15.04	2.15	3.16					
VMJH	18:29	1.23	2.42	117.69	15.17	2.15	3.23					
VMJH	18:59	1.00	2.45	120.34	14.75	1.97	3.39					
VMJH	19:29	0.73	2.40	118.00	15.22	2.31	3.32					
VMJH	19:59	0.70	2.22	118.85	14.55	2.13	3.32					
VMJH	20:29	1.67	2.35	120.94	14.65	2.11	3.21					
VMJH	20:59	0.30	2.40	119.57	14.43	2.24	3.28					
VMJH	21:29	1.33	2.36	117.91	14.78	2.14	3.27					
VMJH	21:59	0.80	2.36	122.54	13.97	2.16	3.14					
VMJH	22:29	1.67	2.30	118.46	14.33	2.11	3.21					
VMJH	22:42	0.00	2.44	118.70	15.21	2.21	3.10					
VMZ		1.22	2.31	119.46	14.63	2.17	3.23					



# Valori inregistrate MIR-IS HP-1500

Data:01/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.77		3.84		168.80		18.71		3.24		2.95	
VMJH	07:59	1.00		3.84		169.62		18.69		3.22		3.05	
VMJH	08:29	1.13		3.84		169.67		19.27		3.23		2.98	
VMJH	08:59	2.23		3.85		170.22		18.77		3.26		2.99	
VMJH	09:29	2.20		3.90		169.03		18.54		3.20		3.03	
VMJH	09:59	2.00		3.91		169.23		18.54		3.26		3.02	
VMJH	10:29	1.87		3.89		169.22		18.65		3.23		3.18	
VMJH	10:59	1.87		4.19		168.73		19.18		3.27		2.87	
VMJH	11:29	2.03		4.10		169.74		18.44		3.23		3.17	
VMJH	11:59	2.67		3.91		169.36		18.38		3.17		3.05	
VMJH	12:29	2.07		4.10		169.23		19.12		3.21		3.00	
VMJH	12:59	1.97		3.95		169.13		18.89		3.22		2.88	
VMJH	13:29	1.27		3.90		169.73		18.36		3.21		2.98	
VMJH	13:59	1.60		3.99		168.93		19.35		3.25		3.00	
VMJH	14:29	1.83		4.09		168.18		19.27		3.26		3.09	
VMJH	14:59	0.80		3.93		169.50		18.96		3.17		3.04	
VMJH	15:29	0.77		3.75		169.30		19.35		3.19		2.90	
VMJH	15:59	1.03		3.80		169.51		18.85		3.24		2.86	
VMJH	16:29	0.97		3.87		168.98		18.93		3.12		3.05	
VMJH	16:59	1.83		4.02		170.12		17.80		3.19		2.98	
VMJH	17:29	2.47		4.01		170.21		18.22		3.23		2.93	
VMJH	17:59	1.83		3.90		168.29		18.70		3.22		2.87	
VMJH	18:29	2.13		3.92		169.75		18.47		3.23		3.06	
VMJH	18:59	2.07		4.10		167.71		18.84		3.22		3.03	
VMJH	19:29	1.67		3.99		169.19		18.80		3.19		2.98	
VMJH	19:59	2.93		3.80		168.84		18.86		3.20		3.07	
VMJH	20:29	2.03		3.96		169.85		18.27		3.19		3.04	
VMJH	20:59	1.87		4.00		169.88		18.88		3.24		2.91	
VMJH	21:29	1.40		3.89		169.45		18.74		3.15		3.07	
VMJH	21:59	1.43		3.93		170.68		18.33		3.25		3.03	
VMJH	22:12	2.15		3.82		169.22		18.55		3.16		2.86	
VMZ		1.73		3.94		169.33		18.74		3.22		3.00	

# Valori inregistrate MIR-IS HP-1500

Data:02/03/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.33	3.80	168.53	19.09	3.24	3.02
VMJH	07:59	0.63	3.79	171.04	18.96	3.16	3.03
VMJH	08:29	1.60	4.07	170.41	18.67	3.22	2.99
VMJH	08:59	2.03	3.89	168.72	19.00	3.24	3.01
VMJH	09:29	1.37	4.01	169.60	18.97	3.16	3.03
VMJH	09:59	1.33	3.81	169.82	18.40	3.21	2.97
VMJH	10:29	3.43	3.97	168.10	18.87	3.19	2.95
VMJH	10:59	1.63	3.78	169.55	18.56	3.21	3.05
VMJH	11:29	3.20	3.88	170.05	18.28	3.16	3.12
VMJH	11:59	1.93	3.99	168.94	18.79	3.19	2.92
VMJH	12:29	0.77	4.12	168.66	18.68	3.17	3.12
VMJH	12:59	0.77	3.95	169.40	18.08	3.16	3.02
VMJH	13:29	1.93	4.06	168.88	18.62	3.27	2.94
VMJH	13:59	0.57	4.06	168.77	18.22	3.20	3.14
VMJH	14:29	1.00	3.95	170.27	18.82	3.23	2.94
VMJH	14:59	0.87	3.88	171.26	18.46	3.26	3.01
VMJH	15:29	0.83	4.05	168.16	18.69	3.16	2.97
VMJH	15:59	1.03	3.26	146.32	15.54	2.82	3.06
VMJH	16:29	0.73	2.46	113.95	12.77	2.10	2.95
VMJH	16:59	1.27	2.36	117.82	12.11	1.92	3.00
VMJH	17:29	1.80	2.44	113.66	12.84	2.07	3.03
VMJH	17:59	1.73	2.31	116.25	11.93	2.02	2.88
VMJH	18:29	1.40	2.34	114.77	12.32	2.13	2.79
VMJH	18:59	1.97	2.32	111.50	12.85	1.96	2.85
VMJH	19:29	0.67	2.19	117.73	12.34	1.85	2.98
VMJH	19:59	0.77	2.41	112.47	12.31	1.92	2.84
VMJH	20:29	0.77	2.38	114.91	12.18	2.06	2.87
VMJH	20:59	1.30	2.33	116.91	11.93	2.11	3.00
VMJH	21:29	3.13	2.43	117.23	12.70	2.08	2.80
VMJH	21:59	1.70	2.45	115.01	12.01	2.09	2.88
VMJH	22:24	2.24	2.40	114.94	12.67	1.99	2.79
VMZ		1.47	3.27	146.09	15.94	2.70	2.97



# Valori inregistrate MIR-IS HP-1500

Data:03/03/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.83	2.55	116.68	11.72	2.16	2.81
VMJH	07:59	0.60	2.34	115.06	12.44	2.10	2.90
VMJH	08:29	1.33	2.59	114.13	12.73	1.98	2.88
VMJH	08:59	1.43	2.44	115.00	12.47	2.16	2.94
VMJH	09:29	1.47	2.39	115.56	12.46	2.11	2.97
VMJH	09:59	0.43	2.39	113.33	11.93	2.03	2.97
VMJH	10:29	1.23	2.29	112.88	12.80	2.20	2.92
VMJH	10:59	0.97	2.36	114.95	12.41	2.17	2.82
VMJH	11:29	2.10	2.63	112.48	12.07	1.99	3.06
VMJH	11:59	0.47	2.34	114.77	12.66	2.28	2.79
VMJH	12:29	1.67	2.39	117.52	12.04	2.02	2.93
VMJH	12:59	1.30	2.35	115.74	12.45	2.04	3.00
VMJH	13:29	1.40	2.41	114.18	12.02	1.98	2.93
VMJH	13:59	0.50	2.45	115.09	12.30	2.20	2.87
VMJH	14:29	0.70	2.40	115.45	12.49	2.11	2.87
VMJH	14:59	0.67	2.62	115.59	12.54	2.05	2.92
VMJH	15:29	1.03	2.47	114.64	12.75	2.03	2.93
VMJH	15:59	0.83	2.42	117.07	12.14	2.05	2.93
VMJH	16:29	1.23	2.36	115.99	12.04	2.13	2.89
VMJH	16:59	0.77	2.41	115.59	12.23	1.96	2.90
VMJH	17:29	2.20	2.26	113.96	12.40	2.04	2.91
VMJH	17:59	1.43	2.39	112.97	12.16	2.04	2.98
VMJH	18:29	1.97	2.49	112.61	12.88	2.09	2.98
VMJH	18:59	1.40	2.41	116.12	12.70	2.05	2.79
VMJH	19:29	1.67	2.56	114.32	11.86	2.12	2.94
VMJH	19:59	2.10	2.44	115.92	12.18	2.16	2.90
VMJH	20:29	1.33	2.45	114.38	12.36	1.94	3.02
VMJH	20:59	0.87	2.43	116.06	12.50	2.09	2.88
VMJH	21:29	1.00	2.56	116.12	12.49	1.92	2.92
VMJH	22:00	1.23	2.44	112.24	12.78	1.99	2.81
VMZ		1.21	2.43	114.88	12.37	2.07	2.91



# Valori inregistrate MIR-IS HP-1500

Data:04/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.20	2.48	116.09	12.58	2.23	2.92
VMJH	07:59	0.63	2.33	115.63	12.46	2.01	2.98
VMJH	08:29	1.07	2.51	113.21	12.15	1.99	2.85
VMJH	08:59	1.13	2.54	115.22	12.23	2.06	2.94
VMJH	09:29	0.63	2.59	117.47	12.36	2.07	2.97
VMJH	09:59	0.70	2.94	119.74	15.01	2.22	2.87
VMJH	10:29	0.60	2.92	120.03	15.64	2.18	2.91
VMJH	10:59	0.57	3.00	119.61	14.74	2.32	2.93
VMJH	11:29	0.90	2.73	118.51	15.28	2.18	3.02
VMJH	11:59	1.37	2.95	118.01	16.07	2.32	2.86
VMJH	12:29	1.43	2.79	119.18	14.42	2.30	2.90
VMJH	12:59	1.90	2.90	118.85	13.89	2.10	2.80
VMJH	13:29	0.53	2.81	120.62	16.00	2.34	3.01
VMJH	13:59	1.03	2.86	117.99	14.92	2.29	2.97
VMJH	14:20	0.67	2.71	119.17	14.34	2.23	2.91
VMZ		0.96	2.74	117.93	14.14	2.19	2.92

# Valori inregistrate MIR-IS HP-1500

Data:06/03/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	08:59	1.37	2.76	120.72	15.17	2.08	2.78
VMJH	09:29	1.30	2.84	118.35	15.06	2.37	2.72
VMJH	09:59	1.07	2.86	120.76	14.75	2.24	2.84
VMJH	10:29	0.73	2.90	120.27	14.96	2.23	2.95
VMJH	10:59	0.80	2.68	121.04	15.57	2.31	2.94
VMJH	11:29	1.87	3.10	120.02	15.16	2.17	2.83
VMJH	11:59	1.03	2.74	120.94	16.01	2.24	2.83
VMJH	12:29	1.23	2.87	117.63	14.49	2.32	2.93
VMJH	12:59	0.70	2.84	121.27	14.20	2.33	2.80
VMJH	13:29	0.47	2.86	118.07	15.03	2.30	2.96
VMJH	13:59	0.93	2.87	118.95	14.91	2.26	2.95
VMJH	14:29	0.97	2.83	117.52	15.40	2.19	2.88
VMJH	14:59	1.03	2.99	120.26	15.27	2.34	3.04
VMJH	15:29	0.83	2.91	120.58	15.38	2.16	2.85
VMJH	15:59	1.03	2.65	118.63	15.86	2.22	2.84
VMJH	16:29	1.60	2.75	118.93	14.88	2.19	2.83
VMJH	16:59	1.30	2.85	120.69	15.12	2.19	2.97
VMJH	17:29	1.67	2.69	119.34	16.00	2.26	2.97
VMJH	17:59	1.53	2.68	117.79	15.93	2.40	2.89
VMJH	18:29	1.40	2.82	118.98	15.11	2.28	2.96
VMJH	18:59	2.27	2.62	120.71	15.03	2.13	2.93
VMJH	19:29	1.83	2.79	121.09	15.15	2.31	2.93
VMJH	19:59	0.47	2.76	118.93	14.20	2.12	2.97
VMJH	20:29	1.63	2.70	119.55	14.07	2.18	2.82
VMJH	20:59	0.20	2.87	119.77	15.15	2.18	3.02
VMJH	21:29	1.77	2.43	119.46	15.03	2.14	2.98
VMJH	21:59	0.87	2.78	120.64	13.99	2.21	2.89
VMJH	22:29	1.03	2.83	120.75	14.18	2.37	2.82
VMJH	22:43	0.79	2.59	121.23	14.56	2.15	2.82
VMZ		1.17	2.79	119.73	15.03	2.24	2.90

# Valori inregistrate MIR-IS HP-1500

Data:07/03/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.80	2.60	118.67	15.05	2.17	2.97
VMJH	07:59	0.80	2.80	118.88	14.71	2.14	2.82
VMJH	08:29	0.53	2.93	119.22	15.84	2.05	3.00
VMJH	08:59	0.53	2.85	119.79	15.30	2.18	2.80
VMJH	09:29	0.80	2.80	119.08	14.28	2.31	2.93
VMJH	09:59	0.63	2.97	118.63	15.11	2.34	2.97
VMJH	10:29	0.87	2.82	119.76	15.04	2.24	2.91
VMJH	10:59	1.73	2.82	120.53	14.55	2.26	2.90
VMJH	11:29	1.00	2.77	118.72	14.71	2.32	2.89
VMJH	11:59	0.83	3.80	144.41	17.96	3.30	3.17
VMJH	12:29	0.80	4.92	170.51	21.39	3.96	3.19
VMJH	12:59	0.83	4.83	172.25	19.96	4.03	3.25
VMJH	13:29	1.20	4.45	171.20	20.87	4.11	3.24
VMJH	13:59	1.30	4.34	171.02	20.63	4.11	3.15
VMJH	14:29	2.07	4.32	169.96	20.26	3.97	3.29
VMJH	14:59	1.57	4.70	173.37	21.32	3.97	3.21
VMJH	15:29	1.23	4.85	168.92	19.96	3.91	3.19
VMJH	15:59	1.50	4.69	171.77	21.16	3.98	3.10
VMJH	16:29	1.20	4.37	168.76	19.78	4.03	3.21
VMJH	16:59	0.53	4.57	170.58	20.94	3.86	3.30
VMJH	17:29	0.90	4.73	173.01	22.03	4.06	3.11
VMJH	17:59	0.90	4.24	170.73	20.65	3.87	3.21
VMJH	18:29	1.13	4.80	171.32	21.30	3.95	3.19
VMJH	18:59	1.13	4.16	172.11	20.38	3.77	3.20
VMJH	19:29	0.90	4.53	171.46	20.29	4.07	3.20
VMJH	19:59	1.10	4.61	171.74	20.50	3.86	3.12
VMJH	20:29	0.77	4.70	171.04	20.54	3.94	3.41
VMJH	20:59	1.03	4.56	170.46	19.61	3.88	3.15
VMJH	21:29	0.97	4.60	172.23	20.03	4.08	3.18
VMJH	21:59	1.00	4.76	171.32	20.55	4.12	3.41
VMJH	22:19	0.75	4.27	171.89	21.23	3.82	3.36
VMZ		1.01	4.03	155.09	18.88	3.44	3.13



# Valori inregistrate MIR-IS HP-1500

Data:08/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 07:29	1.00	4.50	170.53	20.35	3.92	3.19
VMJH 07:59	0.73	4.41	170.27	20.04	4.07	3.41
VMJH 08:29	0.80	4.48	171.01	20.81	4.15	3.37
VMJH 08:59	1.13	4.57	170.30	19.72	4.00	3.35
VMJH 09:29	0.83	4.46	170.64	21.13	3.99	3.14
VMJH 09:59	0.93	4.47	169.97	20.33	3.79	3.25
VMJH 10:29	1.10	4.22	170.83	19.99	3.68	3.32
VMJH 10:59	1.57	4.58	172.24	20.46	4.03	3.16
VMJH 11:29	1.17	4.17	170.22	21.31	3.95	3.22
VMJH 11:59	0.63	4.78	171.38	20.75	3.97	3.16
VMJH 12:29	0.80	4.34	169.60	20.69	3.96	3.19
VMJH 12:59	0.90	4.87	169.48	20.40	4.02	3.31
VMJH 13:29	0.67	4.64	171.15	20.83	4.00	3.20
VMJH 13:59	1.17	4.50	171.34	20.77	3.96	3.19
VMJH 14:29	1.50	4.36	169.87	21.44	4.04	3.28
VMJH 14:59	0.60	4.40	169.92	21.71	3.97	3.06
VMJH 15:29	0.93	4.71	172.16	20.00	3.80	3.39
VMJH 15:59	0.67	4.63	170.04	19.51	3.99	3.20
VMJH 16:29	0.87	4.44	172.11	20.35	4.05	3.29
VMJH 16:59	0.90	4.76	171.02	22.07	4.00	3.23
VMJH 17:29	0.50	4.78	172.03	21.65	4.03	3.15
VMJH 17:59	0.87	4.77	170.88	20.79	3.86	3.29
VMJH 18:29	0.70	4.85	169.09	19.91	4.12	3.26
VMJH 18:59	1.27	4.78	170.16	20.68	3.94	3.32
VMJH 19:29	1.47	4.58	173.03	21.22	3.86	3.43
VMJH 19:59	1.43	4.45	170.84	19.75	3.96	2.97
VMJH 20:29	0.23	4.55	166.89	20.56	3.54	3.22
VMJH 20:59	0.20	3.65	145.09	17.77	2.97	3.12
VMJH 21:29	0.17	3.80	144.74	17.56	2.99	3.13
VMJH 21:59	1.60	3.72	145.59	17.86	3.17	3.10
VMJH 22:29	0.30	3.80	145.35	17.60	3.25	3.15
VMJH 22:43	1.21	3.78	146.61	17.35	2.97	3.09
VMZ	0.90	4.44	167.03	20.21	3.83	3.23

# Valori inregistrate MIR-IS HP-1500

Data:09/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	2.30		3.72		145.03		18.21		3.14		3.07	
VMJH	07:59	0.23		3.81		144.02		18.03		2.98		3.09	
VMJH	08:29	1.30		3.51		144.86		18.06		3.11		3.11	
VMJH	08:59	1.03		3.49		145.91		18.33		3.03		3.07	
VMJH	09:29	1.23		3.78		144.87		16.81		3.12		2.99	
VMJH	09:59	1.03		3.60		144.04		17.37		3.05		3.06	
VMJH	10:29	1.27		3.80		145.15		17.39		3.11		3.02	
VMJH	10:59	1.17		3.54		146.96		17.89		3.23		3.05	
VMJH	11:29	0.97		3.56		145.10		18.10		3.27		3.02	
VMJH	11:59	1.13		3.69		144.33		17.53		3.00		3.18	
VMJH	12:29	1.20		3.66		145.06		17.39		3.09		3.04	
VMJH	12:59	1.27		3.70		144.15		17.96		3.13		3.08	
VMJH	13:29	1.23		3.88		146.09		17.21		3.23		3.06	
VMJH	13:59	0.90		3.76		145.25		18.33		3.04		3.13	
VMJH	14:29	0.80		3.65		143.09		18.47		3.12		3.04	
VMJH	14:59	0.73		3.66		145.41		18.06		3.12		3.12	
VMJH	15:29	0.97		3.61		146.30		17.25		3.12		3.12	
VMJH	15:59	1.40		3.56		146.04		17.56		3.14		3.10	
VMJH	16:29	0.30		3.40		144.96		17.77		3.22		3.12	
VMJH	16:59	0.47		3.61		145.97		17.51		3.07		3.01	
VMJH	17:29	0.80		3.55		145.08		19.11		3.14		3.02	
VMJH	17:59	1.37		3.79		145.75		18.02		3.22		3.16	
VMJH	18:29	1.43		3.71		146.20		17.93		3.09		3.11	
VMJH	18:59	1.00		3.88		146.08		17.88		3.17		3.18	
VMJH	19:29	1.10		3.76		145.81		17.35		3.16		3.05	
VMJH	19:59	0.27		3.65		145.04		17.91		3.11		3.06	
VMJH	20:29	0.43		3.94		145.82		17.16		3.06		3.11	
VMJH	20:59	1.27		3.86		144.65		18.68		3.17		3.08	
VMJH	21:29	0.67		3.68		144.41		17.44		3.12		3.11	
VMJH	21:59	0.87		3.74		145.52		18.19		3.14		3.05	
VMJH	22:29	1.33		3.45		144.56		18.25		2.98		3.05	
VMJH	22:40	0.91		3.69		146.15		17.40		3.01		3.21	
VMZ		1.01		3.68		145.22		17.84		3.12		3.08	



# Valori inregistrate MIR-IS HP-1500

Data:10/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.93		3.63		144.41		17.72		3.03		3.06	
VMJH	07:59	1.17		3.89		145.51		18.37		3.19		3.11	
VMJH	08:29	1.03		3.50		145.67		17.88		3.26		3.04	
VMJH	08:59	1.03		3.89		145.70		17.75		3.08		3.03	
VMJH	09:29	1.10		3.81		145.27		17.43		3.15		3.10	
VMJH	09:59	1.20		3.86		145.12		18.10		3.08		3.01	
VMJH	10:29	1.07		3.61		144.90		17.71		3.04		3.13	
VMJH	10:59	1.20		3.56		145.60		18.06		3.14		3.04	
VMJH	11:29	1.30		3.74		145.48		17.70		3.07		3.12	
VMJH	11:59	1.37		3.56		143.93		17.26		3.08		3.19	
VMJH	12:29	1.43		3.59		145.98		18.12		3.09		2.98	
VMJH	12:59	1.20		3.68		146.06		18.07		3.22		2.99	
VMJH	13:29	1.17		2.67		126.99		14.12		2.13		2.81	
VMJH	13:59	1.37		2.39		129.37		14.42		1.93		2.74	
VMJH	14:29	1.57		2.73		127.06		13.23		2.03		2.99	
VMJH	14:59	0.87		2.68		126.76		13.09		2.03		2.88	
VMJH	15:29	1.50		2.78		127.26		13.59		2.12		2.76	
VMJH	15:59	1.47		2.70		124.20		14.22		2.13		2.92	
VMJH	16:29	0.87		2.76		127.05		14.03		2.01		2.86	
VMJH	16:59	2.00		2.71		128.60		14.93		2.00		2.79	
VMJH	17:29	0.50		2.40		125.63		15.05		2.12		2.95	
VMJH	17:59	0.33		2.49		131.69		15.42		2.02		2.80	
VMJH	18:29	0.40		2.59		125.58		14.23		2.14		2.77	
VMJH	18:59	1.13		2.72		127.53		14.90		2.17		2.95	
VMJH	19:29	0.63		2.52		127.10		14.77		2.05		2.90	
VMJH	19:59	0.73		2.69		125.97		14.19		2.07		2.85	
VMJH	20:29	1.47		2.53		126.49		14.69		2.22		2.77	
VMJH	20:59	1.27		2.66		125.94		14.53		2.12		2.87	
VMJH	21:29	1.00		2.76		125.93		13.77		2.05		2.89	
VMJH	21:59	1.00		2.81		127.10		14.67		1.97		2.83	
VMJH	22:29	1.03		2.54		125.55		13.91		2.09		2.94	
VMJH	22:42	1.38		2.82		131.01		14.67		2.17		2.90	
VMZ		1.11		3.04		134.00		15.66		2.47		2.94	



# Valori inregistrate MIR-IS HP-1500

Data:13/03/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	10:49	1.03	2.59	129.73	14.03	1.98	2.88
VMJH	11:19	0.73	2.57	125.62	14.41	1.99	2.77
VMJH	11:49	1.00	2.53	129.27	14.00	2.17	2.83
VMJH	12:19	1.03	2.53	126.51	14.58	2.12	2.91
VMJH	12:49	0.73	2.40	124.62	14.18	2.13	2.91
VMJH	13:19	0.90	2.48	127.92	13.70	2.07	2.73
VMJH	13:49	0.67	2.53	124.86	13.71	2.09	2.89
VMJH	14:19	1.23	2.55	123.42	14.42	2.20	2.78
VMJH	14:49	0.77	2.53	123.33	15.24	2.13	2.86
VMJH	15:19	1.07	2.45	127.70	13.85	2.08	2.87
VMJH	15:49	1.97	2.67	127.44	14.05	2.21	2.86
VMJH	16:19	0.50	2.51	127.01	13.97	2.15	2.90
VMJH	16:49	1.93	2.77	127.21	14.02	2.00	2.86
VMJH	17:19	0.70	2.59	125.20	14.79	2.15	2.93
VMJH	17:49	1.43	2.44	126.00	13.29	1.99	2.88
VMJH	18:19	1.00	2.58	132.56	13.94	2.09	2.86
VMJH	18:49	1.53	2.64	127.68	13.50	2.00	2.82
VMJH	19:19	1.07	2.88	128.65	14.28	1.95	2.89
VMJH	19:49	1.13	2.62	128.10	14.26	2.27	2.86
VMJH	20:19	1.47	2.69	128.10	13.79	1.99	2.74
VMJH	20:49	0.70	2.74	127.02	14.10	2.14	2.94
VMJH	21:19	0.90	2.65	128.75	13.88	1.82	2.91
VMJH	21:49	1.23	2.48	126.86	14.61	1.91	3.01
VMJH	22:19	1.03	2.70	126.98	14.25	2.14	2.96
VMJH	22:36	0.47	2.45	125.42	13.22	2.02	2.84
VMZ		1.06	2.58	127.07	14.10	2.07	2.87

# Valori inregistrate MIR-IS HP-1500

Data:14/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.20		2.62		128.11		14.79		2.01		2.98	
VMJH	07:59	0.83		2.46		126.98		13.94		2.02		2.91	
VMJH	08:29	0.97		2.53		126.39		13.88		2.25		2.92	
VMJH	08:59	0.77		2.44		122.46		14.12		2.02		2.85	
VMJH	09:29	0.77		4.27		170.36		20.97		3.78		3.04	
VMJH	09:59	0.93		4.49		171.47		20.31		3.60		3.17	
VMJH	10:29	0.73		4.37		170.34		21.66		3.92		3.25	
VMJH	10:59	0.97		4.29		170.62		20.26		3.88		3.22	
VMJH	11:29	1.17		4.34		171.37		20.02		4.00		3.27	
VMJH	11:59	1.40		4.26		172.63		20.12		3.73		3.26	
VMJH	12:29	1.10		4.46		169.22		21.78		3.91		3.42	
VMJH	12:59	0.50		4.25		170.36		20.98		3.94		3.17	
VMJH	13:29	0.80		4.61		170.06		19.68		3.81		3.12	
VMJH	13:59	1.23		4.36		170.94		20.36		3.85		3.10	
VMJH	14:29	1.07		4.52		171.08		21.59		3.88		3.19	
VMJH	14:59	1.10		4.48		172.92		20.21		3.87		3.16	
VMJH	15:29	1.77		4.18		171.98		20.60		3.77		3.35	
VMJH	15:40	0.45		4.22		171.66		21.03		3.83		3.35	
VMZ		1.01		3.94		160.68		19.17		3.44		3.14	

# Valori inregistrate MIR-IS HP-1500

Data:15/03/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:49	2.27	4.37	169.92	20.24	3.90	3.25
VMJH	08:19	0.27	4.38	171.15	19.79	3.74	3.30
VMJH	08:49	1.17	4.30	171.30	20.22	3.63	3.27
VMJH	09:19	0.90	4.56	170.34	21.01	3.77	3.07
VMJH	09:49	1.40	4.32	170.62	20.67	3.79	3.16
VMJH	10:19	1.40	4.78	171.76	21.06	3.75	3.17
VMJH	10:49	0.70	4.18	171.14	20.87	3.80	3.25
VMJH	11:19	0.43	4.53	170.89	19.58	3.84	3.19
VMJH	11:49	0.87	4.65	169.89	20.97	3.65	3.25
VMJH	12:19	0.57	4.28	172.71	21.35	3.92	3.27
VMJH	12:49	0.27	4.38	170.63	19.86	3.86	3.15
VMJH	13:19	1.20	4.58	171.05	20.21	3.80	3.35
VMJH	13:49	0.60	4.06	170.60	19.66	4.02	3.15
VMJH	14:19	1.23	4.39	170.46	20.33	3.85	3.21
VMJH	14:49	0.67	4.37	170.16	20.91	3.83	3.23
VMJH	15:19	0.93	4.30	168.54	20.79	3.74	3.12
VMJH	15:49	1.17	4.52	170.87	21.57	3.70	3.22
VMJH	16:19	0.30	4.41	169.52	20.27	3.76	3.14
VMJH	16:49	1.17	4.25	172.50	20.55	3.76	3.35
VMJH	17:19	1.10	4.36	172.70	20.37	3.96	3.20
VMJH	17:49	1.33	4.33	171.59	20.41	3.66	3.30
VMJH	18:19	0.50	4.35	169.99	20.56	3.85	3.25
VMJH	18:49	0.87	4.18	170.97	20.14	3.90	3.22
VMJH	19:19	1.30	4.20	169.43	20.65	4.01	3.32
VMJH	19:49	2.03	4.56	170.99	20.93	3.91	3.37
VMJH	20:19	1.27	4.13	170.26	22.08	3.80	3.09
VMJH	20:49	0.87	4.22	171.51	20.57	3.77	3.09
VMJH	21:19	0.63	4.47	169.23	20.22	3.71	3.10
VMJH	21:49	1.17	4.25	171.55	20.66	3.73	3.26
VMJH	22:19	0.63	4.31	172.17	20.69	3.70	3.21
VMJH	22:45	0.73	4.38	169.93	20.62	3.82	3.17
VMZ		0.97	4.37	170.79	20.57	3.80	3.22



# Valori inregistrate MIR-IS HP-1500

Data:16/03/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:31	0.20	4.36	169.04	20.93	3.83	3.26
VMJH	16:01	0.43	4.55	172.07	20.79	3.70	3.14
VMJH	16:31	0.73	4.25	171.38	20.36	3.68	3.24
VMJH	17:01	0.37	4.15	165.31	20.05	3.83	3.11
VMJH	17:31	1.10	3.46	149.19	17.33	3.04	3.20
VMJH	18:01	0.60	3.53	150.42	17.98	2.86	2.92
VMJH	18:31	0.80	3.48	148.43	17.95	2.90	3.06
VMJH	19:01	0.67	3.47	149.01	17.41	3.05	3.13
VMJH	19:31	0.77	3.53	147.56	17.62	2.94	3.11
VMJH	20:01	0.97	3.43	148.36	17.75	3.01	3.02
VMJH	20:31	0.33	3.27	148.80	17.07	2.81	3.07
VMJH	21:01	0.73	3.50	150.27	17.78	2.94	3.06
VMJH	21:31	0.77	3.30	149.47	18.00	2.97	2.95
VMJH	22:01	1.57	3.41	145.97	17.79	2.97	3.09
VMJH	22:31	1.07	3.38	149.98	17.35	2.86	2.99
VMJH	22:50	0.74	3.53	148.32	17.69	3.07	3.20
VMZ		0.74	3.66	154.10	18.38	3.15	3.09

# Valori inregistrate MIR-IS HP-1500

Data:17/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 07:29	0.13	3.47	148.06	17.51	2.84	3.05
VMJH 07:59	1.10	3.49	148.57	16.82	2.99	3.03
VMJH 08:29	0.50	3.68	148.20	17.72	2.93	2.98
VMJH 08:59	0.77	3.63	147.64	17.47	2.89	3.03
VMJH 09:29	1.07	3.38	148.43	17.49	2.85	3.03
VMJH 09:59	0.70	3.62	147.76	17.28	2.91	3.12
VMJH 10:29	1.47	3.60	150.86	17.35	2.91	3.06
VMJH 10:59	0.70	3.54	147.95	17.54	2.91	3.02
VMJH 11:29	0.47	3.58	150.36	16.88	2.96	3.03
VMJH 11:59	0.20	3.70	150.11	18.16	2.96	3.06
VMJH 12:29	1.20	3.60	150.24	17.01	2.93	2.94
VMJH 12:59	0.50	3.52	147.71	18.15	2.97	3.12
VMJH 13:29	1.27	3.26	149.34	17.61	2.83	3.04
VMJH 13:59	0.90	3.53	148.84	18.05	2.94	3.00
VMJH 14:29	0.83	3.55	147.67	17.18	2.91	3.06
VMJH 14:59	1.13	3.47	149.09	18.03	2.97	3.05
VMJH 15:29	0.50	3.39	148.15	17.32	2.96	3.03
VMJH 15:59	0.70	3.57	148.83	16.98	3.03	3.01
VMJH 16:29	1.07	3.45	147.50	17.06	2.96	3.01
VMJH 16:59	0.97	3.67	149.65	17.81	3.02	3.09
VMJH 17:29	0.67	3.55	147.47	17.38	2.98	3.05
VMJH 17:59	1.47	3.44	147.47	17.79	2.92	3.05
VMJH 18:29	0.63	3.66	150.07	17.19	2.94	3.13
VMJH 18:59	0.40	3.44	149.65	17.10	2.94	3.06
VMJH 19:29	0.73	3.47	149.24	17.61	2.99	3.02
VMJH 19:59	0.67	3.47	148.67	17.47	2.87	3.10
VMJH 20:29	0.80	3.50	149.10	17.98	2.87	3.02
VMJH 20:59	0.50	3.38	148.89	18.26	2.89	3.00
VMJH 21:29	0.33	3.44	149.40	16.72	2.91	3.07
VMJH 21:59	0.17	3.40	147.85	17.19	2.94	3.04
VMJH 22:26	1.00	3.46	150.38	17.44	3.00	2.99
VMZ	0.76	3.51	148.81	17.47	2.93	3.04

# Valori inregistrate MIR-IS HP-1500

Data:18/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.13	3.37	149.34	17.55	3.00	2.97
VMJH	07:59	1.50	3.52	148.39	17.26	2.90	3.03
VMJH	08:29	1.57	3.58	147.50	17.22	2.93	3.05
VMJH	08:59	2.13	3.40	149.72	17.81	2.99	3.08
VMJH	09:29	1.70	3.58	146.98	17.89	2.92	2.96
VMJH	09:59	1.33	4.06	164.79	21.16	3.77	3.29
VMJH	10:29	1.87	4.29	170.91	20.71	3.79	3.14
VMJH	10:59	0.80	4.23	169.59	19.76	3.80	3.16
VMJH	11:29	1.47	4.56	170.42	20.10	3.74	3.28
VMJH	11:59	1.67	4.37	169.76	21.13	3.89	3.07
VMJH	12:29	1.33	4.61	170.30	21.35	3.64	3.11
VMJH	12:59	1.23	4.61	170.91	19.31	3.92	3.18
VMJH	13:29	0.90	4.11	170.21	20.90	3.87	3.13
VMJH	13:59	0.53	4.53	171.59	20.85	3.84	3.29
VMJH	14:12	2.62	4.59	169.97	20.19	3.60	3.16
VMZ		1.41	4.08	162.42	19.52	3.50	3.13



# Valori inregistrate MIR-IS HP-1500

Data:20/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 100 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 11:59	1.30	4.52	168.96	20.14	3.76	3.28
VMJH 12:29	1.40	4.09	170.58	20.42	3.75	3.19
VMJH 12:59	0.27	4.40	170.94	19.99	3.80	3.18
VMJH 13:29	0.67	4.20	170.89	20.01	3.83	3.21
VMJH 13:59	0.73	4.38	170.87	21.17	3.77	3.22
VMJH 14:29	0.67	4.21	169.64	22.12	3.84	3.26
VMJH 14:59	0.87	4.22	171.47	20.71	3.81	3.16
VMJH 15:29	0.67	4.26	170.94	20.25	3.97	3.26
VMJH 15:59	1.17	4.50	171.21	20.78	3.71	3.22
VMJH 16:29	0.73	4.26	170.37	21.35	3.74	3.15
VMJH 16:59	0.83	4.10	170.62	18.94	3.81	3.10
VMJH 17:29	1.53	4.43	170.85	20.95	3.78	3.38
VMJH 17:59	1.13	4.24	170.10	20.85	3.87	3.17
VMJH 18:29	2.03	4.38	169.55	21.48	3.74	3.10
VMJH 18:59	1.53	3.95	171.34	21.90	3.84	3.10
VMJH 19:29	0.90	4.16	171.41	20.12	3.96	3.21
VMJH 19:59	0.70	4.29	170.65	21.02	3.82	3.18
VMJH 20:29	1.63	4.17	169.28	20.32	3.85	3.21
VMJH 20:59	2.27	4.35	171.59	19.87	3.85	3.10
VMJH 21:29	2.33	4.79	170.45	20.41	3.80	3.23
VMJH 21:59	1.30	4.31	170.83	19.91	3.77	3.24
VMJH 22:29	1.23	4.54	171.65	20.45	4.03	3.00
VMJH 22:59	1.07	4.23	170.83	20.01	3.87	3.28
VMJH 23:29	1.13	4.41	170.47	20.93	4.05	3.19
VMJH 23:59	1.33	4.32	169.99	20.93	3.70	3.27
VMZ	1.18	4.31	170.62	20.60	3.83	3.19

# Valori inregistrate MIR-IS HP-1500

Data:21/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	00:29	0.77	4.32	170.54	21.09	3.76	3.10
VMJH	00:59	0.97	4.55	172.67	21.23	3.78	3.24
VMJH	01:29	1.10	3.98	170.40	20.15	3.80	3.09
VMJH	01:59	0.67	4.36	170.38	19.63	3.84	3.18
VMJH	02:29	0.83	4.69	171.28	21.28	3.88	3.30
VMJH	02:59	1.17	4.44	169.51	20.62	3.80	3.33
VMJH	03:29	1.07	4.51	173.08	21.01	3.71	3.22
VMJH	03:59	0.33	4.17	171.81	21.52	3.76	3.09
VMJH	04:29	0.73	4.54	171.80	20.88	3.81	3.34
VMJH	04:59	0.77	4.54	170.07	21.58	3.68	3.29
VMJH	05:29	0.47	4.03	170.79	19.48	3.80	3.10
VMJH	05:59	0.80	4.37	171.74	20.96	3.86	3.18
VMJH	06:29	1.97	4.34	172.83	20.44	3.81	3.34
VMJH	06:36	1.71	4.26	171.51	22.20	3.77	3.51
VMZ		0.91	4.37	171.31	20.79	3.79	3.22

# Valori inregistrate MIR-IS HP-1500

Data:21/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	100	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.50		3.48		153.09		18.56		3.26		3.05	
VMJH	07:59	0.47		2.52		126.73		14.77		2.07		2.88	
VMJH	08:29	0.33		2.64		125.07		14.40		2.04		2.95	
VMJH	08:59	0.57		2.48		124.16		15.20		1.98		2.83	
VMJH	09:29	0.37		2.68		126.99		15.02		2.20		2.92	
VMJH	09:59	0.70		2.57		128.99		14.35		1.96		2.98	
VMJH	10:29	0.27		2.58		128.79		14.13		2.10		2.78	
VMJH	10:59	0.87		2.50		124.18		14.69		2.27		2.85	
VMJH	11:29	0.70		2.60		126.94		15.37		2.04		2.90	
VMJH	11:59	0.57		2.41		126.82		14.11		2.06		2.81	
VMJH	12:29	1.03		2.80		127.70		13.70		2.12		2.95	
VMJH	12:59	0.77		2.46		124.40		14.14		2.13		2.94	
VMJH	13:29	0.63		2.28		129.93		14.47		2.15		2.87	
VMJH	13:59	0.90		2.49		125.63		14.06		2.13		2.88	
VMJH	14:29	0.90		2.61		127.14		14.03		2.06		2.84	
VMJH	14:59	0.80		2.75		126.50		15.32		2.15		2.80	
VMJH	15:29	0.47		2.49		126.92		14.47		2.03		2.90	
VMJH	15:59	1.27		2.48		126.14		14.22		2.03		2.80	
VMJH	16:29	0.43		2.53		127.52		15.17		2.21		2.88	
VMJH	16:59	1.00		2.36		125.41		14.79		1.92		2.88	
VMJH	17:29	1.00		2.56		123.72		14.27		2.07		2.80	
VMJH	17:59	0.80		2.65		127.60		14.23		2.23		2.86	
VMJH	18:29	0.70		2.60		126.22		13.93		1.94		2.94	
VMJH	18:59	0.73		2.40		124.46		14.64		2.08		2.93	
VMJH	19:29	0.97		2.56		124.53		13.60		2.00		2.73	
VMJH	19:59	1.17		2.70		122.47		14.38		2.03		2.89	
VMJH	20:29	1.40		2.54		125.24		13.94		2.03		2.88	
VMJH	20:59	1.13		2.71		129.37		14.50		1.98		2.86	
VMJH	21:29	1.30		2.60		130.98		13.71		1.91		2.92	
VMJH	21:59	1.60		2.38		128.24		13.85		2.10		2.75	
VMJH	22:29	1.80		2.66		124.13		13.67		2.11		2.86	
VMJH	22:36	1.86		2.25		125.67		15.13		2.04		2.93	
VMZ		0.88		2.58		127.28		14.51		2.11		2.88	



# Valori inregistrate MIR-IS HP-1500

Data:22/03/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.37	2.44	126.59	13.83	2.13	2.77
VMJH	07:59	1.30	2.38	124.32	14.05	2.01	2.82
VMJH	08:29	1.37	2.63	125.00	13.86	2.11	2.84
VMJH	08:59	0.83	2.73	127.52	14.87	2.01	2.85
VMJH	09:29	1.67	2.51	127.69	14.10	2.14	2.83
VMJH	09:59	1.63	2.51	124.12	13.43	2.00	2.90
VMJH	10:29	1.60	2.64	125.34	13.86	2.05	2.80
VMJH	10:59	0.87	2.58	124.34	14.17	2.11	2.68
VMJH	11:29	0.30	2.79	128.03	14.21	2.07	2.90
VMJH	11:59	0.27	2.64	126.82	14.34	2.11	2.94
VMJH	12:29	0.47	2.47	126.67	15.05	2.13	2.91
VMJH	12:59	0.63	2.71	126.18	14.57	2.07	2.80
VMJH	13:29	0.80	2.94	126.68	12.96	1.90	2.88
VMJH	13:59	0.30	2.59	130.56	14.30	2.10	2.78
VMJH	14:29	0.57	2.65	124.77	13.90	2.17	2.90
VMJH	14:59	0.30	2.54	128.05	13.82	2.01	2.90
VMJH	15:29	0.20	2.69	129.56	13.84	2.09	2.85
VMJH	15:59	0.30	2.38	125.45	15.17	2.12	2.85
VMJH	16:29	0.43	2.19	119.83	15.87	2.23	2.90
VMJH	16:59	0.33	2.15	123.16	15.30	2.23	2.89
VMJH	17:29	0.33	2.15	123.59	15.36	2.21	2.92
VMJH	17:59	0.40	2.01	122.10	16.17	2.14	2.86
VMJH	18:29	1.90	2.15	123.07	15.54	2.04	2.95
VMJH	18:59	0.77	2.30	123.03	15.74	2.15	2.94
VMJH	19:29	0.47	2.16	123.99	16.36	2.10	2.92
VMJH	19:59	0.20	2.11	125.39	15.55	2.20	2.78
VMJH	20:29	0.27	2.20	122.19	15.53	2.28	2.76
VMJH	20:59	0.57	2.08	121.99	15.55	2.33	2.88
VMJH	21:29	0.87	2.16	125.46	15.57	2.21	2.78
VMJH	21:59	0.97	2.17	122.69	15.00	2.07	2.87
VMJH	22:29	0.63	2.21	125.09	15.86	2.28	2.91
VMJH	22:48	0.68	2.20	122.20	16.21	2.33	2.90
VMZ		0.74	2.41	125.08	14.80	2.13	2.86

# Valori inregistrate MIR-IS HP-1500

Data:23/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:41	0.40		2.07		122.48		15.48		2.27		2.83	
VMJH	08:11	0.20		2.10		126.19		14.77		2.25		2.90	
VMJH	08:41	0.30		2.11		124.57		15.61		2.37		2.76	
VMJH	09:11	0.33		2.29		120.11		14.89		2.41		2.92	
VMJH	09:41	1.40		2.20		123.51		15.11		2.25		2.87	
VMJH	10:11	1.30		2.30		123.35		15.58		2.17		2.77	
VMJH	10:41	1.40		2.08		123.14		15.75		2.28		2.96	
VMJH	11:11	1.07		2.17		120.89		14.39		2.34		2.95	
VMJH	11:41	0.67		2.23		123.77		14.22		2.29		2.87	
VMJH	12:11	1.03		2.14		123.67		14.30		2.32		2.90	
VMJH	12:41	1.63		2.22		124.41		15.60		2.24		2.91	
VMJH	13:11	0.67		2.23		123.10		16.29		2.16		2.97	
VMJH	13:41	0.87		2.18		120.43		15.27		2.11		2.73	
VMJH	14:11	1.03		2.08		121.14		15.90		2.25		2.89	
VMJH	14:41	1.03		2.11		124.24		14.83		2.23		3.05	
VMJH	15:11	0.50		2.07		121.30		14.90		2.28		2.90	
VMJH	15:41	0.73		2.10		122.77		16.63		2.27		2.88	
VMJH	16:11	1.20		2.03		120.08		14.26		2.27		2.89	
VMJH	16:41	0.93		2.13		123.07		14.94		2.23		2.87	
VMJH	17:11	0.27		2.22		123.01		14.95		2.17		2.92	
VMJH	17:41	0.57		2.16		122.13		14.28		2.21		2.96	
VMJH	18:11	1.07		2.15		120.03		15.81		2.21		3.01	
VMJH	18:41	0.50		2.05		123.09		15.81		2.11		2.98	
VMJH	19:11	0.40		2.11		125.87		15.17		2.35		2.85	
VMJH	19:41	1.03		2.17		125.31		14.43		2.30		2.84	
VMJH	20:11	1.50		2.13		122.46		15.97		2.22		2.91	
VMJH	20:41	0.93		2.16		125.10		14.93		2.22		2.92	
VMJH	21:11	1.40		2.11		122.60		15.77		2.26		2.89	
VMJH	21:41	0.77		2.17		120.85		16.42		2.15		2.72	
VMJH	22:11	0.77		2.19		126.03		15.74		2.30		2.82	
VMJH	22:24	1.00		2.20		124.82		15.51		2.30		3.06	
VMZ		0.87		2.15		122.98		15.27		2.25		2.89	



# Valori inregistrate MIR-IS HP-1500

Data:24/03/2023

	Ora	Pulberi mg/Nm <sup>2</sup>		SO <sub>2</sub> L1 mg/Nm <sup>3</sup>		NO <sub>x</sub> L1 mg/Nm <sup>3</sup>		CO L1 mg/Nm <sup>3</sup>		COT L1 mg/Nm <sup>3</sup>		HCL L1 mg/Nm <sup>3</sup>	
		VMA VMJH		VMA VMJH		VMA VMJH		VMA		VMA VMJH		VMA VMJH	
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.93		2.32		125.23		15.51		2.31		2.91	
VMJH	07:59	1.00		2.16		119.38		15.56		2.26		2.89	
VMJH	08:29	0.80		2.13		123.23		14.52		2.12		2.90	
VMJH	08:59	0.53		3.17		154.81		19.51		3.55		3.09	
VMJH	09:29	0.40		3.62		171.13		19.54		3.95		3.34	
VMJH	09:59	0.83		3.55		171.26		20.72		4.12		3.10	
VMJH	10:29	0.67		3.51		169.32		20.90		4.01		3.26	
VMJH	10:59	1.70		3.47		172.64		20.44		3.73		3.17	
VMJH	11:29	0.83		3.46		169.60		19.57		4.04		3.25	
VMJH	11:59	0.47		3.60		172.77		20.27		3.90		3.42	
VMJH	12:29	0.83		3.52		170.73		20.37		3.93		3.43	
VMJH	12:59	0.80		3.47		171.84		21.23		4.02		3.30	
VMJH	13:29	1.00		3.50		171.15		20.16		4.14		3.22	
VMJH	13:59	0.73		3.60		171.17		20.62		3.93		3.20	
VMJH	14:29	1.00		3.53		171.89		21.05		3.91		3.37	
VMJH	14:59	1.63		3.60		171.33		19.93		3.92		3.12	
VMJH	15:29	0.47		3.48		169.84		20.42		3.87		3.19	
VMJH	15:59	1.57		3.58		171.56		21.52		4.06		3.28	
VMJH	16:29	1.50		3.62		170.90		20.71		3.94		3.06	
VMJH	16:59	1.17		3.58		172.61		20.92		3.89		3.36	
VMJH	17:29	1.40		3.66		170.42		20.23		3.81		3.21	
VMJH	17:59	0.70		3.55		171.20		20.77		3.90		3.24	
VMJH	18:29	1.27		3.66		170.21		21.64		3.79		3.33	
VMJH	18:59	1.13		3.67		171.31		21.17		4.11		3.02	
VMJH	19:29	0.70		3.48		171.32		19.69		3.75		3.22	
VMJH	19:59	1.23		3.47		171.76		20.95		3.93		3.37	
VMJH	20:29	0.63		3.65		173.09		20.50		4.02		3.28	
VMJH	20:59	1.00		3.52		170.61		20.71		3.91		3.17	
VMJH	21:29	0.87		3.45		170.39		21.22		4.00		3.24	
VMJH	21:59	1.30		3.52		169.64		20.10		4.08		3.34	
VMJH	22:29	0.90		3.54		170.87		20.35		3.94		3.15	
VMJH	22:48	1.05		3.50		173.90		21.20		3.97		3.04	
VMZ		0.97		3.41		166.07		20.05		3.77		3.20	



# Valori inregistrate MIR-IS HP-1500

Data:27/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	11:29	1.17	3.56	172.17	21.50	3.89	3.22
VMJH	11:59	1.47	3.56	171.05	21.33	3.88	3.23
VMJH	12:29	1.13	3.57	171.69	20.83	3.72	3.20
VMJH	12:59	0.83	3.58	170.22	21.38	4.01	3.27
VMJH	13:29	2.07	3.59	172.45	19.77	3.99	3.40
VMJH	13:59	0.93	3.59	169.20	20.02	4.04	3.35
VMJH	14:29	1.40	3.48	170.36	20.10	3.95	3.28
VMJH	14:59	0.33	3.60	170.71	21.14	3.96	3.22
VMJH	15:29	0.20	3.48	170.91	20.24	3.99	3.29
VMJH	15:59	0.97	3.45	171.42	20.48	3.62	3.34
VMJH	16:29	0.97	3.70	171.27	20.89	4.11	3.42
VMJH	16:59	0.77	3.47	171.89	20.85	3.88	3.31
VMJH	17:29	0.73	3.59	170.58	20.34	4.08	3.32
VMJH	17:59	1.50	3.56	169.51	20.77	3.80	3.18
VMJH	18:29	0.70	3.60	170.54	21.29	3.82	3.24
VMJH	18:59	1.07	3.59	171.89	20.34	4.08	3.34
VMJH	19:29	1.07	3.45	172.30	21.36	3.94	3.10
VMJH	19:59	1.13	3.68	170.73	22.45	3.93	3.26
VMJH	20:29	0.77	3.53	170.00	19.91	3.92	3.20
VMJH	20:59	1.03	3.35	162.30	19.93	3.65	3.27
VMJH	21:29	1.57	2.88	147.30	17.52	3.02	2.98
VMJH	21:59	0.63	2.91	147.90	18.53	2.96	2.99
VMJH	22:29	0.93	2.83	148.28	17.76	3.07	3.11
VMJH	22:44	0.53	2.99	147.11	18.38	3.14	3.15
VMZ		1.01	3.45	167.15	20.34	3.78	3.24

# Valori inregistrate MIR-IS HP-1500

Data:28/03/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 15:11	0.70	2.91	146.13	18.09	3.14	3.01
VMJH 15:41	1.10	2.88	145.89	17.77	3.02	3.17
VMJH 16:11	0.57	2.94	148.37	17.43	3.14	2.99
VMJH 16:41	0.83	2.93	148.01	18.08	3.12	3.12
VMJH 17:11	0.90	2.91	147.44	17.94	3.09	3.02
VMJH 17:41	1.57	2.79	146.82	17.41	3.15	3.06
VMJH 18:11	0.93	2.82	146.88	17.93	2.93	3.08
VMJH 18:41	0.97	2.79	144.72	17.24	3.22	3.13
VMJH 19:11	0.80	2.86	147.36	17.89	3.11	3.06
VMJH 19:41	0.80	2.84	146.59	18.19	3.18	3.10
VMJH 20:11	1.00	2.81	147.96	17.73	3.04	3.15
VMJH 20:41	1.10	2.90	146.36	18.47	3.00	3.08
VMJH 21:11	1.47	2.87	146.96	17.67	3.04	3.10
VMJH 21:41	0.90	2.83	146.92	18.70	3.13	3.03
VMJH 22:11	1.10	2.76	145.25	17.71	3.04	3.13
VMJH 22:41	0.77	2.87	147.57	17.98	3.08	3.11
VMJH 22:45	2.75	2.89	150.87	18.56	2.86	2.93
VMZ	0.99	2.86	146.87	17.89	3.09	3.08

# Valori inregistrate MIR-IS HP-1500

Data:29/03/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.67	2.84	148.00	18.23	2.91	3.00
VMJH	07:59	0.40	2.83	148.55	17.83	3.13	2.85
VMJH	08:29	0.67	2.86	145.86	18.21	3.17	3.01
VMJH	08:59	0.53	2.86	146.22	17.39	3.03	3.12
VMJH	09:29	0.63	2.92	146.58	18.19	3.06	3.05
VMJH	09:59	0.77	2.86	145.64	18.91	3.15	3.15
VMJH	10:29	0.40	2.89	148.02	18.08	2.94	2.99
VMJH	10:59	0.40	2.92	148.60	17.93	3.24	3.11
VMJH	11:29	0.40	2.82	146.09	18.16	3.31	3.08
VMJH	11:59	0.40	2.87	146.36	18.10	3.05	3.15
VMJH	12:29	0.23	2.91	146.80	17.45	3.19	3.09
VMJH	12:59	0.37	2.92	145.26	17.88	3.08	3.17
VMJH	13:29	0.60	2.78	144.91	18.00	3.01	3.15
VMJH	13:59	0.43	2.88	147.52	17.96	3.16	3.12
VMJH	14:29	0.40	2.86	147.77	18.08	3.19	3.09
VMJH	14:59	0.53	2.88	147.28	17.38	3.10	3.01
VMJH	15:29	1.17	2.94	146.59	18.44	3.10	3.05
VMJH	15:59	0.87	2.84	146.92	18.04	3.10	2.92
VMJH	16:29	0.60	2.89	148.29	18.21	3.02	3.05
VMJH	16:59	0.77	2.86	146.56	17.87	2.98	3.19
VMJH	17:29	0.37	2.88	150.49	17.97	3.06	3.03
VMJH	17:59	0.80	2.84	147.20	17.89	3.06	3.01
VMJH	18:29	0.60	2.86	146.71	18.54	3.13	3.06
VMJH	18:59	0.90	2.86	146.43	18.00	3.06	3.16
VMJH	19:29	1.07	2.92	146.12	17.28	3.05	3.11
VMJH	19:59	0.63	2.79	148.61	18.03	2.92	3.15
VMJH	20:29	0.80	2.89	146.13	17.76	3.13	2.98
VMJH	20:59	0.40	2.86	148.76	18.02	3.07	3.14
VMJH	21:29	0.43	3.11	120.94	13.28	2.14	3.02
VMJH	21:59	0.73	3.20	123.06	13.00	2.02	2.98
VMJH	22:29	0.73	3.09	121.37	13.74	2.38	3.04
VMJH	22:45	0.31	3.10	120.50	12.83	2.16	2.85
VMZ		0.60	2.90	144.21	17.46	2.98	3.06



# Valori inregistrate MIR-IS HP-1500

Data:30/03/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	100	400/200	50		10	20/10	10	60/10
VMJH	07:29	0.83		3.05		124.06		12.90		2.01		2.97	
VMJH	07:59	0.00		3.08		121.11		12.42		2.24		2.93	
VMJH	08:29	0.83		3.14		122.20		13.49		2.23		2.95	
VMJH	08:59	1.13		2.94		123.05		13.29		2.17		2.94	
VMJH	09:29	0.40		3.14		121.43		12.98		2.03		3.04	
VMJH	09:59	0.40		3.07		121.86		13.08		2.00		2.87	
VMJH	10:29	1.03		3.18		120.43		12.32		2.31		2.99	
VMJH	10:59	0.37		3.08		120.20		12.66		2.18		3.02	
VMJH	11:29	0.60		2.99		120.50		13.10		2.20		2.96	
VMJH	11:59	0.77		3.20		123.57		12.92		2.04		2.93	
VMJH	12:29	0.63		3.17		119.74		12.72		2.23		2.86	
VMJH	12:59	1.77		2.92		122.43		13.23		2.02		2.91	
VMJH	13:29	0.73		3.03		121.59		13.29		2.19		2.92	
VMJH	13:59	0.33		3.08		121.88		12.92		1.96		3.01	
VMJH	14:29	0.70		3.15		119.56		13.42		2.00		2.96	
VMJH	14:59	1.10		3.31		121.75		12.71		2.03		2.90	
VMJH	15:29	0.97		3.14		124.64		13.72		2.11		2.92	
VMJH	15:59	0.70		3.11		120.57		13.08		2.24		2.93	
VMJH	16:29	0.53		3.11		121.53		12.68		2.20		2.91	
VMJH	16:59	1.53		3.31		120.77		12.50		2.06		2.91	
VMJH	17:29	0.77		3.27		121.32		12.77		2.22		2.94	
VMJH	17:59	0.73		3.10		115.94		13.65		2.08		2.92	
VMJH	18:29	0.30		3.19		119.98		12.87		2.16		2.91	
VMJH	18:59	0.47		3.13		122.94		13.06		2.18		2.96	
VMJH	19:29	0.53		3.27		120.32		13.55		2.12		2.83	
VMJH	19:59	0.43		2.91		122.99		12.90		2.14		2.95	
VMJH	20:29	0.43		3.11		120.60		12.37		2.14		3.05	
VMJH	20:59	0.57		3.01		121.84		12.82		2.10		2.90	
VMJH	21:29	0.70		2.99		120.53		13.09		2.02		2.92	
VMJH	21:59	1.60		2.93		119.84		12.75		1.99		2.80	
VMJH	22:29	1.93		3.14		126.52		13.42		2.16		3.00	
VMJH	22:50	1.29		3.13		118.84		12.62		2.15		2.93	
VMZ		0.78		3.11		121.41		12.98		2.12		2.94	

# Valori inregistrate MIR-IS HP-1500

Data:17/03/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.40	3.18	118.16	12.93	1.92	3.04
VMJH	07:59	0.40	2.90	121.08	12.73	2.07	2.94
VMJH	08:29	0.87	3.11	120.63	12.43	1.91	2.96
VMJH	08:59	0.70	3.11	122.63	13.38	2.12	3.01
VMJH	09:29	0.90	3.03	116.51	13.44	2.12	2.94
VMJH	09:59	0.97	3.13	121.63	12.57	2.20	3.06
VMJH	10:29	0.73	3.15	120.85	12.82	2.16	3.08
VMJH	10:59	0.67	2.96	120.36	12.87	2.18	2.98
VMJH	11:29	1.27	3.12	120.68	12.48	2.15	3.03
VMJH	11:59	0.80	2.90	118.35	12.90	2.17	2.82
VMJH	12:29	0.77	3.28	120.59	13.12	2.14	2.88
VMJH	12:59	0.70	3.24	120.41	13.41	2.21	2.95
VMJH	13:29	0.53	3.60	128.86	14.36	2.54	3.10
VMJH	13:59	1.10	5.28	170.65	19.84	3.85	3.45
VMJH	14:29	1.20	5.46	172.11	20.31	4.00	3.63
VMJH	14:59	0.87	5.24	168.71	18.80	3.85	3.69
VMJH	15:29	1.80	5.49	169.72	20.73	4.06	3.52
VMJH	15:59	0.37	5.35	170.92	20.04	3.87	3.55
VMJH	16:29	0.73	5.48	170.46	19.40	4.02	3.71
VMJH	16:59	1.20	5.45	171.87	19.88	3.94	3.38
VMJH	17:29	0.90	5.58	169.65	19.98	4.07	3.57
VMJH	17:59	0.93	5.33	170.20	20.03	3.97	3.39
VMJH	18:29	1.60	5.25	168.33	19.48	4.18	3.40
VMJH	18:59	0.50	5.35	170.55	19.78	4.00	3.50
VMJH	19:29	1.23	5.29	170.86	19.56	3.82	3.56
VMJH	19:59	0.93	5.32	171.34	19.84	3.87	3.70
VMJH	20:29	0.93	5.50	170.32	19.43	3.73	3.35
VMJH	20:59	0.30	5.44	169.77	19.83	3.86	3.57
VMJH	21:29	1.23	5.46	172.03	19.95	3.70	3.45
VMJH	21:59	0.87	5.28	170.84	19.63	3.96	3.58
VMJH	22:29	1.27	5.52	170.95	19.75	3.81	3.64
VMJH	22:48	1.00	5.23	171.33	20.43	3.81	3.56
VMZ		0.89	4.46	150.12	17.03	3.19	3.31



# Valori inregistrate MIR-IS HP-1500

Data:03/04/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	11:09	0.60	2.81	111.58	13.02	2.97	2.59
VMJH	11:39	0.83	2.82	111.80	13.23	2.56	2.63
VMJH	12:09	0.63	2.71	113.40	13.20	2.55	2.58
VMJH	12:39	0.53	2.83	113.33	12.31	3.00	2.56
VMJH	13:09	1.13	3.07	112.57	13.00	2.53	2.65
VMJH	13:39	0.43	2.99	112.59	13.20	2.51	2.65
VMJH	14:09	0.57	3.33	113.03	12.16	2.87	2.62
VMJH	14:39	0.63	2.84	109.71	12.81	2.47	2.66
VMJH	15:09	1.40	3.19	110.91	13.75	2.61	2.73
VMJH	15:39	1.33	2.87	110.99	12.81	2.58	2.63
VMJH	16:09	0.70	2.77	111.94	13.10	2.35	2.62
VMJH	16:39	0.13	3.11	111.16	13.11	2.46	2.63
VMJH	17:09	1.20	2.98	110.65	13.15	2.55	2.61
VMJH	17:39	0.43	2.91	112.11	12.97	2.92	2.69
VMJH	18:09	0.73	3.17	110.91	13.10	2.66	2.59
VMJH	18:39	1.23	2.77	113.08	11.86	2.67	2.64
VMJH	19:09	1.13	3.14	113.20	12.93	2.51	2.61
VMJH	19:39	1.13	2.96	111.89	12.48	2.63	2.62
VMJH	20:09	0.70	3.12	111.33	12.76	2.73	2.60
VMJH	20:39	0.20	2.83	112.30	12.01	2.85	2.63
VMJH	21:09	0.20	3.05	113.55	13.12	2.70	2.64
VMJH	21:39	1.30	2.98	111.91	12.89	2.57	2.61
VMJH	22:09	0.40	2.85	111.37	12.94	2.72	2.63
VMJH	22:39	1.47	2.91	111.45	13.31	2.43	2.55
VMJH	22:52	1.23	3.10	108.62	12.47	2.74	2.64
VMZ		0.80	2.96	111.89	12.88	2.64	2.62



# Valori inregistrate MIR-IS HP-1500

Data:04/04/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.50	3.01	111.34	12.89	2.77	2.65
VMJH	07:59	1.10	3.04	111.47	12.76	2.43	2.62
VMJH	08:29	0.93	2.89	111.91	12.60	2.50	2.68
VMJH	08:59	0.50	2.90	112.49	12.61	2.73	2.66
VMJH	09:29	0.97	2.86	111.25	13.30	2.53	2.69
VMJH	09:59	0.87	3.19	112.91	13.71	2.50	2.63
VMJH	10:29	0.80	3.13	111.13	13.21	2.60	2.68
VMJH	10:59	1.23	2.99	111.67	13.10	2.59	2.63
VMJH	11:29	0.87	3.07	110.53	12.75	2.51	2.65
VMJH	11:59	0.43	3.07	112.26	13.10	2.92	2.59
VMJH	12:29	0.63	3.08	111.91	13.16	2.56	2.65
VMJH	12:59	0.77	3.10	112.99	13.46	2.86	2.64
VMJH	13:29	0.80	3.07	111.11	12.94	2.93	2.68
VMJH	13:59	0.50	3.15	110.41	12.31	2.63	2.64
VMJH	14:29	0.33	2.96	111.42	12.74	2.70	2.67
VMJH	14:59	0.17	3.15	110.84	12.80	2.72	2.57
VMJH	15:29	0.90	2.86	112.54	12.68	2.60	2.67
VMJH	15:59	1.30	3.15	111.80	12.85	2.65	2.63
VMJH	16:29	1.33	3.16	110.97	12.95	2.73	2.58
VMJH	16:59	1.67	3.10	112.16	11.96	2.66	2.62
VMJH	17:29	2.03	3.08	111.31	12.65	2.68	2.57
VMJH	17:59	1.40	3.15	112.51	12.41	2.59	2.65
VMJH	18:29	1.63	2.96	112.99	13.19	2.46	2.64
VMJH	18:59	1.90	4.40	137.95	15.37	3.11	2.91
VMJH	19:29	0.80	5.52	169.49	18.67	4.34	3.14
VMJH	19:59	1.43	5.80	168.99	18.79	3.97	3.07
VMJH	20:29	1.53	5.82	170.02	18.93	3.89	3.04
VMJH	20:59	1.53	5.76	170.79	18.25	3.98	3.10
VMJH	21:29	0.90	5.87	169.88	18.45	4.01	3.16
VMJH	21:59	1.17	6.06	171.35	19.27	4.04	3.16
VMJH	22:29	0.50	5.80	169.67	18.12	3.91	2.98
VMJH	22:36	0.43	5.95	168.73	19.50	4.07	3.27
VMZ		1.01	3.73	126.10	14.30	2.98	2.76

# Valori inregistrate MIR-IS HP-1500

Data:05/04/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.83	5.90	170.05	19.03	3.98	3.10
VMJH	07:59	1.83	5.83	170.23	19.42	4.01	3.17
VMJH	08:29	0.33	5.68	169.74	18.16	3.98	3.21
VMJH	08:59	1.07	5.99	169.78	18.78	3.93	3.17
VMJH	09:29	1.50	6.01	170.59	18.38	3.87	3.02
VMJH	09:59	1.13	5.79	171.10	19.58	3.99	3.08
VMJH	10:29	1.13	5.87	170.36	18.78	3.96	3.17
VMJH	10:59	1.33	5.68	169.49	19.04	3.91	3.04
VMJH	11:29	0.57	5.68	170.67	19.46	3.95	3.15
VMJH	11:59	1.70	5.80	171.93	18.48	3.98	3.08
VMJH	12:29	1.73	6.00	170.03	19.12	4.04	3.07
VMJH	12:59	1.37	5.56	170.53	18.89	3.84	3.17
VMJH	13:29	0.90	5.90	170.00	18.82	4.18	2.98
VMJH	13:59	2.47	5.73	171.44	18.64	3.85	2.99
VMJH	14:29	2.07	5.77	170.88	18.79	3.80	3.03
VMJH	14:59	1.03	5.73	171.12	19.51	4.28	3.10
VMJH	15:29	2.10	5.73	171.06	19.17	4.24	3.17
VMJH	15:59	1.43	5.77	171.76	18.54	4.15	3.21
VMJH	16:29	0.43	5.51	169.03	18.83	4.09	3.06
VMJH	16:59	1.20	5.67	169.16	18.51	4.01	3.13
VMJH	17:29	0.23	5.71	171.26	18.98	3.96	3.19
VMJH	17:59	1.37	5.68	171.45	19.13	3.85	3.15
VMJH	18:29	1.83	5.16	172.58	18.39	4.01	3.24
VMJH	18:59	1.37	5.76	170.88	19.24	3.92	3.17
VMJH	19:29	0.27	5.94	171.05	18.92	4.17	3.13
VMJH	19:59	0.50	5.39	171.46	18.95	3.94	3.15
VMJH	20:29	1.47	5.89	169.32	18.98	3.83	3.17
VMJH	20:59	0.87	5.73	170.96	18.98	4.01	3.17
VMJH	21:29	2.00	5.58	170.58	18.37	4.11	3.11
VMJH	21:59	1.43	5.78	170.48	18.72	4.00	3.10
VMJH	22:29	1.80	5.68	170.92	19.20	3.92	3.08
VMJH	22:44	0.93	5.67	170.24	18.05	3.76	3.18
VMZ		1.29	5.74	170.63	18.88	3.99	3.12



# Valori inregistrate MIR-IS HP-1500

Data:06/04/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.53	5.84	169.82	19.19	3.95	3.06
VMJH	07:59	1.23	5.69	170.91	18.06	4.12	3.11
VMJH	08:29	1.20	5.63	169.85	18.85	3.97	3.16
VMJH	08:59	1.73	6.06	171.08	19.08	4.10	3.16
VMJH	09:29	0.50	5.59	169.80	18.88	4.22	3.13
VMJH	09:59	0.93	5.48	170.17	19.06	4.03	3.19
VMJH	10:29	0.23	5.52	171.40	18.97	4.24	3.31
VMJH	10:59	1.10	5.56	170.06	18.79	4.24	3.08
VMJH	11:29	1.70	5.30	165.14	18.50	3.90	3.12
VMJH	11:59	0.80	4.28	141.14	15.93	3.23	2.88
VMJH	12:29	1.90	4.31	141.16	15.92	3.34	2.87
VMJH	12:59	1.30	4.31	140.70	15.90	3.22	2.82
VMJH	13:29	1.57	4.27	141.64	15.67	3.16	2.81
VMJH	13:59	1.30	4.51	141.35	15.96	3.33	2.85
VMJH	14:29	1.00	4.37	140.81	15.79	3.48	2.81
VMJH	14:59	0.60	4.49	141.32	16.31	3.22	2.84
VMJH	15:29	1.27	4.38	141.88	15.67	3.36	2.84
VMJH	15:59	0.33	4.59	141.74	15.93	3.28	2.91
VMJH	16:29	1.20	4.49	140.52	15.79	3.33	2.82
VMJH	16:59	0.87	4.45	140.73	15.92	3.46	2.88
VMJH	17:29	1.03	4.52	140.14	16.55	3.46	2.86
VMJH	17:59	1.37	4.37	141.60	15.92	3.36	2.85
VMJH	18:29	1.10	4.51	141.31	16.36	3.42	2.94
VMJH	18:59	1.17	4.55	142.20	15.63	3.40	2.84
VMJH	19:29	0.73	4.27	141.05	15.65	3.20	2.91
VMJH	19:59	0.90	4.53	141.33	16.26	3.22	2.98
VMJH	20:29	0.47	4.19	140.78	15.80	3.32	2.90
VMJH	20:59	0.30	4.59	141.16	16.09	3.14	2.79
VMJH	21:29	1.37	4.38	142.23	16.25	3.30	2.86
VMJH	21:59	1.03	4.40	140.99	15.81	3.22	2.90
VMJH	22:30	1.26	4.35	142.12	16.18	3.34	2.90
VMZ		1.03	4.77	149.54	16.79	3.53	2.95



# Valori inregistrate MIR-IS HP-1500

Data:07/04/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	2.10	4.46	140.73	15.80	3.42	2.85
VMJH	07:59	2.00	4.32	141.80	16.11	3.32	2.82
VMJH	08:29	0.97	4.45	140.62	15.85	3.38	2.90
VMJH	08:59	0.77	4.42	141.34	16.04	3.29	2.85
VMJH	09:29	0.93	4.42	140.47	15.81	3.37	2.90
VMJH	09:59	1.43	4.51	140.35	15.58	3.31	2.88
VMJH	10:29	2.07	4.39	141.33	15.86	3.18	2.90
VMJH	10:59	1.67	4.50	141.88	15.87	3.28	2.85
VMJH	11:29	1.40	4.52	141.48	15.66	3.38	2.88
VMJH	11:59	1.37	4.34	141.42	15.91	3.42	2.85
VMJH	12:29	1.73	4.28	140.63	15.83	3.55	2.83
VMJH	12:59	1.47	4.45	141.73	16.04	3.25	2.88
VMJH	13:29	1.57	4.33	141.19	16.14	3.41	2.95
VMJH	13:59	0.80	4.22	142.06	16.27	3.27	2.89
VMJH	14:29	0.77	4.56	141.76	15.63	3.32	2.94
VMJH	14:59	1.43	4.34	141.52	16.14	3.32	2.80
VMJH	15:29	0.60	4.42	140.67	16.13	3.38	2.90
VMJH	15:59	0.20	4.34	141.51	15.76	3.32	2.91
VMJH	16:29	0.97	4.41	141.69	15.85	3.26	2.85
VMJH	16:59	1.20	4.32	141.32	15.97	3.19	2.90
VMJH	17:29	1.47	4.27	140.57	15.82	3.35	2.78
VMJH	17:59	1.17	4.48	140.92	15.88	3.35	2.86
VMJH	18:29	0.70	4.24	141.06	15.91	3.35	2.90
VMJH	18:59	1.67	4.31	141.63	15.91	3.38	2.78
VMJH	19:29	0.83	4.42	140.68	15.57	3.17	2.83
VMJH	19:59	0.33	4.32	142.17	15.88	3.60	2.95
VMJH	20:29	1.53	4.49	143.19	17.77	3.29	3.11
VMJH	20:59	2.40	4.42	143.55	17.23	3.52	3.04
VMJH	21:29	1.93	4.32	143.77	17.08	3.13	3.12
VMJH	21:59	2.30	4.47	142.76	17.03	3.41	3.06
VMJH	22:24	2.36	4.75	143.36	17.16	3.46	3.18
VMZ		1.35	4.40	141.58	16.11	3.34	2.91

# Valori inregistrate MIR-IS HP-1500

Data:10/04/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	2.27	4.67	143.49	17.49	3.52	3.04
VMJH	07:59	1.83	4.45	143.09	17.52	3.27	3.18
VMJH	08:29	1.67	4.56	142.76	17.17	3.37	3.00
VMJH	08:59	2.73	4.53	143.56	17.38	3.45	3.02
VMJH	09:29	2.83	4.52	143.01	17.09	3.42	3.10
VMJH	09:59	1.80	4.37	142.18	17.48	3.38	2.95
VMJH	10:29	1.90	4.44	142.16	17.32	3.43	3.12
VMJH	10:59	3.20	4.40	143.28	17.88	3.28	3.07
VMJH	11:29	1.33	4.32	144.26	17.19	3.24	3.02
VMJH	11:59	1.70	4.40	143.10	17.65	3.38	3.08
VMJH	12:29	0.93	4.34	142.91	17.41	3.27	3.11
VMJH	12:59	1.23	4.67	144.65	16.55	3.38	3.06
VMJH	13:29	1.30	4.29	143.72	17.34	3.41	2.95
VMJH	13:59	1.60	4.40	141.92	17.09	3.47	3.04
VMJH	14:29	1.80	4.47	141.61	17.81	3.40	3.01
VMJH	14:59	1.27	4.39	143.91	16.82	3.47	3.11
VMJH	15:29	0.47	4.41	144.29	16.73	3.55	3.00
VMJH	15:59	1.10	4.43	143.55	17.17	3.49	3.12
VMJH	16:29	1.80	4.44	142.43	17.54	3.12	3.06
VMJH	16:59	1.47	4.42	142.69	17.52	3.47	3.07
VMJH	17:29	2.00	4.54	142.44	17.30	3.29	3.09
VMJH	17:59	1.10	4.46	142.36	17.15	3.20	3.04
VMJH	18:29	0.50	4.47	142.93	17.04	3.36	3.07
VMJH	18:59	1.63	4.64	142.77	17.47	3.33	3.04
VMJH	19:29	1.67	4.45	141.93	17.88	3.34	2.98
VMJH	19:59	0.80	4.44	142.08	17.65	3.35	3.08
VMJH	20:29	1.23	4.56	143.50	17.12	3.43	3.04
VMJH	20:59	1.37	4.52	141.64	17.13	3.37	2.98
VMJH	21:29	0.47	4.50	142.09	17.22	3.40	3.11
VMJH	21:59	1.13	4.36	143.62	17.05	3.32	3.01
VMJH	22:24	1.24	4.49	143.02	18.14	3.35	2.93
VMZ		1.53	4.46	142.93	17.33	3.37	3.05

# Valori inregistrate MIR-IS HP-1500

Data:11/04/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	15:29	1.50	4.52	142.20	17.50	3.44	3.01
VMJH	15:59	1.67	4.45	142.60	16.86	3.33	3.07
VMJH	16:29	1.13	4.36	141.30	17.64	3.28	3.07
VMJH	16:59	1.53	4.35	144.37	17.62	3.31	3.06
VMJH	17:29	1.90	4.46	143.62	17.57	3.37	3.00
VMJH	17:59	1.63	4.36	142.00	17.36	3.34	3.12
VMJH	18:29	1.40	4.49	144.14	17.57	3.44	3.13
VMJH	18:59	1.20	4.44	143.75	17.45	3.42	3.10
VMJH	19:29	1.30	4.57	141.85	18.12	3.36	3.00
VMJH	19:59	1.43	4.37	143.03	16.84	3.51	3.00
VMJH	20:29	1.10	4.47	142.78	16.85	3.43	3.13
VMJH	20:59	1.07	4.54	142.68	17.63	3.40	3.03
VMJH	21:29	1.13	5.50	166.29	20.74	3.56	3.32
VMJH	21:59	0.87	5.56	169.75	18.79	3.47	3.19
VMJH	22:27	1.07	5.31	169.23	19.89	3.47	3.40
VMZ		1.33	4.65	147.88	17.89	3.41	3.11



# Valori inregistrate MIR-IS HP-1500

Data:12/04/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	16:18	1.20	5.52	170.99	20.03	3.38	3.20
VMJH	16:48	1.40	5.46	172.00	20.35	3.76	3.41
VMJH	17:18	1.17	5.64	172.86	21.23	3.46	3.45
VMJH	17:48	1.40	5.79	172.16	19.44	3.53	3.40
VMJH	18:18	1.30	5.46	170.59	21.01	3.78	3.31
VMJH	18:48	1.63	5.53	170.94	19.96	3.69	3.30
VMJH	19:18	1.33	5.59	170.55	20.25	3.65	3.08
VMJH	19:48	1.43	5.39	170.70	20.30	3.99	3.35
VMJH	20:18	1.63	5.33	172.33	20.38	3.45	3.51
VMJH	20:48	1.10	5.61	171.13	20.10	4.13	3.32
VMJH	21:18	1.47	5.67	172.50	21.04	3.70	3.43
VMJH	21:48	0.77	5.67	169.63	20.33	4.04	3.28
VMJH	22:18	1.43	5.79	171.76	20.52	3.80	3.45
VMJH	22:48	1.43	5.40	170.43	21.42	3.68	3.32
VMJH	23:18	0.43	5.77	172.36	19.45	3.67	3.24
VMJH	23:48	1.23	5.60	172.01	19.85	3.86	3.32
VMJH	23:59	1.00	5.69	170.88	19.36	3.35	3.74
VMZ		1.27	5.58	171.42	20.33	3.72	3.35

# Valori inregistrate MIR-IS HP-1500

Data:13/04/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	00:29	0.80	5.54	171.47	20.12	4.06	3.39
VMJH	00:59	0.13	5.68	170.06	19.50	3.67	3.28
VMJH	01:29	0.53	5.53	170.02	20.25	4.01	3.35
VMJH	01:59	1.03	5.79	170.01	21.09	3.71	3.34
VMJH	02:29	1.07	5.38	171.53	19.46	3.55	3.40
VMJH	02:59	0.83	5.59	171.94	20.34	3.86	3.24
VMJH	03:29	0.77	5.61	172.44	19.75	4.00	3.36
VMJH	03:59	0.57	5.64	171.22	20.51	3.54	3.29
VMJH	04:29	0.33	5.33	170.18	20.36	3.83	3.23
VMJH	04:59	0.93	5.53	170.63	20.80	3.53	3.42
VMJH	05:29	0.53	5.51	171.41	19.93	3.85	3.23
VMJH	05:59	1.03	5.44	172.16	20.15	3.92	3.34
VMJH	06:29	1.20	5.48	169.62	20.76	3.48	3.30
VMJH	06:55	0.85	5.87	171.30	19.67	3.61	3.39
VMZ		0.76	5.56	171.00	20.20	3.76	3.33

# Valori inregistrate MIR-IS HP-1500

Data:13/04/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 15:59	0.53	5.44	170.82	19.48	3.77	3.31
VMJH 16:29	0.47	5.37	171.69	20.29	3.79	3.39
VMJH 16:59	0.57	5.57	172.49	20.14	3.65	3.22
VMJH 17:29	0.77	5.54	172.33	19.27	3.55	3.31
VMJH 17:59	0.50	5.70	170.81	19.55	3.76	3.34
VMJH 18:29	1.03	5.51	170.74	19.55	3.88	3.11
VMJH 18:59	0.83	5.43	169.85	21.05	3.82	3.30
VMJH 19:29	0.50	5.39	170.52	19.15	3.71	3.26
VMJH 19:59	0.70	5.43	171.24	19.61	3.53	3.43
VMJH 20:29	1.10	5.30	171.03	20.56	3.68	3.30
VMJH 20:59	0.70	5.70	170.67	20.06	3.52	3.26
VMJH 21:29	0.33	5.24	171.54	20.65	3.50	3.43
VMJH 21:59	1.10	5.42	170.73	20.93	3.69	3.41
VMJH 22:29	1.27	5.47	174.80	20.99	3.82	3.40
VMJH 22:59	1.53	5.72	167.61	19.92	3.67	3.44
VMJH 23:29	1.07	3.13	112.43	14.63	2.87	2.77
VMJH 23:59	1.10	3.46	115.48	14.43	2.83	2.66
VMZ	0.83	5.22	164.40	19.43	3.59	3.26



# Valori inregistrate MIR-IS HP-1500

Data:14/04/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	00:29	0.67	3.51	116.33	14.53	2.94	2.80
VMJH	00:59	1.23	3.17	115.37	14.37	3.11	2.72
VMJH	01:29	1.47	3.27	116.01	14.89	3.00	2.80
VMJH	01:59	1.37	3.17	113.62	14.10	2.86	2.72
VMJH	02:29	1.03	3.36	115.52	14.21	3.19	2.73
VMJH	02:59	0.97	3.36	114.43	14.56	2.79	2.77
VMJH	03:29	1.23	3.33	115.15	14.12	2.87	2.82
VMJH	03:59	0.60	3.37	115.76	14.83	3.03	2.83
VMJH	04:29	0.90	3.20	112.83	14.84	3.01	2.81
VMJH	04:59	1.43	3.27	113.53	14.33	2.91	2.79
VMJH	05:29	1.47	3.30	114.49	14.79	3.14	2.80
VMJH	05:59	1.23	3.37	114.63	14.67	2.90	2.82
VMJH	06:29	1.13	3.18	115.80	14.69	3.22	2.79
VMJH	06:49	1.00	3.35	116.10	14.84	3.06	2.73
VMZ		1.13	3.30	114.94	14.55	3.00	2.78

# Valori inregistrate MIR-IS HP-1500

Data:18/04/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:29	1.03	3.33	114.09	14.76	3.02	2.66
VMJH	15:59	0.63	3.42	116.82	14.79	2.92	2.83
VMJH	16:29	0.87	3.28	115.24	14.30	3.09	2.81
VMJH	16:59	0.63	3.32	113.81	14.48	2.98	2.80
VMJH	17:29	0.73	3.37	116.50	14.27	2.87	2.78
VMJH	17:59	0.97	3.60	115.68	14.42	3.02	2.67
VMJH	18:29	1.27	3.42	112.95	14.90	3.12	2.73
VMJH	18:59	1.07	3.39	115.22	14.17	3.06	2.79
VMJH	19:29	1.33	3.30	114.95	15.25	2.99	2.77
VMJH	19:59	0.40	3.24	113.80	14.22	3.04	2.80
VMJH	20:29	0.90	3.37	114.64	13.56	3.14	2.77
VMJH	20:59	1.27	3.47	114.09	14.64	3.03	2.70
VMJH	21:29	1.00	3.27	114.81	14.66	2.96	2.74
VMJH	21:59	1.00	3.38	113.51	14.87	2.97	2.75
VMJH	22:29	1.67	3.15	115.71	14.02	3.16	2.73
VMJH	22:50	1.62	3.37	116.68	13.92	3.03	2.77
VMZ		1.01	3.36	114.87	14.46	3.03	2.76

# Valori inregistrate MIR-IS HP-1500

Data:19/04/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.27	3.33	115.54	14.52	3.08	2.80					
VMJH	07:59	1.03	3.27	115.37	14.20	3.05	2.79					
VMJH	08:29	1.43	3.31	112.07	14.42	2.96	2.83					
VMJH	08:59	1.23	3.33	112.90	14.15	2.92	2.78					
VMJH	09:29	1.33	3.44	114.52	14.54	3.04	2.76					
VMJH	09:59	1.07	3.31	114.71	14.25	2.85	2.71					
VMJH	10:29	1.37	3.31	116.18	14.96	3.06	2.82					
VMJH	10:59	0.57	3.24	114.88	14.37	3.00	2.78					
VMJH	11:29	0.67	3.28	114.43	13.89	3.15	2.67					
VMJH	11:59	0.40	3.14	114.39	14.07	2.97	2.81					
VMJH	12:29	0.47	3.37	114.64	14.83	3.13	2.76					
VMJH	12:59	0.70	3.35	114.89	14.76	2.93	2.74					
VMJH	13:29	0.83	3.24	115.25	14.79	3.10	2.81					
VMJH	13:59	1.37	3.29	116.30	14.70	2.71	2.79					
VMJH	14:29	0.90	3.50	115.43	13.79	2.71	2.78					
VMJH	14:59	0.67	3.26	115.73	14.92	3.07	2.73					
VMJH	15:29	1.77	3.36	116.00	13.90	2.93	2.95					
VMJH	15:59	1.33	3.21	120.19	13.69	2.68	3.02					
VMJH	16:29	1.87	3.10	120.19	12.65	2.53	2.77					
VMJH	16:59	1.53	3.09	120.26	13.16	2.61	2.98					
VMJH	17:29	0.87	3.10	121.05	13.61	2.56	2.90					
VMJH	17:59	1.70	3.23	118.68	13.63	2.61	3.00					
VMJH	18:29	1.73	3.34	120.84	12.80	2.58	3.10					
VMJH	18:59	1.40	3.05	119.99	13.68	2.56	3.05					
VMJH	19:29	0.97	3.07	121.06	13.40	2.61	2.94					
VMJH	19:59	1.10	3.14	120.17	13.49	2.65	3.03					
VMJH	20:29	0.97	3.20	121.07	13.82	2.65	3.00					
VMJH	20:59	1.30	3.16	120.57	13.41	2.75	3.13					
VMJH	21:29	1.33	3.11	120.64	13.65	2.55	3.12					
VMJH	21:59	1.03	2.85	120.46	13.50	2.63	3.11					
VMJH	22:29	1.47	3.05	120.42	13.42	2.65	2.96					
VMJH	22:50	1.29	3.19	120.98	13.28	2.71	2.90					
VMZ		1.15	3.23	117.46	13.95	2.81	2.88					



# Valori inregistrate MIR-IS HP-1500

Data:20/04/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	2.90		3.25		120.05		13.82		2.74		2.86	
VMJH	07:59	1.57		2.95		120.17		12.82		2.67		3.03	
VMJH	08:29	1.83		3.27		120.63		13.70		2.63		2.96	
VMJH	08:59	1.30		3.02		121.59		13.52		2.72		3.06	
VMJH	09:29	2.67		3.11		121.31		12.96		2.76		2.97	
VMJH	09:59	2.10		3.16		121.15		12.69		2.56		3.03	
VMJH	10:29	1.63		3.12		120.56		13.22		2.65		3.04	
VMJH	10:59	1.23		3.29		119.74		13.36		2.73		3.05	
VMJH	11:29	1.73		3.14		120.42		13.28		2.76		2.90	
VMJH	11:59	1.77		3.08		120.89		12.94		2.52		2.88	
VMJH	12:29	1.13		3.22		119.99		12.92		2.51		3.07	
VMJH	12:59	1.80		2.98		121.57		12.95		2.60		3.02	
VMJH	13:29	0.90		3.09		120.78		13.46		2.68		3.00	
VMJH	13:59	1.77		3.28		120.65		13.77		2.60		2.96	
VMJH	14:29	1.07		3.17		120.20		13.45		2.66		2.93	
VMJH	14:59	2.20		3.24		120.46		12.95		2.63		2.96	
VMJH	15:29	1.77		3.07		121.16		13.26		2.43		2.99	
VMJH	15:59	1.50		3.10		120.41		14.25		2.66		3.04	
VMJH	16:29	1.60		3.15		121.22		13.51		2.68		3.07	
VMJH	16:59	1.60		3.10		120.82		13.09		2.64		2.98	
VMJH	17:29	1.50		3.15		120.76		13.58		2.69		3.03	
VMJH	17:59	1.50		3.08		120.63		13.50		2.58		2.83	
VMJH	18:29	0.80		3.05		121.44		13.40		2.60		3.01	
VMJH	18:59	0.40		3.07		121.00		13.45		2.62		2.91	
VMJH	19:29	0.37		3.23		120.76		13.70		2.61		3.04	
VMJH	19:59	0.83		3.18		119.31		13.42		2.65		3.00	
VMJH	20:29	0.73		3.07		121.39		12.68		2.60		3.08	
VMJH	20:59	0.90		3.06		120.47		13.16		2.61		2.98	
VMJH	21:29	1.20		3.12		120.57		13.40		2.66		2.93	
VMJH	21:59	1.13		3.10		119.88		13.86		2.58		3.03	
VMJH	22:29	1.17		3.03		120.64		14.04		2.61		2.87	
VMJH	22:42	1.08		3.19		119.20		13.87		2.66		2.88	
VMZ		1.43		3.13		120.64		13.36		2.63		2.98	

# Valori inregistrate MIR-IS HP-1500

Data:21/04/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 100 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 07:29	0.63	2.90	145.15	17.39	3.06	3.44
VMJH 07:59	0.83	2.80	144.40	17.44	3.28	3.39
VMJH 08:29	0.33	2.89	145.08	17.60	3.18	3.38
VMJH 08:59	0.80	2.92	145.52	17.43	3.17	3.35
VMJH 09:29	0.93	2.82	144.36	17.40	3.14	3.35
VMJH 09:59	0.40	2.83	145.37	18.22	3.17	3.34
VMJH 10:29	1.37	2.80	145.56	17.70	3.21	3.20
VMJH 10:59	1.67	2.82	145.20	17.52	3.33	3.30
VMJH 11:29	0.33	2.85	144.77	18.42	3.20	3.34
VMJH 11:59	0.47	2.94	145.89	17.63	3.18	3.40
VMJH 12:29	0.53	2.78	143.68	18.51	3.21	3.42
VMJH 12:59	1.00	2.84	144.46	18.07	3.15	3.39
VMJH 13:29	1.07	2.79	145.81	18.45	3.14	3.25
VMJH 13:59	0.43	2.83	146.12	17.61	3.21	3.29
VMJH 14:29	0.90	2.82	143.87	19.19	3.18	3.36
VMJH 14:59	0.60	2.78	143.19	17.70	3.15	3.28
VMJH 15:29	0.93	2.85	145.78	17.93	3.16	3.34
VMJH 15:59	0.40	2.81	146.41	17.55	3.13	3.09
VMJH 16:29	0.93	2.83	145.11	17.84	3.27	3.31
VMJH 16:59	0.60	2.78	144.96	17.94	3.09	3.37
VMJH 17:29	0.30	2.92	143.79	17.47	3.29	3.05
VMJH 17:59	0.50	3.14	142.01	17.46	3.14	3.06
VMJH 18:29	0.60	3.03	141.99	17.44	3.14	3.16
VMJH 18:59	1.03	3.03	141.39	17.20	3.15	3.19
VMJH 19:29	0.73	3.06	142.59	17.23	2.96	3.10
VMJH 19:59	0.50	3.13	141.65	17.23	3.13	3.13
VMJH 20:29	0.80	3.03	142.73	17.67	3.09	3.15
VMJH 20:59	0.67	3.05	141.73	17.15	3.08	3.16
VMJH 21:29	0.90	2.93	142.14	17.34	3.03	3.25
VMJH 21:59	0.67	3.13	141.72	17.06	3.09	3.20
VMJH 22:29	0.67	3.09	142.41	17.15	3.17	3.22
VMJH 22:49	0.65	3.01	141.91	17.67	3.08	3.36
VMZ	0.73	2.91	143.98	17.68	3.16	3.27



# Valori inregistrate MIR-IS HP-1500

Data:24/04/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 100 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	10:44	1.43	3.12	121.08	13.08	2.63	2.87
VMJH	11:14	1.30	3.53	118.46	13.97	2.61	2.87
VMJH	11:44	0.97	4.25	117.37	13.29	2.51	2.67
VMJH	12:14	0.60	4.13	116.73	13.42	2.53	2.74
VMJH	12:44	1.50	4.35	116.93	13.67	2.57	2.75
VMJH	13:14	0.93	4.29	118.48	13.02	2.44	2.63
VMJH	13:44	1.87	4.49	118.61	13.31	2.52	2.68
VMJH	14:14	1.67	3.99	117.22	13.16	2.54	2.69
VMJH	14:44	1.43	3.89	116.56	12.85	2.44	2.64
VMJH	15:14	1.53	3.89	117.92	13.24	2.55	2.71
VMJH	15:44	1.07	4.40	116.74	13.34	2.54	2.65
VMJH	16:14	1.63	4.69	117.23	13.87	2.61	2.61
VMJH	16:44	1.33	4.43	117.18	12.83	2.53	2.65
VMJH	17:14	1.67	4.14	118.12	13.43	2.53	2.59
VMJH	17:44	1.57	4.17	115.77	12.52	2.58	2.69
VMJH	18:14	0.73	3.89	119.73	14.04	2.37	2.62
VMJH	18:44	0.60	4.22	117.89	13.68	2.58	2.64
VMJH	19:14	1.07	4.27	116.83	13.77	2.56	2.74
VMJH	19:44	0.50	4.42	117.58	13.39	2.50	2.63
VMJH	20:14	0.90	4.07	118.17	13.66	2.52	2.59
VMJH	20:44	0.70	4.10	117.88	13.17	2.57	2.65
VMJH	21:14	0.47	4.13	117.79	12.92	2.55	2.61
VMJH	21:44	0.53	3.94	117.47	13.40	2.47	2.69
VMJH	22:14	1.67	4.19	117.35	13.50	2.46	2.63
VMJH	22:44	0.80	4.50	117.03	13.43	2.41	2.71
VMJH	22:48	1.50	4.13	117.18	13.55	2.54	2.73
VMZ		1.14	4.14	117.68	13.36	2.53	2.68



# Valori inregistrate MIR-IS HP-1500

Data:25/04/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.03	4.04	116.63	13.63	2.50	2.59
VMJH	07:59	1.37	4.35	116.62	13.55	2.45	2.72
VMJH	08:29	2.00	4.43	118.24	12.81	2.47	2.69
VMJH	08:59	0.90	4.35	118.50	13.73	2.52	2.72
VMJH	09:29	1.70	4.19	119.49	13.52	2.55	2.73
VMJH	09:59	0.90	3.94	117.75	13.68	2.51	2.58
VMJH	10:29	0.57	4.20	118.45	13.25	2.54	2.65
VMJH	10:59	1.03	4.37	117.66	13.99	2.44	2.71
VMJH	11:29	0.80	4.05	116.56	13.65	2.42	2.66
VMJH	11:59	0.63	4.04	117.84	13.15	2.50	2.67
VMJH	12:29	0.87	4.33	116.95	12.92	2.41	2.73
VMJH	12:59	0.53	4.32	118.80	13.74	2.54	2.72
VMJH	13:29	0.57	4.16	116.60	12.95	2.50	2.62
VMJH	13:59	0.63	3.86	117.53	13.86	2.45	2.61
VMJH	14:29	1.17	4.15	118.41	13.20	2.46	2.61
VMJH	14:59	1.33	3.79	118.10	13.38	2.54	2.65
VMJH	15:29	1.17	4.25	117.52	13.51	2.51	2.74
VMJH	15:59	0.87	4.28	118.35	13.27	2.46	2.62
VMJH	16:29	1.43	3.76	116.94	12.96	2.51	2.76
VMJH	16:59	1.33	3.70	117.45	13.38	2.56	2.73
VMJH	17:29	0.60	4.08	117.93	13.60	2.58	2.62
VMJH	17:59	1.23	4.20	117.87	13.63	2.47	2.68
VMJH	18:29	1.03	4.53	116.99	13.50	2.51	2.61
VMJH	18:59	0.90	4.43	117.05	13.70	2.48	2.70
VMJH	19:29	1.23	2.86	118.70	14.35	2.79	2.82
VMJH	19:59	1.17	2.35	118.84	13.98	2.80	2.98
VMJH	20:29	1.33	2.22	117.81	13.95	2.83	3.07
VMJH	20:59	0.60	2.25	121.49	13.55	2.84	3.01
VMJH	21:29	1.03	2.26	120.44	13.43	2.93	2.84
VMJH	21:59	1.77	2.26	121.18	14.02	2.81	3.16
VMJH	22:32	1.61	2.21	119.49	13.82	2.88	2.81
VMZ		1.08	3.74	118.14	13.54	2.57	2.74

# Valori inregistrate MIR-IS HP-1500

Data:26/04/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.50		2.28		119.09		14.08		2.81		2.95	
VMJH	07:59	1.30		2.26		121.35		13.58		2.89		3.01	
VMJH	08:29	1.60		2.26		121.20		13.46		2.98		3.02	
VMJH	08:59	1.10		2.21		120.19		13.75		3.03		2.80	
VMJH	09:29	0.90		2.38		119.42		13.47		2.92		2.96	
VMJH	09:59	1.33		2.27		120.91		14.21		2.78		2.94	
VMJH	10:29	0.63		2.23		120.41		13.62		2.83		2.98	
VMJH	10:59	0.90		2.19		120.89		14.07		2.74		2.88	
VMJH	11:29	0.83		2.31		118.54		14.10		2.82		2.94	
VMJH	11:59	0.80		2.27		119.66		13.88		2.84		2.86	
VMJH	12:29	1.00		2.29		120.82		13.70		2.85		2.92	
VMJH	12:59	1.30		2.19		119.51		13.54		3.00		2.96	
VMJH	13:29	0.77		2.28		120.17		13.79		2.83		2.91	
VMJH	13:59	1.23		2.30		120.67		14.52		2.86		2.75	
VMJH	14:29	0.93		2.25		120.35		13.11		2.78		3.05	
VMJH	14:59	1.37		2.19		119.37		13.62		2.76		3.03	
VMJH	15:29	1.27		2.25		120.54		14.17		2.90		2.83	
VMJH	15:59	3.43		2.20		121.67		14.07		2.80		2.87	
VMJH	16:29	0.87		2.26		120.67		13.69		2.68		3.04	
VMJH	16:59	1.07		2.29		120.88		13.96		3.09		3.01	
VMJH	17:29	0.90		2.22		117.84		13.55		2.82		2.94	
VMJH	17:59	2.10		2.28		120.20		14.32		2.75		2.98	
VMJH	18:29	1.90		2.22		120.27		14.55		2.94		2.87	
VMJH	18:59	1.73		2.29		118.53		14.26		2.86		2.82	
VMJH	19:29	1.17		2.34		121.54		14.20		2.93		2.92	
VMJH	19:59	2.20		2.24		120.60		14.41		2.97		3.00	
VMJH	20:29	1.03		2.34		120.08		14.44		2.74		2.74	
VMJH	20:59	1.00		2.20		118.32		14.15		2.90		3.04	
VMJH	21:29	1.13		2.18		118.83		13.03		2.96		2.86	
VMJH	21:59	1.43		2.25		119.26		14.07		2.76		2.85	
VMJH	22:29	0.73		2.23		119.48		13.69		3.01		3.03	
VMJH	22:48	1.26		2.22		120.26		14.10		2.97		2.81	
VMZ		1.27		2.26		120.05		13.91		2.87		2.92	



# Valori inregistrate MIR-IS HP-1500

Data:27/04/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	07:29	0.77	2.22	120.87	14.02	2.92	2.97
VMJH	07:59	0.70	2.20	121.17	13.51	2.93	2.95
VMJH	08:29	1.13	2.23	119.31	13.83	2.88	2.91
VMJH	08:59	1.13	2.24	121.73	14.35	2.78	2.99
VMJH	09:29	1.80	2.18	119.19	13.56	2.89	2.97
VMJH	09:59	0.67	2.30	119.73	13.91	2.83	2.88
VMJH	10:29	0.97	2.19	119.32	13.94	2.77	3.01
VMJH	10:59	0.90	2.22	120.17	13.87	2.81	2.96
VMJH	11:29	1.10	2.29	120.06	13.25	2.98	3.00
VMJH	11:59	1.93	2.79	138.86	17.10	3.29	3.41
VMJH	12:29	0.80	3.52	169.61	22.50	3.17	3.70
VMJH	12:59	1.63	3.42	169.75	21.06	3.40	3.54
VMJH	13:29	1.03	3.39	170.33	21.11	3.44	3.57
VMJH	13:59	1.07	3.42	169.61	22.48	3.50	3.72
VMJH	14:29	0.90	3.42	168.94	22.73	3.41	3.55
VMJH	14:59	0.87	3.41	170.87	21.60	3.55	3.49
VMJH	15:29	0.77	3.38	170.30	21.83	3.80	3.80
VMJH	15:59	0.73	3.38	170.39	22.14	3.57	3.77
VMJH	16:29	1.23	3.40	169.45	22.27	3.42	3.76
VMJH	16:59	0.87	3.37	170.34	22.66	3.50	3.64
VMJH	17:29	1.37	3.44	171.01	22.50	3.54	3.67
VMJH	17:59	1.33	3.31	170.53	21.33	3.85	3.35
VMJH	18:29	1.33	3.37	170.24	21.48	3.51	3.68
VMJH	18:59	1.20	3.38	170.05	22.47	3.91	3.49
VMJH	19:29	1.67	3.39	171.02	22.06	3.36	3.54
VMJH	19:59	1.13	3.36	167.29	22.19	3.31	3.91
VMJH	20:29	1.07	3.42	169.69	21.75	3.24	3.44
VMJH	20:59	1.40	3.47	169.85	20.75	3.16	3.68
VMJH	21:29	1.60	3.38	169.59	22.15	3.49	3.72
VMJH	21:59	1.13	3.45	170.29	22.01	3.53	3.40
VMJH	22:29	0.93	3.39	170.18	22.16	3.54	3.42
VMJH	22:44	2.53	3.30	170.22	22.65	3.60	3.62
VMZ		1.16	3.05	154.77	19.49	3.30	3.42



# Valori inregistrate MIR-IS HP-1500

Data:28/04/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	0.77	3.46	169.16	22.46	3.74	3.60					
VMJH	07:59	1.13	3.38	169.87	22.93	3.63	3.61					
VMJH	08:29	1.03	3.41	170.32	22.26	3.52	3.55					
VMJH	08:59	0.37	3.36	170.22	20.54	3.62	3.40					
VMJH	09:29	0.70	3.50	170.10	21.56	3.35	3.38					
VMJH	09:59	0.97	3.42	171.72	21.71	3.73	3.64					
VMJH	10:29	0.63	3.26	168.44	22.36	3.54	3.32					
VMJH	10:59	0.40	3.39	168.19	20.51	3.42	3.87					
VMJH	11:29	1.13	3.29	169.29	20.75	3.56	3.87					
VMJH	11:59	0.87	3.34	170.66	21.36	3.16	3.70					
VMJH	12:29	1.57	3.33	169.00	22.46	3.72	3.53					
VMJH	12:59	0.97	3.25	169.75	20.46	3.61	3.65					
VMJH	13:29	1.20	3.37	170.45	21.77	3.62	3.49					
VMJH	13:59	0.20	3.24	170.66	22.34	3.48	3.61					
VMJH	14:29	0.17	3.42	169.88	21.60	3.35	3.64					
VMJH	14:59	0.50	3.38	170.38	21.59	3.72	3.58					
VMJH	15:29	1.37	3.41	170.67	20.71	3.60	3.57					
VMJH	15:59	0.70	3.47	169.45	21.74	3.61	3.70					
VMJH	16:29	2.30	3.47	168.02	21.86	3.56	3.46					
VMJH	16:59	0.13	3.31	170.05	21.36	3.49	3.59					
VMJH	17:29	0.80	3.42	169.03	21.14	3.41	3.73					
VMJH	17:59	1.03	3.30	169.36	21.50	3.51	3.57					
VMJH	18:29	1.37	3.41	170.70	22.86	3.45	3.69					
VMJH	18:59	0.30	3.28	170.17	22.86	3.37	3.74					
VMJH	19:29	0.50	3.44	169.06	21.84	3.54	3.69					
VMJH	19:59	0.80	3.47	169.84	21.95	3.39	3.61					
VMJH	20:29	1.37	2.90	148.10	18.10	3.27	3.26					
VMJH	20:59	1.40	2.82	144.47	18.16	3.30	3.42					
VMJH	21:29	1.03	2.85	144.32	17.74	3.41	3.21					
VMJH	21:59	1.07	2.84	144.38	17.83	3.20	3.34					
VMJH	22:29	0.30	2.79	145.30	18.11	3.14	3.32					
VMJH	22:40	0.36	2.69	146.07	18.12	3.02	3.62					
VMZ		0.87	3.28	165.60	21.07	3.48	3.56					

# Valori inregistrate MIR-IS HP-1500

Data:02/05/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 12:44	0.97	2.90	144.99	17.39	3.08	3.43
VMJH 13:14	1.03	2.80	144.40	17.44	3.28	3.39
VMJH 13:44	0.67	2.89	145.08	17.60	3.18	3.38
VMJH 14:14	0.87	2.92	145.52	17.43	3.17	3.35
VMJH 14:44	0.70	2.82	144.36	17.40	3.14	3.35
VMJH 15:14	0.53	2.83	145.37	18.22	3.17	3.34
VMJH 15:44	0.67	2.80	145.56	17.70	3.21	3.20
VMJH 16:14	0.60	2.82	145.20	17.52	3.33	3.30
VMJH 16:44	0.50	2.85	144.77	18.42	3.20	3.34
VMJH 17:14	0.87	2.94	145.89	17.63	3.18	3.40
VMJH 17:44	1.50	2.78	143.68	18.51	3.21	3.42
VMJH 18:14	0.50	2.84	144.46	18.07	3.15	3.39
VMJH 18:44	1.00	2.79	145.81	18.45	3.14	3.25
VMJH 19:14	1.07	2.83	146.12	17.61	3.21	3.29
VMJH 19:44	1.33	2.82	143.87	19.19	3.18	3.36
VMJH 20:14	2.03	2.78	143.19	17.70	3.15	3.28
VMJH 20:44	1.97	2.85	145.78	17.93	3.16	3.34
VMJH 21:14	1.03	2.81	146.41	17.55	3.13	3.09
VMJH 21:44	1.63	2.83	145.11	17.84	3.27	3.31
VMJH 22:14	1.33	2.78	144.96	17.94	3.09	3.37
VMJH 22:44	1.53	4.15	143.16	17.81	3.19	3.16
VMJH 22:48	4.75	4.92	139.01	15.44	3.28	3.33
VMZ	1.09	2.91	144.89	17.86	3.18	3.32

# Valori inregistrate MIR-IS HP-1500

Data:03/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	1.83		5.02		140.89		17.36		3.18		3.21
VMJH	07:59	1.63		5.03		142.70		17.62		3.23		3.22
VMJH	08:29	1.83		4.98		141.68		17.15		3.37		3.11
VMJH	08:59	1.20		4.85		140.24		17.78		3.21		3.30
VMJH	09:29	2.10		5.03		141.53		16.82		3.24		3.25
VMJH	09:59	1.77		4.76		141.45		17.39		3.14		3.13
VMJH	10:29	0.57		5.16		141.68		16.55		3.29		3.34
VMJH	10:59	1.07		5.00		141.72		17.45		3.28		3.11
VMJH	11:29	1.57		5.00		143.42		17.04		3.28		3.12
VMJH	11:59	1.17		5.14		141.39		17.31		3.25		3.23
VMJH	12:29	0.97		4.87		142.22		16.97		3.33		3.21
VMJH	12:59	1.13		5.19		142.37		17.22		3.28		3.16
VMJH	13:29	1.33		4.94		141.57		16.74		3.29		3.17
VMJH	13:59	0.77		4.82		142.51		16.85		3.26		3.13
VMJH	14:29	1.23		4.84		141.57		17.35		3.35		3.18
VMJH	14:59	0.97		5.08		140.73		17.37		3.11		3.27
VMJH	15:29	0.63		5.07		141.20		17.79		3.28		3.15
VMJH	15:59	1.00		5.13		141.39		16.52		3.37		3.18
VMJH	16:29	1.17		5.03		141.86		17.67		3.19		3.12
VMJH	16:59	0.80		4.66		142.80		17.81		3.36		3.32
VMJH	17:29	1.20		5.26		140.68		16.89		3.32		3.13
VMJH	17:59	2.13		5.15		143.33		17.41		3.33		3.19
VMJH	18:29	1.77		4.86		141.88		17.22		3.32		3.19
VMJH	18:59	1.97		5.15		142.50		17.18		3.19		3.18
VMJH	19:29	1.60		5.24		140.33		17.42		3.23		3.08
VMJH	19:59	1.90		5.08		139.12		17.76		3.35		3.17
VMJH	20:29	2.57		5.06		141.08		16.91		3.26		3.04
VMJH	20:59	2.17		4.53		142.86		17.02		3.28		3.09
VMJH	21:29	2.93		5.05		142.12		17.34		3.23		3.15
VMJH	21:59	2.23		5.11		142.73		17.89		3.19		3.12
VMJH	22:24	3.24		4.92		143.95		16.90		3.38		3.25
VMZ		1.53		5.00		141.78		17.24		3.27		3.18



# Valori inregistrate MIR-IS HP-1500

Data:04/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	1.27	4.84	142.47	16.87	3.25	3.14				
VMJH	07:59	2.97	5.21	142.25	17.96	3.30	3.09				
VMJH	08:29	2.63	4.94	142.70	17.00	3.25	3.15				
VMJH	08:59	2.23	4.48	141.02	17.25	3.27	3.17				
VMJH	09:29	1.67	4.70	141.14	16.84	3.24	3.07				
VMJH	09:59	2.10	4.98	140.12	17.62	3.34	3.15				
VMJH	10:29	2.37	5.46	141.18	17.72	3.19	3.21				
VMJH	10:59	1.93	5.10	139.71	17.20	3.26	3.12				
VMJH	11:29	2.93	4.90	142.39	17.18	3.29	3.23				
VMJH	11:59	2.30	4.99	141.54	17.26	3.23	3.14				
VMJH	12:29	0.57	4.92	143.09	17.13	3.29	3.24				
VMJH	12:59	1.40	4.97	141.31	17.21	3.33	3.23				
VMJH	13:29	2.57	4.78	143.33	17.53	3.33	3.10				
VMJH	13:59	1.20	4.98	142.12	17.33	3.25	3.08				
VMJH	14:29	2.10	4.79	142.06	17.26	3.29	3.17				
VMJH	14:59	2.27	4.97	142.24	16.73	3.36	3.15				
VMJH	15:29	1.73	6.49	157.64	19.13	3.40	3.14				
VMJH	15:59	1.53	7.99	166.76	21.04	3.69	3.49				
VMJH	16:29	2.27	6.83	162.68	21.26	3.77	3.29				
VMJH	16:59	2.80	7.33	162.91	22.06	3.56	3.31				
VMJH	17:29	1.67	7.76	162.99	21.07	3.60	3.21				
VMJH	17:59	2.77	7.45	166.71	21.40	3.47	3.34				
VMJH	18:29	1.63	7.02	167.29	20.48	3.41	3.27				
VMJH	18:59	1.67	7.28	166.82	21.39	3.50	3.09				
VMJH	19:29	3.00	7.01	165.06	21.44	3.54	3.27				
VMJH	19:59	1.87	6.86	161.22	21.70	3.52	3.35				
VMJH	20:29	2.50	6.97	166.80	20.97	3.61	3.40				
VMJH	20:59	1.37	6.85	167.96	21.35	3.59	3.14				
VMJH	21:29	0.93	7.34	166.65	21.37	3.67	3.50				
VMJH	21:59	1.97	7.41	163.95	20.92	3.68	3.41				
VMJH	22:24	1.76	6.81	166.71	21.13	3.50	3.33				
VMZ		2.00	6.01	152.86	19.11	3.42	3.22				

# Valori inregistrate MIR-IS HP-1500

Data:05/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	2.03		7.32		167.77		21.89	3.55		3.26	
VMJH	07:59	1.57		6.92		166.09		21.60	3.57		3.43	
VMJH	08:29	0.80		7.40		165.84		21.08	3.63		3.30	
VMJH	08:59	1.87		6.62		164.46		21.44	3.59		3.27	
VMJH	09:29	2.80		7.72		165.28		21.27	3.53		3.29	
VMJH	09:59	1.20		7.32		164.83		19.92	3.46		3.33	
VMJH	10:29	2.27		6.82		167.09		21.21	3.58		3.42	
VMJH	10:59	2.57		7.23		167.91		19.29	3.50		3.44	
VMJH	11:29	1.83		7.34		161.78		20.56	3.75		3.41	
VMJH	11:59	2.90		7.12		164.92		20.95	3.52		3.37	
VMJH	12:29	1.77		6.79		163.08		21.52	3.68		3.29	
VMJH	12:59	1.93		6.86		167.62		21.21	3.70		3.44	
VMJH	13:29	2.63		7.66		166.90		20.79	3.65		3.23	
VMJH	13:59	1.83		7.61		168.05		22.18	3.72		3.38	
VMJH	14:29	0.53		6.55		161.64		21.43	3.50		3.45	
VMJH	14:59	0.53		7.11		166.23		20.92	3.59		3.32	
VMJH	15:29	0.63		7.00		164.35		21.38	3.63		3.24	
VMJH	15:59	0.67		6.97		166.71		21.19	3.68		3.33	
VMJH	16:29	1.20		7.10		167.90		21.80	3.57		3.39	
VMJH	16:59	0.83		6.78		164.02		20.80	3.53		3.23	
VMJH	17:29	0.60		7.08		165.80		21.38	3.49		3.39	
VMJH	17:59	0.73		6.78		163.74		21.30	3.55		3.02	
VMJH	18:29	0.77		6.86		165.00		21.13	3.66		3.40	
VMJH	18:59	0.63		6.83		164.98		20.94	3.71		3.26	
VMJH	19:29	0.90		6.87		162.92		21.63	3.50		3.38	
VMJH	19:59	0.67		7.40		166.85		20.22	3.67		3.01	
VMJH	20:29	0.77		6.87		163.65		22.07	3.82		3.50	
VMJH	20:59	1.07		6.90		164.60		21.13	3.73		3.34	
VMJH	21:29	0.93		7.36		166.17		21.04	3.62		3.28	
VMJH	21:59	1.77		7.07		163.01		20.70	3.53		3.37	
VMJH	22:29	0.90		7.06		164.99		20.79	3.69		3.38	
VMJH	22:36	1.57		7.76		161.54		21.75	3.89		3.72	
VMZ		1.36		7.08		165.27		21.13	3.61		3.33	



# Valori inregistrate MIR-IS HP-1500

Data:08/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.40	7.22	164.51	21.48	3.49	3.51					
VMJH	07:59	0.97	6.67	166.04	20.71	3.61	3.31					
VMJH	08:29	1.23	4.50	134.46	15.91	3.06	3.22					
VMJH	08:59	1.87	2.64	118.03	13.77	2.91	3.07					
VMJH	09:29	1.20	2.86	119.86	13.54	2.91	2.90					
VMJH	09:59	1.70	2.87	118.30	13.26	2.99	2.96					
VMJH	10:29	1.17	3.04	118.28	13.16	3.02	2.96					
VMJH	10:59	0.13	2.70	118.63	13.16	2.71	2.94					
VMJH	11:29	1.40	2.65	118.83	13.29	2.99	3.02					
VMJH	11:59	1.73	2.73	117.86	13.45	2.95	2.96					
VMJH	12:29	1.00	2.80	120.00	13.40	3.00	2.99					
VMJH	12:59	1.53	2.67	118.02	13.30	2.79	3.02					
VMJH	13:29	2.57	2.61	118.99	12.77	2.92	2.97					
VMJH	13:59	1.33	3.01	119.54	13.09	2.99	2.89					
VMJH	14:29	2.07	2.90	119.10	12.97	2.83	3.08					
VMJH	14:59	1.40	2.81	118.72	13.16	2.91	3.11					
VMJH	15:29	1.13	3.13	117.30	13.33	2.92	2.96					
VMJH	15:59	1.87	2.80	119.40	13.29	2.80	2.95					
VMJH	16:29	1.80	2.71	117.57	12.88	2.91	3.02					
VMJH	16:59	1.63	2.85	118.92	13.23	2.81	2.93					
VMJH	17:29	0.60	2.94	119.00	13.28	3.08	2.87					
VMJH	17:59	0.77	2.68	120.02	13.40	2.86	2.98					
VMJH	18:29	0.83	2.59	118.65	13.03	2.96	3.03					
VMJH	18:59	0.87	2.80	119.43	12.87	3.03	2.91					
VMJH	19:29	1.17	2.93	118.13	13.13	2.95	3.00					
VMJH	19:59	1.00	2.80	118.95	13.63	3.07	3.08					
VMJH	20:29	1.00	2.52	120.54	13.42	2.93	3.05					
VMJH	20:59	0.67	3.01	119.06	13.53	2.96	2.95					
VMJH	21:29	0.77	2.65	119.92	12.88	2.92	2.90					
VMJH	21:59	1.23	2.52	119.35	13.11	2.84	3.05					
VMJH	22:29	0.93	2.77	119.71	13.18	2.90	3.06					
VMJH	22:49	0.80	2.90	116.11	13.22	3.02	2.87					
VMZ		1.25	3.10	122.29	13.81	2.97	3.02					



# Valori inregistrate MIR-IS HP-1500

Data:09/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	0.93	2.92	118.85	13.61	2.72	2.94					
VMJH	07:59	1.50	2.91	117.76	13.35	2.94	3.00					
VMJH	08:29	1.60	2.72	117.80	13.65	3.00	3.05					
VMJH	08:59	2.30	2.71	118.55	13.36	2.87	2.97					
VMJH	09:29	1.57	2.67	118.44	13.47	3.05	2.99					
VMJH	09:59	1.17	2.89	119.26	13.53	2.99	3.02					
VMJH	10:29	2.47	2.89	119.63	13.06	3.08	2.91					
VMJH	10:59	2.27	2.88	119.27	13.15	2.95	3.00					
VMJH	11:29	1.17	3.03	118.92	13.57	2.98	3.01					
VMJH	11:59	1.70	2.77	119.13	13.26	2.99	3.00					
VMJH	12:29	1.37	2.63	117.60	13.23	3.01	2.96					
VMJH	12:59	2.17	2.64	119.04	13.31	2.86	2.99					
VMJH	13:29	1.73	2.73	118.42	12.46	3.07	2.94					
VMJH	13:59	1.20	2.89	118.67	13.25	2.89	2.95					
VMJH	14:29	2.40	2.74	120.12	13.60	2.98	3.00					
VMJH	14:59	0.93	2.70	121.49	12.94	3.02	3.10					
VMJH	15:29	1.70	2.82	118.32	12.90	3.03	2.95					
VMJH	15:59	2.03	2.78	118.47	13.87	3.06	2.93					
VMJH	16:29	1.57	3.40	119.96	14.57	3.21	2.92					
VMJH	16:59	2.10	4.64	121.74	15.55	3.20	3.00					
VMJH	17:29	1.80	4.63	121.85	15.80	2.88	2.90					
VMJH	17:59	1.63	4.54	120.90	15.95	2.82	2.96					
VMJH	18:29	1.47	4.60	120.68	15.01	3.06	2.85					
VMJH	18:59	1.50	4.58	122.54	15.77	2.95	2.98					
VMJH	19:29	1.53	4.53	119.70	15.06	2.98	2.91					
VMJH	19:59	0.87	4.57	120.73	15.28	2.83	2.95					
VMJH	20:29	1.23	4.49	120.63	14.77	2.82	3.00					
VMJH	20:59	1.30	4.57	120.58	15.47	3.12	2.98					
VMJH	21:29	1.17	4.50	119.74	14.71	3.08	2.89					
VMJH	21:59	0.93	4.50	123.33	16.24	3.14	2.97					
VMJH	22:29	0.90	4.47	119.76	15.35	2.96	3.04					
VMJH	22:47	0.94	4.71	122.53	15.35	3.18	2.84					
VMZ		1.54	3.52	119.79	14.19	2.99	2.97					

# Valori inregistrate MIR-IS HP-1500

Data:10/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.00		4.63		121.09		14.97		3.06		2.97	
VMJH	07:59	0.77		4.62		121.73		14.94		3.08		3.12	
VMJH	08:29	1.30		4.41		122.29		15.49		3.02		2.95	
VMJH	08:59	1.00		4.57		122.98		14.47		3.08		3.20	
VMJH	09:29	0.90		4.43		121.80		15.61		3.05		2.93	
VMJH	09:59	1.17		4.56		119.43		15.62		3.17		2.93	
VMJH	10:29	1.13		4.56		122.03		15.45		3.10		2.90	
VMJH	10:59	1.47		4.45		121.16		14.86		3.12		2.86	
VMJH	11:29	0.63		4.66		124.05		15.58		3.13		2.97	
VMJH	11:59	0.90		4.66		118.66		15.92		2.94		3.03	
VMJH	12:29	0.67		4.71		122.94		16.65		3.09		2.82	
VMJH	12:59	1.40		4.57		119.08		15.40		3.05		2.92	
VMJH	13:29	2.23		4.56		121.08		15.05		2.99		3.06	
VMJH	13:59	1.13		4.72		119.33		15.01		3.11		2.90	
VMJH	14:29	1.00		4.47		121.64		14.76		3.03		3.06	
VMJH	14:59	1.63		4.58		121.41		15.27		3.01		3.05	
VMJH	15:29	2.03		4.63		123.06		15.91		3.17		3.00	
VMJH	15:59	1.70		4.70		120.38		15.33		3.12		3.08	
VMJH	16:29	2.00		4.65		121.47		15.48		3.05		2.92	
VMJH	16:59	1.77		4.37		121.16		14.82		3.10		2.89	
VMJH	17:29	2.30		4.63		121.13		15.75		3.05		3.03	
VMJH	17:59	2.20		4.40		122.66		14.82		2.95		2.85	
VMJH	18:29	2.30		4.54		121.59		15.61		3.14		2.98	
VMJH	18:59	2.37		4.70		121.79		15.46		3.10		2.91	
VMJH	19:29	2.70		4.63		121.33		15.33		3.07		2.94	
VMJH	19:59	2.53		4.53		121.96		16.02		2.89		2.98	
VMJH	20:29	2.43		4.59		120.88		16.57		2.96		3.14	
VMJH	20:59	1.60		4.62		122.70		15.07		2.82		3.02	
VMJH	21:29	1.07		4.55		119.91		16.31		2.93		2.90	
VMJH	21:59	1.60		4.51		121.90		15.70		3.20		3.04	
VMJH	22:29	0.77		4.60		121.43		15.24		3.07		2.83	
VMJH	22:49	1.10		4.78		122.10		15.52		2.83		3.00	
VMZ		1.53		4.58		121.44		15.44		3.05		2.97	



# Valori inregistrate MIR-IS HP-1500

Data:11/05/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH	07:29	0.83	4.49	121.10	14.56	2.97	2.90
VMJH	07:59	1.10	4.59	120.34	15.07	2.95	3.05
VMJH	08:29	0.83	4.50	120.85	15.14	3.21	2.95
VMJH	08:59	1.03	6.07	146.02	18.29	4.10	3.39
VMJH	09:29	0.83	6.50	165.21	21.63	4.82	3.70
VMJH	09:59	1.43	7.25	164.23	20.72	4.79	3.69
VMJH	10:29	1.20	6.88	165.16	21.06	4.82	3.74
VMJH	10:59	0.90	7.23	167.20	21.79	4.79	3.70
VMJH	11:29	1.07	6.82	168.51	22.19	4.80	3.69
VMJH	11:59	1.10	6.94	168.45	21.39	4.86	3.77
VMJH	12:29	0.80	7.06	165.93	21.01	4.78	3.76
VMJH	12:59	1.00	6.95	166.56	21.37	4.83	3.79
VMJH	13:29	1.27	7.10	164.54	20.84	4.95	3.70
VMJH	13:59	1.80	6.62	166.95	20.69	4.81	3.72
VMJH	14:29	1.40	6.84	164.82	21.70	4.94	3.69
VMJH	14:59	1.67	7.09	166.40	21.01	4.76	3.69
VMJH	15:29	1.33	6.57	163.44	22.47	4.84	3.71
VMJH	15:59	1.33	7.15	166.06	21.34	4.72	3.75
VMJH	16:29	2.03	7.30	164.86	21.28	4.84	3.67
VMJH	16:59	1.07	7.15	166.01	19.85	4.93	3.59
VMJH	17:29	1.23	6.47	163.89	20.74	4.87	3.58
VMJH	17:59	1.43	7.28	165.68	21.01	4.90	3.66
VMJH	18:29	1.10	7.46	163.49	20.87	4.79	3.65
VMJH	18:59	1.20	7.16	165.39	20.87	4.78	3.73
VMJH	19:29	2.00	6.90	165.41	20.69	4.82	3.63
VMJH	19:59	0.83	7.06	163.90	21.92	4.75	3.72
VMJH	20:29	1.77	7.50	165.15	20.07	4.72	3.74
VMJH	20:59	1.17	7.03	163.27	21.77	4.90	3.80
VMJH	21:29	1.37	7.13	165.63	21.78	4.81	3.81
VMJH	21:59	1.60	6.46	169.55	20.93	4.80	3.78
VMJH	22:29	0.70	7.22	166.41	20.49	4.87	3.77
VMJH	22:49	1.35	6.67	161.39	22.42	4.84	3.86
VMZ		1.24	6.73	160.67	20.51	4.63	3.64



# Valori inregistrate MIR-IS HP-1500

Data:12/05/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.47	6.97	164.68	20.93	4.86	3.62
VMJH	07:59	1.40	6.07	164.77	21.18	4.81	3.59
VMJH	08:29	1.17	6.98	166.70	20.37	4.80	3.79
VMJH	08:59	2.63	7.16	162.66	20.95	4.81	3.79
VMJH	09:29	2.27	7.29	168.10	21.36	4.89	3.78
VMJH	09:59	2.47	6.98	163.97	20.72	4.91	3.72
VMJH	10:29	2.10	7.67	162.61	20.88	4.83	3.73
VMJH	10:59	2.40	7.64	164.46	21.27	4.96	3.75
VMJH	11:29	1.47	6.97	165.60	20.53	4.77	3.66
VMJH	11:59	1.60	7.63	164.10	21.70	4.73	3.71
VMJH	12:29	1.47	7.27	163.92	22.03	4.84	3.62
VMJH	12:59	0.80	6.62	165.58	22.25	4.87	3.76
VMJH	13:29	0.53	7.06	164.47	21.98	4.92	3.63
VMJH	13:59	1.17	7.35	164.79	21.06	4.80	3.76
VMJH	14:29	0.67	6.67	164.13	20.86	4.89	3.81
VMJH	14:59	0.63	7.44	164.86	21.92	4.95	3.67
VMJH	15:29	1.03	7.02	164.68	21.34	4.62	3.74
VMJH	15:59	0.73	7.05	164.81	22.30	4.96	3.69
VMJH	16:29	0.83	6.24	165.47	20.45	4.93	3.68
VMJH	16:59	1.07	6.81	160.70	21.18	4.44	3.46
VMJH	17:29	0.80	5.86	144.10	18.61	3.92	3.34
VMJH	17:59	0.60	6.12	143.75	18.66	3.96	3.36
VMJH	18:29	1.23	5.57	144.50	18.04	4.03	3.33
VMJH	18:59	0.93	5.88	142.54	18.98	4.05	3.42
VMJH	19:29	1.10	5.67	141.47	18.39	3.85	3.37
VMJH	19:59	1.20	5.76	142.14	18.10	3.95	3.37
VMJH	20:29	1.27	5.84	143.22	18.26	3.86	3.39
VMJH	20:59	1.03	5.87	141.80	18.69	3.88	3.33
VMJH	21:29	2.40	5.83	143.44	18.17	4.00	3.37
VMJH	21:59	0.57	6.09	143.04	17.66	3.94	3.37
VMJH	22:29	0.60	5.96	143.93	18.63	3.98	3.34
VMJH	22:40	0.73	6.33	145.97	18.90	3.95	3.30
VMZ		1.27	6.62	156.80	20.22	4.51	3.58

# Valori inregistrate MIR-IS HP-1500

Data:15/05/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	10:14	0.47	5.78	142.65	17.69	3.82	3.37
VMJH	10:44	0.73	5.83	142.86	18.25	3.77	3.37
VMJH	11:14	0.70	6.02	142.25	18.83	3.85	3.27
VMJH	11:44	0.57	5.91	142.44	18.59	3.86	3.33
VMJH	12:14	0.67	5.56	143.38	18.39	4.04	3.25
VMJH	12:44	0.77	5.78	141.55	17.56	3.93	3.35
VMJH	13:14	0.70	5.91	143.39	18.58	3.83	3.44
VMJH	13:44	0.70	5.66	144.13	18.37	3.82	3.39
VMJH	14:14	0.63	5.87	141.94	19.40	3.97	3.30
VMJH	14:44	0.63	5.82	142.23	18.74	3.94	3.34
VMJH	15:14	1.07	5.88	141.60	18.66	3.80	3.33
VMJH	15:44	0.43	6.17	144.40	18.45	3.85	3.34
VMJH	16:14	0.97	5.58	142.32	18.73	3.92	3.37
VMJH	16:44	0.93	5.61	142.71	18.45	3.91	3.28
VMJH	17:14	1.37	5.89	142.68	18.46	3.88	3.47
VMJH	17:44	0.67	5.87	141.06	18.46	3.95	3.42
VMJH	18:14	0.77	5.79	142.68	18.36	3.98	3.36
VMJH	18:44	1.40	5.94	143.09	17.75	3.96	3.39
VMJH	19:14	0.73	5.69	144.11	18.63	4.00	3.30
VMJH	19:44	1.60	5.59	143.01	18.85	3.87	3.34
VMJH	20:14	1.17	6.05	143.28	18.22	3.91	3.32
VMJH	20:44	1.07	6.04	141.53	18.08	4.03	3.36
VMJH	21:14	1.20	5.76	144.13	17.29	3.98	3.35
VMJH	21:44	1.60	5.80	142.42	18.47	3.92	3.35
VMJH	22:14	0.93	5.87	141.04	18.73	4.02	3.34
VMJH	22:44	0.90	5.95	143.55	18.03	3.82	3.35
VMJH	22:48	2.50	6.63	145.26	18.18	4.01	3.58
VMZ		0.91	5.84	142.72	18.38	3.91	3.35



# Valori inregistrate MIR-IS HP-1500

Data:16/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	0.47		5.63		143.41		18.76		3.93		3.37
VMJH	07:59	0.83		5.93		143.29		18.33		3.93		3.34
VMJH	08:29	0.20		6.19		143.13		18.64		3.96		3.30
VMJH	08:59	2.23		5.64		143.11		18.74		3.93		3.46
VMJH	09:29	1.70		6.18		143.02		19.04		3.96		3.32
VMJH	09:59	0.30		5.76		143.48		18.18		3.87		3.33
VMJH	10:29	0.90		5.76		143.33		18.74		3.84		3.47
VMJH	10:59	0.83		5.85		143.49		17.73		4.00		3.32
VMJH	11:29	0.47		5.68		140.80		18.87		3.90		3.37
VMJH	11:59	0.73		6.05		143.10		18.30		3.99		3.36
VMJH	12:29	0.90		4.52		129.20		16.54		3.12		2.90
VMJH	12:59	0.53		4.79		125.52		16.56		2.96		2.86
VMJH	13:29	1.27		4.45		125.51		16.22		2.80		2.88
VMJH	13:59	1.17		4.73		126.54		16.12		2.98		2.83
VMJH	14:29	0.50		4.62		126.07		16.64		2.68		2.95
VMJH	14:59	1.63		4.70		124.68		15.90		2.86		2.83
VMJH	15:29	1.70		4.62		126.47		16.88		2.94		2.82
VMJH	15:59	0.67		4.83		125.11		16.70		2.95		2.88
VMJH	16:29	2.07		4.53		125.79		16.84		2.75		2.81
VMJH	16:59	0.93		4.60		124.52		16.18		2.85		2.97
VMJH	17:29	1.83		4.52		126.69		16.76		2.84		2.91
VMJH	17:59	1.60		4.48		125.15		16.76		2.80		2.75
VMJH	18:29	1.03		4.60		125.27		16.66		2.73		2.88
VMJH	18:59	2.23		4.43		125.16		15.36		2.87		2.97
VMJH	19:29	1.97		4.50		124.75		16.88		2.88		2.88
VMJH	19:59	1.57		4.59		125.01		16.72		2.78		2.81
VMJH	20:29	2.00		4.70		125.62		16.70		2.81		2.85
VMJH	20:59	0.73		4.66		124.94		16.74		2.93		2.78
VMJH	21:29	0.90		4.55		124.61		16.49		2.56		2.86
VMJH	21:59	1.63		4.64		122.77		16.59		2.91		2.91
VMJH	22:29	0.83		4.66		124.81		16.21		2.79		2.80
VMJH	22:37	0.50		4.91		125.26		15.93		2.66		2.92
VMZ		1.17		5.01		131.05		17.14		3.19		3.02



# Valori inregistrate MIR-IS HP-1500

Data:17/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.57		4.57		125.07		16.25		2.96		2.71	
VMJH	07:59	0.53		4.66		125.01		16.45		2.87		2.86	
VMJH	08:29	0.73		4.69		124.34		16.48		2.71		2.84	
VMJH	08:59	0.87		4.53		123.98		16.56		2.64		2.89	
VMJH	09:29	0.50		4.73		125.33		17.08		2.96		2.87	
VMJH	09:59	0.67		4.44		124.23		16.81		2.62		2.94	
VMJH	10:29	0.77		4.77		124.81		16.43		2.96		2.81	
VMJH	10:59	0.77		4.65		124.74		15.99		2.92		2.94	
VMJH	11:29	0.73		4.62		124.28		16.77		2.81		2.95	
VMJH	11:59	0.80		4.67		124.35		16.20		2.86		2.76	
VMJH	12:29	1.03		4.71		125.18		16.58		2.74		2.78	
VMJH	12:59	0.73		4.60		124.29		16.21		2.59		2.82	
VMJH	13:29	0.83		4.57		125.66		16.16		2.82		2.77	
VMJH	13:59	1.63		4.69		125.34		16.67		2.84		2.89	
VMJH	14:29	0.93		4.50		125.29		16.27		2.74		2.87	
VMJH	14:59	1.00		4.59		124.17		16.19		2.74		3.03	
VMJH	15:29	1.17		4.46		124.27		16.27		2.88		2.80	
VMJH	15:59	0.67		4.70		125.24		17.05		2.83		2.84	
VMJH	16:29	0.97		4.37		125.28		16.51		2.81		2.88	
VMJH	16:59	1.13		4.56		124.39		16.87		2.93		2.98	
VMJH	17:29	1.57		4.56		124.33		15.17		2.84		2.94	
VMJH	17:59	1.57		4.70		123.90		16.83		2.82		2.84	
VMJH	18:29	1.03		4.57		126.19		17.12		2.74		2.97	
VMJH	18:59	1.43		4.49		124.76		16.55		2.90		2.96	
VMJH	19:29	1.27		4.48		125.51		16.24		2.72		2.82	
VMJH	19:59	1.67		4.50		122.97		16.97		2.84		2.81	
VMJH	20:29	1.33		4.78		127.05		16.46		2.88		2.92	
VMJH	20:59	1.60		6.16		166.71		21.09		4.31		3.68	
VMJH	21:29	0.57		6.39		166.13		20.41		4.35		3.80	
VMJH	21:59	0.80		5.74		164.68		20.71		4.30		3.82	
VMJH	22:29	0.67		6.54		162.41		20.88		4.32		3.87	
VMJH	22:36	0.71		5.32		167.48		22.74		4.41		3.71	
VMZ		0.98		4.81		130.31		17.09		3.02		3.00	

# Valori inregistrate MIR-IS HP-1500

Data:18/05/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	07:29	0.77	6.33	163.60	21.09	4.30	3.79
VMJH	07:59	0.70	6.31	166.94	21.36	4.33	3.77
VMJH	08:29	0.73	6.04	164.02	21.54	4.35	3.85
VMJH	08:59	0.83	6.58	166.46	20.32	4.28	3.84
VMJH	09:29	0.63	6.27	164.16	21.95	4.33	3.89
VMJH	09:59	1.03	6.90	167.66	20.69	4.36	3.96
VMJH	10:29	1.23	6.30	165.39	20.68	4.34	3.83
VMJH	10:59	0.90	6.22	165.80	20.81	4.32	3.67
VMJH	11:29	0.57	6.46	166.45	21.51	4.35	3.93
VMJH	11:59	0.67	6.36	167.13	21.40	4.34	3.83
VMJH	12:29	0.80	6.31	163.92	20.26	4.32	3.72
VMJH	12:59	0.83	6.31	165.71	19.47	4.36	3.85
VMJH	13:29	1.07	5.75	166.31	20.41	4.33	3.80
VMJH	13:59	0.70	6.60	164.55	22.99	4.36	3.86
VMJH	14:29	1.17	6.69	165.23	19.80	4.36	3.92
VMJH	14:59	0.90	6.00	167.16	21.06	4.36	3.90
VMJH	15:29	1.33	5.88	165.61	20.40	4.37	3.90
VMJH	15:59	0.80	6.33	166.39	20.94	4.34	3.89
VMJH	16:29	0.87	6.25	168.16	20.21	4.34	3.74
VMJH	16:59	0.97	6.53	165.01	20.68	4.34	3.78
VMJH	17:29	1.53	6.36	164.25	21.37	4.34	3.85
VMJH	17:59	1.37	6.10	165.19	21.17	4.34	3.77
VMJH	18:29	0.70	6.25	168.13	21.13	4.33	3.95
VMJH	18:59	1.13	6.33	164.81	21.12	4.37	3.75
VMJH	19:29	0.67	6.08	163.77	19.55	4.36	3.82
VMJH	19:59	1.00	6.32	165.83	20.63	4.32	3.85
VMJH	20:29	1.10	6.16	164.13	21.51	4.34	3.81
VMJH	20:59	1.13	6.18	164.66	21.36	4.35	3.79
VMJH	21:29	1.80	6.32	161.81	21.34	4.35	3.84
VMJH	21:59	2.03	6.39	163.27	20.43	4.32	3.81
VMJH	22:29	1.03	6.52	166.68	20.11	4.35	3.95
VMJH	22:48	1.26	6.08	165.80	21.41	4.31	3.89
VMZ		1.01	6.30	165.43	20.89	4.34	3.84



# Valori inregistrate MIR-IS HP-1500

Data:19/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	1.70	6.33	165.81	20.92	4.35	3.74				
VMJH	07:59	0.63	5.97	165.97	21.61	4.34	3.80				
VMJH	08:29	1.63	5.72	162.00	20.54	4.30	3.81				
VMJH	08:59	1.20	6.05	166.36	21.28	4.34	3.90				
VMJH	09:29	0.50	6.44	165.19	21.33	4.33	3.89				
VMJH	09:59	2.93	6.09	167.28	21.37	4.33	3.84				
VMJH	10:29	1.50	6.78	167.06	20.55	4.33	3.92				
VMJH	10:59	0.97	5.48	165.51	21.32	4.34	3.92				
VMJH	11:29	0.87	6.16	162.94	21.08	4.36	3.81				
VMJH	11:59	1.03	6.51	167.53	20.06	4.31	3.88				
VMJH	12:29	0.80	6.83	165.49	20.83	4.35	3.89				
VMJH	12:59	1.83	5.78	166.12	20.62	4.33	3.87				
VMJH	13:29	1.37	5.47	146.81	19.05	3.59	3.44				
VMJH	13:59	0.30	5.63	147.21	18.58	3.57	3.25				
VMJH	14:29	1.17	5.40	146.66	18.80	3.57	3.41				
VMJH	14:59	1.03	5.34	144.60	18.81	3.54	3.34				
VMJH	15:29	1.37	5.48	145.66	18.88	3.55	3.42				
VMJH	15:59	0.80	5.61	145.96	19.12	3.63	3.38				
VMJH	16:29	1.17	5.54	144.14	18.45	3.61	3.36				
VMJH	16:59	1.50	5.52	144.60	19.17	3.55	3.34				
VMJH	17:29	1.90	5.35	143.58	18.62	3.64	3.40				
VMJH	17:59	2.03	5.21	144.90	19.55	3.57	3.32				
VMJH	18:29	0.93	5.43	146.04	19.07	3.60	3.32				
VMJH	18:59	1.60	5.48	145.51	18.99	3.63	3.31				
VMJH	19:29	1.33	5.18	145.71	19.36	3.59	3.33				
VMJH	19:59	1.57	5.11	142.64	18.50	3.54	3.37				
VMJH	20:29	1.90	5.36	145.79	18.39	3.54	3.37				
VMJH	20:59	1.40	5.37	144.75	18.56	3.53	3.37				
VMJH	21:29	0.93	5.43	145.00	18.68	3.55	3.34				
VMJH	21:59	1.67	5.48	145.62	18.98	3.59	3.29				
VMJH	22:29	1.33	5.41	145.62	18.69	3.55	3.39				
VMJH	22:40	2.00	5.38	145.14	18.78	3.49	3.32				
VMZ		1.33	5.70	153.06	19.66	3.86	3.55				



# Valori inregistrate MIR-IS HP-1500

Data:20/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3		
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH		
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	0.47	5.32	147.62	18.53	3.56	3.38				
VMJH	07:59	1.20	5.49	146.15	18.45	3.58	3.35				
VMJH	08:29	1.53	5.28	143.10	19.12	3.48	3.42				
VMJH	08:59	0.87	5.23	144.51	19.13	3.59	3.39				
VMJH	09:29	1.30	5.71	147.54	18.51	3.55	3.34				
VMJH	09:59	0.83	5.59	145.10	19.27	3.60	3.33				
VMJH	10:29	1.47	5.28	144.32	18.87	3.52	3.40				
VMJH	10:59	1.77	5.51	145.86	18.90	3.54	3.31				
VMJH	11:29	0.53	5.50	145.68	19.10	3.58	3.39				
VMJH	11:59	2.13	5.53	144.82	18.44	3.61	3.37				
VMJH	12:29	0.93	5.51	144.55	19.02	3.57	3.43				
VMJH	12:59	1.27	5.40	145.06	17.90	3.55	3.33				
VMJH	13:29	0.97	5.48	145.54	18.47	3.55	3.27				
VMJH	13:48	0.89	5.62	145.00	19.36	3.65	3.35				
VMZ		1.16	5.46	145.36	18.77	3.56	3.36				

# Valori inregistrate MIR-IS HP-1500

Data:22/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	11:29	0.93	5.41	144.58	18.73	3.53	3.36				
VMJH	11:59	0.87	5.18	146.96	18.67	3.56	3.33				
VMJH	12:29	0.80	5.29	144.96	18.79	3.59	3.30				
VMJH	12:59	1.27	5.08	143.61	18.63	3.53	3.39				
VMJH	13:29	0.37	5.40	144.85	18.95	3.55	3.45				
VMJH	13:59	1.30	5.62	144.95	19.04	3.50	3.33				
VMJH	14:29	1.33	5.32	144.52	18.22	3.58	3.39				
VMJH	14:59	0.83	5.45	144.56	18.38	3.61	3.43				
VMJH	15:29	1.40	5.47	146.28	19.00	3.63	3.31				
VMJH	15:59	1.37	5.25	145.18	18.63	3.62	3.28				
VMJH	16:29	1.77	5.60	143.31	18.92	3.60	3.36				
VMJH	16:59	1.10	5.46	143.94	18.77	3.63	3.47				
VMJH	17:29	1.20	5.25	144.17	18.63	3.51	3.45				
VMJH	17:59	1.27	5.51	145.35	17.92	3.61	3.34				
VMJH	18:29	1.33	5.63	143.21	18.98	3.55	3.30				
VMJH	18:59	1.47	4.23	146.84	17.64	3.71	3.25				
VMJH	19:29	1.10	4.71	155.01	17.40	4.40	3.52				
VMJH	19:59	0.63	4.97	165.31	18.98	5.03	3.69				
VMJH	20:29	0.20	4.97	162.07	18.70	4.93	3.54				
VMJH	20:59	0.73	4.91	164.52	18.73	5.04	3.74				
VMJH	21:29	0.87	4.97	165.68	19.10	5.14	3.65				
VMJH	21:59	0.90	5.03	166.49	18.74	4.99	3.71				
VMJH	22:24	0.64	4.94	166.61	18.67	5.03	3.62				
VMZ		1.03	5.20	150.45	18.62	3.99	3.44				

# Valori inregistrate MIR-IS HP-1500

Data:23/05/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.20	5.14	165.34	19.23	5.12	3.65
VMJH	07:59	1.60	4.93	163.61	19.13	4.99	3.64
VMJH	08:29	2.40	4.97	163.80	18.94	5.08	3.59
VMJH	08:59	2.70	5.04	165.95	18.59	5.06	3.65
VMJH	09:29	2.13	5.07	163.40	18.85	5.14	3.66
VMJH	09:59	2.57	5.10	164.79	18.34	5.08	3.68
VMJH	10:29	3.43	5.19	165.17	19.00	5.13	3.69
VMJH	10:59	2.63	5.12	166.26	19.07	5.07	3.65
VMJH	11:29	3.10	4.90	164.96	19.50	5.17	3.63
VMJH	11:59	2.80	5.06	164.96	18.78	5.10	3.69
VMJH	12:29	2.50	5.02	164.42	19.00	5.07	3.62
VMJH	12:59	2.90	5.10	165.98	18.49	5.20	3.62
VMJH	13:29	3.43	5.15	163.87	18.70	5.09	3.58
VMJH	13:59	2.17	5.16	163.84	18.98	5.06	3.72
VMJH	14:29	1.40	4.78	163.84	19.04	4.94	3.63
VMJH	14:59	1.20	4.99	164.83	18.43	5.03	3.65
VMJH	15:29	1.00	4.91	166.04	18.22	5.03	3.63
VMJH	15:59	2.93	5.08	166.01	19.25	5.08	3.60
VMJH	16:29	2.53	5.07	166.12	18.57	5.09	3.66
VMJH	16:59	3.13	4.93	163.11	18.95	4.98	3.65
VMJH	17:29	2.23	4.86	165.62	18.99	5.11	3.62
VMJH	17:59	2.57	5.21	162.40	18.70	5.02	3.65
VMJH	18:29	2.27	5.05	163.94	19.14	5.17	3.83
VMJH	18:59	2.63	5.15	164.36	19.28	5.06	3.64
VMJH	19:29	2.70	5.18	164.36	18.76	4.95	3.65
VMJH	19:59	1.57	5.02	164.97	19.04	4.98	3.80
VMJH	20:29	2.57	5.05	161.71	18.37	5.05	3.56
VMJH	20:59	3.10	5.01	165.00	18.85	5.05	3.67
VMJH	21:29	2.20	4.93	163.87	18.65	5.11	3.71
VMJH	21:59	2.43	5.07	166.22	18.82	5.12	3.63
VMJH	22:12	2.23	5.04	163.06	18.96	4.83	3.57
VMZ		2.40	5.04	164.60	18.86	5.07	3.65



# Valori inregistrate MIR-IS HP-1500

Data:24/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	2.63		5.25		164.44		18.69		4.99		3.70
VMJH	07:59	2.47		4.96		162.45		17.96		5.02		3.56
VMJH	08:29	2.80		4.96		161.89		19.20		5.02		3.63
VMJH	08:59	2.87		4.94		164.28		18.72		5.08		3.67
VMJH	09:29	2.53		5.12		164.82		19.23		5.07		3.65
VMJH	09:59	2.80		4.97		165.05		18.82		5.06		3.65
VMJH	10:29	1.93		4.99		162.88		19.19		5.10		3.59
VMJH	10:59	1.77		5.03		164.22		18.53		5.07		3.64
VMJH	11:29	2.53		4.85		163.11		18.73		5.20		3.69
VMJH	11:59	2.43		4.99		165.47		18.56		5.01		3.66
VMJH	12:29	1.63		4.86		161.85		19.03		4.92		3.68
VMJH	12:59	2.20		3.76		133.97		16.09		2.98		2.96
VMJH	13:29	1.97		3.23		125.30		15.38		2.56		2.89
VMJH	13:59	2.60		3.30		125.91		15.68		2.47		2.84
VMJH	14:29	2.83		3.31		126.20		15.06		2.52		2.77
VMJH	14:59	2.13		3.17		127.88		15.10		2.56		2.77
VMJH	15:29	2.47		3.21		126.40		15.40		2.55		2.76
VMJH	15:59	2.10		3.35		125.09		14.39		2.46		2.81
VMJH	16:29	2.67		3.32		125.89		15.02		2.47		2.90
VMJH	16:59	2.83		3.20		126.20		15.59		2.48		2.85
VMJH	17:29	2.23		3.13		126.88		15.47		2.50		2.86
VMJH	17:59	2.10		3.28		126.48		14.99		2.47		2.81
VMJH	18:29	2.30		3.04		126.13		15.02		2.54		2.78
VMJH	18:59	1.97		3.42		125.38		15.48		2.45		2.73
VMJH	19:29	1.60		3.06		126.52		15.15		2.44		2.83
VMJH	19:59	1.20		3.29		126.26		14.87		2.55		2.82
VMJH	20:29	0.73		3.07		125.54		14.65		2.39		2.82
VMJH	20:59	2.37		3.20		126.70		15.16		2.51		2.84
VMJH	21:29	2.60		3.32		125.98		15.74		2.52		2.90
VMJH	22:00	3.13		3.17		127.15		15.35		2.51		2.76
VMZ		2.28		3.89		140.20		16.54		3.45		3.13

# Valori inregistrate MIR-IS HP-1500

Data:24/05/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	3.10		3.27		127.07		15.49	2.55		2.77	
VMJH	07:59	2.60		3.21		127.19		15.26	2.49		2.81	
VMJH	08:29	4.93		3.23		126.82		14.91	2.52		2.81	
VMJH	08:59	4.07		3.12		126.59		15.54	2.52		2.78	
VMJH	09:29	2.23		3.27		126.06		15.03	2.42		2.88	
VMJH	09:59	2.40		3.22		126.94		14.78	2.45		2.83	
VMJH	10:29	1.93		3.34		125.93		15.44	2.50		2.81	
VMJH	10:59	2.00		2.95		126.23		14.37	2.53		2.77	
VMJH	11:29	2.37		3.07		126.83		14.69	2.53		2.91	
VMJH	11:59	2.17		3.28		126.42		15.23	2.48		2.87	
VMJH	12:29	3.37		3.38		126.57		14.42	2.34		2.79	
VMJH	12:59	3.07		3.21		125.75		14.54	2.53		2.86	
VMJH	13:29	2.93		2.98		127.68		15.04	2.56		2.81	
VMJH	13:59	2.67		3.08		127.79		15.64	2.52		2.87	
VMJH	14:29	3.00		3.39		125.80		15.42	2.57		2.82	
VMJH	14:59	3.20		3.09		127.15		15.37	2.53		2.85	
VMJH	15:29	2.90		3.16		125.87		15.66	2.53		2.75	
VMJH	15:59	3.50		3.27		127.00		14.71	2.44		2.88	
VMJH	16:29	3.07		3.17		126.34		15.16	2.50		2.83	
VMJH	16:59	2.77		3.34		126.86		15.26	2.48		2.78	
VMJH	17:29	2.90		3.27		127.14		15.69	2.40		2.88	
VMJH	17:59	2.87		3.16		126.38		15.61	2.49		2.86	
VMJH	18:29	2.23		3.24		127.76		13.88	2.50		2.78	
VMJH	18:59	2.20		3.23		126.46		15.34	2.58		2.82	
VMJH	19:29	2.33		3.24		126.22		14.32	2.66		2.88	
VMJH	19:59	1.90		3.15		126.08		14.98	2.53		2.80	
VMJH	20:29	2.07		3.12		126.00		15.34	2.55		2.75	
VMJH	20:59	1.17		3.31		126.88		14.92	2.53		2.80	
VMJH	21:29	1.93		3.22		126.51		14.48	2.57		2.77	
VMJH	21:59	0.93		3.39		129.08		14.76	2.48		2.79	
VMJH	22:29	1.67		3.27		130.31		14.43	2.50		2.72	
VMJH	22:36	0.00		3.10		131.37		15.52	2.59		2.58	
VMZ		2.57		3.21		126.87		15.03	2.51		2.82	



# Valori inregistrate MIR-IS HP-1500

Data:26/05/2023

	Ora	Pulberi mg/Nm <sup>2</sup>		SO <sub>2</sub> L1 mg/Nm <sup>3</sup>		NO <sub>x</sub> L1 mg/Nm <sup>3</sup>		CO L1 mg/Nm <sup>3</sup>		COT L1 mg/Nm <sup>3</sup>		HCL L1 mg/Nm <sup>3</sup>	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.97		3.34		131.34		15.96		2.56		2.81	
VMJH	07:59	1.67		3.81		131.14		15.53		2.53		2.79	
VMJH	08:29	1.53		3.36		131.85		15.22		2.53		2.84	
VMJH	08:59	0.63		3.50		129.87		15.06		2.53		2.71	
VMJH	09:29	1.77		3.46		130.59		14.98		2.55		2.78	
VMJH	09:59	0.63		3.23		129.05		15.74		2.53		2.88	
VMJH	10:29	1.77		3.51		131.74		15.46		2.49		2.80	
VMJH	10:59	2.10		3.52		132.44		14.60		2.49		2.85	
VMJH	11:29	2.07		3.68		131.33		14.81		2.52		2.73	
VMJH	11:59	1.27		3.53		132.05		14.82		2.47		2.77	
VMJH	12:29	2.07		3.61		129.38		15.04		2.55		2.75	
VMJH	12:59	2.13		3.64		128.74		15.23		2.47		2.83	
VMJH	13:29	1.43		3.49		131.08		14.59		2.41		2.75	
VMJH	13:59	0.57		3.63		131.01		15.32		2.50		2.83	
VMJH	14:29	1.47		3.62		130.54		14.34		2.45		2.84	
VMJH	14:59	0.83		3.69		130.75		15.01		2.48		2.83	
VMJH	15:29	1.77		3.66		131.06		15.88		2.48		2.78	
VMJH	15:59	1.87		3.59		129.77		15.81		2.50		2.85	
VMJH	16:29	0.90		3.61		129.32		15.60		2.57		2.90	
VMJH	16:59	1.73		3.47		130.39		16.10		2.54		2.83	
VMJH	17:29	1.53		3.70		129.80		15.01		2.54		2.82	
VMJH	17:59	1.63		3.34		130.68		15.41		2.46		2.80	
VMJH	18:29	1.57		3.51		132.06		14.82		2.57		2.88	
VMJH	18:59	1.40		3.67		130.91		15.44		2.58		2.77	
VMJH	19:29	0.90		3.89		131.57		15.48		2.46		2.81	
VMJH	19:59	1.23		3.59		131.51		15.28		2.53		2.84	
VMJH	20:29	1.30		3.75		129.34		14.89		2.48		2.79	
VMJH	20:59	1.73		3.49		130.37		16.11		2.53		2.78	
VMJH	21:29	1.03		3.58		130.53		14.88		2.50		2.80	
VMJH	21:59	1.90		3.47		131.54		14.86		2.50		2.77	
VMJH	22:12	0.31		3.93		132.15		14.56		2.45		2.91	
VMZ		1.46		3.57		130.75		15.23		2.51		2.81	



# Valori inregistrate MIR-IS HP-1500

Data:29/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3		
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH		
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	11:09	0.87	3.66	132.47	15.09	2.50	2.76				
VMJH	11:39	1.67	3.87	131.88	15.53	2.49	2.81				
VMJH	12:09	1.17	3.42	130.45	15.30	2.43	2.80				
VMJH	12:39	0.47	3.61	131.13	15.13	2.54	2.78				
VMJH	13:09	1.03	3.75	130.47	14.99	2.55	2.80				
VMJH	13:39	0.60	3.59	131.21	14.69	2.56	2.79				
VMJH	14:09	1.17	3.46	130.38	15.03	2.55	2.80				
VMJH	14:39	0.90	3.76	130.36	14.96	2.55	2.93				
VMJH	15:09	1.27	3.63	131.58	14.97	2.51	2.80				
VMJH	15:39	1.03	3.29	129.32	15.13	2.53	2.67				
VMJH	16:09	1.70	3.54	133.06	14.69	2.55	2.82				
VMJH	16:39	1.50	3.86	129.74	15.80	2.64	2.88				
VMJH	17:09	2.27	3.84	131.28	14.49	2.48	2.89				
VMJH	17:39	1.40	3.50	131.25	15.26	2.52	2.86				
VMJH	18:09	1.47	3.44	130.37	15.11	2.60	2.88				
VMJH	18:39	2.10	4.90	147.30	17.52	3.88	3.15				
VMJH	19:09	1.27	5.82	163.91	18.39	5.11	3.64				
VMJH	19:39	2.17	6.06	165.99	18.47	5.02	3.71				
VMJH	20:09	1.20	5.98	165.62	18.62	5.02	3.61				
VMJH	20:39	1.07	6.01	169.74	18.55	4.99	3.63				
VMJH	21:09	2.13	6.02	167.10	18.71	5.14	3.70				
VMJH	21:39	1.07	6.29	167.70	18.39	4.96	3.76				
VMJH	22:09	0.97	6.10	165.46	18.44	5.07	3.72				
VMJH	22:39	2.67	6.41	167.44	18.45	5.19	3.77				
VMJH	23:09	1.10	6.42	166.65	19.42	5.17	3.65				
VMJH	23:34	1.32	5.83	165.77	17.98	5.17	3.59				
VMZ		1.37	4.61	145.17	16.50	3.56	3.16				

# Valori inregistrate MIR-IS HP-1500

Data:30/05/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.67	5.74	168.74	18.56	5.20	3.68					
VMJH	07:59	1.77	6.38	167.54	19.14	5.19	3.75					
VMJH	08:29	1.40	6.20	165.55	18.83	5.11	3.62					
VMJH	08:59	1.03	6.09	163.58	19.24	5.10	3.62					
VMJH	09:29	1.40	5.68	163.81	18.80	5.02	3.65					
VMJH	09:59	1.37	6.26	165.52	18.72	5.06	3.66					
VMJH	10:29	1.73	5.95	165.56	18.63	5.10	3.57					
VMJH	10:59	1.10	6.15	165.42	18.80	5.16	3.70					
VMJH	11:29	1.20	6.11	164.57	19.20	4.87	3.64					
VMJH	11:59	1.07	6.42	168.26	18.67	5.17	3.67					
VMJH	12:29	1.53	5.65	165.21	18.81	5.11	3.79					
VMJH	12:59	0.83	6.37	165.56	18.95	5.05	3.63					
VMJH	13:29	1.43	6.23	167.83	18.89	5.00	3.65					
VMJH	13:59	1.93	6.07	164.93	18.97	5.03	3.76					
VMJH	14:29	1.57	6.07	169.72	18.60	4.97	3.60					
VMJH	14:59	0.87	6.03	168.65	18.49	5.19	3.77					
VMJH	15:29	0.67	6.33	164.76	18.24	5.04	3.67					
VMJH	15:59	2.10	6.30	165.86	19.36	5.06	3.63					
VMJH	16:29	1.10	6.34	164.28	18.95	4.96	3.67					
VMJH	16:59	1.83	5.90	166.72	18.45	5.01	3.69					
VMJH	17:29	1.80	6.12	166.20	18.98	5.12	3.62					
VMJH	17:59	1.70	5.94	167.31	19.01	4.98	3.75					
VMJH	18:29	2.20	6.13	165.13	18.63	5.07	3.66					
VMJH	18:59	2.47	6.19	167.34	19.60	5.17	3.76					
VMJH	19:29	2.10	6.19	167.22	19.09	5.22	3.53					
VMJH	19:59	1.77	6.24	163.51	18.94	5.00	3.71					
VMJH	20:29	1.17	6.21	165.62	18.76	5.13	3.58					
VMJH	20:59	2.10	6.40	166.63	19.18	5.10	3.61					
VMJH	21:29	1.67	6.02	167.08	18.65	4.97	3.64					
VMJH	21:59	1.93	5.99	164.08	18.82	5.15	3.71					
VMJH	22:29	1.57	6.41	165.57	19.02	4.97	3.67					
VMJH	22:41	1.08	6.34	170.16	20.33	5.15	3.64					
VMZ		1.54	6.14	166.11	18.89	5.07	3.67					

# Valori inregistrate MIR-IS HP-1500

Data:31/05/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	10:29	0.93	6.01	166.55	18.57	5.12	3.62
VMJH	10:59	1.10	5.91	165.04	18.66	5.14	3.76
VMJH	11:29	1.20	6.10	167.61	18.49	5.23	3.60
VMJH	11:59	1.10	5.77	167.19	18.76	5.08	3.62
VMJH	12:29	1.10	5.97	163.36	18.75	5.19	3.68
VMJH	12:59	0.97	6.60	166.20	19.43	5.09	3.69
VMJH	13:29	1.53	5.26	153.55	17.55	4.14	3.30
VMJH	13:59	0.93	4.86	146.49	17.03	3.77	3.28
VMJH	14:29	1.63	4.91	146.11	16.90	3.75	3.26
VMJH	14:59	1.37	4.84	148.50	16.97	3.78	3.24
VMJH	15:29	2.27	4.68	148.05	16.79	3.77	3.19
VMJH	15:59	2.10	4.99	148.29	17.02	3.69	3.31
VMJH	16:29	0.70	4.83	148.05	16.85	3.78	3.28
VMJH	16:59	2.30	4.70	147.50	17.23	3.81	3.22
VMJH	17:29	2.27	4.72	147.68	17.14	3.73	3.27
VMJH	17:59	1.03	4.84	146.91	16.92	3.76	3.16
VMJH	18:29	2.17	4.43	148.91	16.68	3.83	3.30
VMJH	18:59	1.20	4.87	147.12	17.22	3.75	3.18
VMJH	19:29	2.07	4.53	148.57	16.64	3.88	3.21
VMJH	19:59	0.63	4.82	148.33	16.92	3.77	3.32
VMJH	20:29	1.77	4.77	150.23	17.44	3.78	3.18
VMJH	20:59	1.63	4.71	148.64	17.29	3.75	3.17
VMJH	21:29	0.77	4.68	147.16	17.01	3.87	3.25
VMJH	21:59	1.43	4.94	148.09	16.91	3.73	3.18
VMJH	22:32	0.52	4.81	146.54	16.55	3.80	3.20
VMZ		1.39	5.10	152.40	17.43	4.12	3.34



# Valori inregistrate MIR-IS HP-1500

Data:01/06/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	14:51	2.57	2.90	145.15	17.39	3.06	3.44
VMJH	15:21	2.30	2.80	144.40	17.44	3.28	3.39
VMJH	15:51	1.00	2.89	145.08	17.60	3.18	3.38
VMJH	16:21	2.33	2.92	145.52	17.43	3.17	3.35
VMJH	16:51	2.20	2.82	144.36	17.40	3.14	3.35
VMJH	17:21	2.47	2.83	145.37	18.22	3.17	3.34
VMJH	17:51	2.00	2.80	145.56	17.70	3.21	3.20
VMJH	18:21	1.67	2.82	145.20	17.52	3.33	3.30
VMJH	18:51	1.93	2.85	144.77	18.42	3.20	3.34
VMJH	19:21	1.30	2.94	145.89	17.63	3.18	3.40
VMJH	19:51	1.67	2.78	143.68	18.51	3.21	3.42
VMJH	20:21	0.73	2.84	144.46	18.07	3.15	3.39
VMJH	20:51	1.83	2.79	145.81	18.45	3.14	3.25
VMJH	21:21	1.67	2.83	146.12	17.61	3.21	3.29
VMJH	21:51	1.43	2.82	143.87	19.19	3.18	3.36
VMJH	22:20	0.62	2.79	143.20	17.71	3.15	3.28
VMZ		1.73	2.84	144.91	17.89	3.18	3.34

# Valori inregistrate MIR-IS HP-1500

Data:02/06/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	2.47	2.84	145.75	17.88	3.15	3.32					
VMJH	07:59	0.83	2.80	146.59	17.55	3.11	3.11					
VMJH	08:29	0.90	2.85	144.82	17.82	3.31	3.30					
VMJH	08:59	1.03	2.78	145.02	17.89	3.08	3.36					
VMJH	09:29	2.07	3.89	148.24	18.22	3.49	3.26					
VMJH	09:59	1.20	5.02	151.59	18.09	3.67	3.30					
VMJH	10:29	0.77	4.81	152.01	18.38	3.75	3.26					
VMJH	10:59	1.33	4.98	151.11	18.40	3.77	3.28					
VMJH	11:29	1.07	5.00	152.09	17.95	3.72	3.25					
VMJH	11:59	1.33	4.75	149.79	17.79	3.62	3.27					
VMJH	12:29	1.90	5.01	150.79	17.93	3.64	3.23					
VMJH	12:59	1.10	4.64	151.80	18.60	3.65	3.24					
VMJH	13:29	1.63	4.94	150.69	18.59	3.57	3.23					
VMJH	13:59	1.73	4.96	149.13	18.91	3.60	3.30					
VMJH	14:29	0.93	4.81	150.75	17.95	3.67	3.25					
VMJH	14:59	1.77	4.88	150.86	17.87	3.62	3.31					
VMJH	15:29	1.30	4.69	151.55	18.06	3.67	3.24					
VMJH	15:42	1.92	4.75	150.47	17.73	3.71	3.24					
VMZ		1.39	4.34	149.59	18.10	3.54	3.26					

# Valori inregistrate MIR-IS HP-1500

Data:06/06/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		<b>10 30/10</b>	<b>50 200/50</b>	<b>100 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>
VMJH	16:19	1.40	4.86	152.07	17.99	3.69	3.24
VMJH	16:49	1.70	5.14	152.31	18.28	3.62	3.21
VMJH	17:19	1.27	5.09	153.13	18.46	3.69	3.36
VMJH	17:49	1.17	4.70	153.17	17.39	3.68	3.15
VMJH	18:19	1.53	4.96	152.14	17.95	3.72	3.25
VMJH	18:49	1.53	5.05	152.93	18.65	3.67	3.29
VMJH	19:19	0.87	4.69	152.27	17.91	3.71	3.34
VMJH	19:49	1.40	4.77	151.62	18.06	3.63	3.23
VMJH	20:19	1.67	4.96	151.89	18.09	3.67	3.20
VMJH	20:49	1.63	4.98	152.27	18.46	3.58	3.23
VMJH	21:19	1.73	4.64	151.96	18.36	3.59	3.21
VMJH	21:49	1.83	5.21	151.73	18.30	3.67	3.25
VMJH	22:19	1.50	4.89	151.34	18.06	3.73	3.15
VMJH	22:32	2.15	5.00	151.42	17.79	3.70	3.19
VMZ		1.50	4.92	152.19	18.14	3.67	3.24



# Valori inregistrate MIR-IS HP-1500

Data:07/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	1.13		4.87		150.88		18.89		3.58		3.30
VMJH	07:59	0.97		5.06		152.23		18.15		3.65		3.24
VMJH	08:29	1.23		4.95		151.67		18.30		3.76		3.21
VMJH	08:59	1.57		5.08		152.14		18.40		3.55		3.22
VMJH	09:29	1.27		4.90		152.37		17.84		3.72		3.19
VMJH	09:59	1.37		4.65		151.09		18.31		3.68		3.21
VMJH	10:29	2.37		4.85		151.03		18.56		3.58		3.23
VMJH	10:59	1.57		4.75		151.50		17.99		3.72		3.27
VMJH	11:29	1.73		4.63		149.71		18.40		3.74		3.20
VMJH	11:59	0.90		4.94		151.48		18.24		3.77		3.23
VMJH	12:29	1.07		4.81		151.31		18.24		3.70		3.21
VMJH	12:59	1.23		4.87		151.49		18.40		3.78		3.15
VMJH	13:29	0.90		4.87		152.83		17.96		3.77		3.28
VMJH	13:59	1.60		4.74		151.62		18.18		3.72		3.22
VMJH	14:29	1.13		4.70		152.77		17.46		3.66		3.23
VMJH	14:59	1.13		4.75		150.36		17.67		3.57		3.29
VMJH	15:29	0.67		4.96		150.42		18.53		3.73		3.23
VMJH	15:59	1.03		4.81		151.54		18.17		3.70		3.23
VMJH	16:29	1.20		4.89		152.52		18.39		3.61		3.26
VMJH	16:59	1.30		5.05		150.85		17.88		3.78		3.30
VMJH	17:29	1.43		4.75		151.01		18.17		3.64		3.26
VMJH	17:59	1.10		5.54		156.64		19.03		3.88		3.59
VMJH	18:29	2.03		6.52		165.84		21.12		4.42		3.64
VMJH	18:59	1.60		6.13		165.06		20.95		4.21		3.75
VMJH	19:29	0.80		6.15		163.36		20.47		4.40		3.69
VMJH	19:59	1.27		6.25		167.94		20.72		4.25		3.61
VMJH	20:29	1.23		6.10		165.52		20.78		4.30		3.74
VMJH	20:59	0.93		6.28		164.23		20.90		4.38		3.58
VMJH	21:29	1.00		6.24		165.79		20.79		4.29		3.68
VMJH	21:59	1.03		6.02		165.07		20.89		4.19		3.67
VMJH	22:29	1.07		6.32		168.01		20.93		4.35		3.56
VMJH	22:38	0.67		6.01		162.15		21.22		4.20		3.67
VMZ		1.25		5.28		155.82		19.01		3.88		3.37

# Valori inregistrate MIR-IS HP-1500

Data:08/06/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.17	6.07	164.23	20.38	4.33	3.64
VMJH	07:59	0.60	6.11	167.72	20.72	4.32	3.56
VMJH	08:29	0.87	6.30	164.88	21.32	4.40	3.73
VMJH	08:59	0.90	5.98	167.73	20.41	4.38	3.70
VMJH	09:29	0.53	6.00	161.79	20.79	4.43	3.71
VMJH	09:59	0.87	6.03	164.40	19.99	4.39	3.70
VMJH	10:29	1.03	6.60	164.30	20.79	4.45	3.69
VMJH	10:59	1.47	6.06	164.90	20.74	4.26	3.66
VMJH	11:29	1.67	5.94	164.24	21.14	4.32	3.72
VMJH	11:59	0.87	6.71	166.98	21.19	4.41	3.57
VMJH	12:29	0.37	6.46	166.56	20.08	4.31	3.62
VMJH	12:59	2.07	6.07	165.45	21.35	4.30	3.69
VMJH	13:29	1.37	5.93	163.48	20.62	4.29	3.58
VMJH	13:59	0.90	6.17	164.13	20.01	4.17	3.80
VMJH	14:29	1.90	6.24	166.11	21.30	4.36	3.68
VMJH	14:59	1.27	5.82	166.96	20.44	4.31	3.67
VMJH	15:29	0.73	6.15	165.63	20.85	4.27	3.61
VMJH	15:59	1.13	6.33	165.58	20.14	4.34	3.60
VMJH	16:29	1.23	6.10	165.97	20.25	4.34	3.70
VMJH	16:59	0.90	6.25	168.25	20.07	4.25	3.59
VMJH	17:29	0.60	6.27	164.55	20.96	4.38	3.60
VMJH	17:59	1.37	6.30	164.80	20.84	4.38	3.76
VMJH	18:29	1.30	6.46	166.61	20.83	4.23	3.61
VMJH	18:59	0.57	6.12	163.15	20.48	4.24	3.71
VMJH	19:29	1.20	6.44	162.81	21.39	4.27	3.65
VMJH	19:59	1.27	6.16	166.08	21.36	4.34	3.71
VMJH	20:29	1.23	6.18	165.91	21.06	4.36	3.66
VMJH	20:59	1.53	6.30	167.19	21.24	4.19	3.63
VMJH	21:29	1.40	6.17	163.43	20.48	4.35	3.70
VMJH	21:59	1.77	6.11	167.02	20.36	4.30	3.60
VMJH	22:32	0.97	6.38	164.58	20.43	4.36	3.72
VMZ		1.13	6.20	165.33	20.71	4.32	3.66



# Valori inregistrate MIR-IS HP-1500

Data:09/06/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.50	6.30	164.61	19.94	4.27	3.72
VMJH	07:59	1.33	6.30	165.09	21.38	4.25	3.59
VMJH	08:29	0.93	6.11	168.16	20.89	4.31	3.63
VMJH	08:59	1.63	6.07	164.81	20.36	4.26	3.53
VMJH	09:29	2.27	6.28	168.30	21.23	4.34	3.71
VMJH	09:59	2.07	6.02	167.39	20.85	4.29	3.65
VMJH	10:29	1.67	6.42	165.81	21.25	4.41	3.63
VMJH	10:59	1.77	4.05	142.38	16.10	3.28	2.88
VMJH	11:29	2.63	3.66	137.07	14.87	3.24	2.84
VMJH	11:59	1.80	3.55	137.89	15.78	3.08	2.75
VMJH	12:29	1.87	3.80	137.22	16.07	2.90	2.81
VMJH	12:59	2.40	3.57	137.05	15.58	2.94	2.84
VMJH	13:29	2.63	3.43	138.52	15.19	2.94	2.79
VMJH	13:59	1.77	3.45	137.28	15.48	3.05	2.89
VMJH	14:29	2.03	3.83	136.19	16.44	2.81	2.74
VMJH	14:59	2.53	3.32	136.11	15.64	2.95	2.78
VMJH	15:29	1.73	3.80	137.88	15.05	3.01	2.82
VMJH	15:59	1.90	3.56	138.76	15.80	3.07	2.89
VMJH	16:29	2.83	3.59	137.87	15.97	3.04	2.86
VMJH	16:59	3.13	3.62	135.43	15.50	3.02	2.90
VMJH	17:29	1.70	3.58	139.07	14.51	3.20	2.93
VMJH	17:59	1.93	3.51	136.40	15.50	3.09	2.74
VMJH	18:29	1.87	3.62	137.76	16.67	3.04	2.85
VMJH	18:59	2.13	3.62	136.01	15.57	2.90	2.92
VMJH	19:29	1.47	3.58	138.08	14.59	2.99	2.80
VMJH	19:59	2.07	3.84	138.98	16.00	3.09	2.80
VMJH	20:29	1.60	3.65	136.97	16.08	3.05	2.76
VMJH	20:59	1.20	3.32	138.00	16.12	3.25	2.80
VMJH	21:29	3.10	3.98	139.69	15.21	3.04	2.84
VMJH	21:59	1.80	3.59	138.10	15.67	3.12	2.87
VMJH	22:32	1.64	3.57	137.39	16.32	3.03	2.74
VMZ		1.96	4.21	144.18	16.82	3.33	3.01



# Valori inregistrate MIR-IS HP-1500

Data:10/06/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	2.37	3.70	136.15	15.95	3.18	2.83
VMJH	07:59	2.30	3.74	137.85	15.65	3.00	2.75
VMJH	08:29	1.13	3.42	136.79	15.16	3.10	2.74
VMJH	08:59	2.70	3.40	138.44	15.38	3.10	2.81
VMJH	09:29	1.53	3.57	138.27	15.12	3.00	2.75
VMJH	09:59	1.70	3.68	136.90	15.68	3.13	2.83
VMJH	10:29	1.80	3.53	138.68	15.05	3.04	2.71
VMJH	10:59	2.80	3.28	138.27	15.27	3.14	2.77
VMJH	11:29	1.27	3.64	136.86	15.70	3.00	2.87
VMJH	11:59	1.90	3.65	136.64	16.82	3.08	2.84
VMJH	12:29	2.23	3.84	137.91	15.21	3.00	2.75
VMJH	12:59	2.07	3.60	138.22	15.98	3.14	2.82
VMJH	13:29	2.43	3.59	136.60	15.69	2.92	2.78
VMJH	13:48	2.89	3.63	136.08	16.19	2.99	2.79
VMZ		2.06	3.59	137.44	15.62	3.06	2.79

# Valori inregistrate MIR-IS HP-1500

Data:12/06/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	11:14	2.17	3.41	138.03	15.63	2.94	2.87					
VMJH	11:44	1.47	3.59	137.96	15.71	2.98	2.83					
VMJH	12:14	2.40	3.70	139.20	15.57	3.05	2.85					
VMJH	12:44	2.07	3.93	137.40	15.47	3.00	2.75					
VMJH	13:14	2.27	3.77	138.26	15.36	3.02	2.75					
VMJH	13:44	2.23	3.76	136.67	15.13	2.93	2.84					
VMJH	14:14	1.50	3.73	139.27	15.46	2.98	2.85					
VMJH	14:44	2.47	3.67	139.39	15.56	3.22	2.81					
VMJH	15:14	1.63	3.57	136.57	16.03	3.04	2.79					
VMJH	15:44	2.07	3.71	139.28	15.10	3.11	2.73					
VMJH	16:14	1.93	4.16	146.96	17.70	3.12	3.05					
VMJH	16:44	2.33	4.22	151.30	18.35	3.48	3.32					
VMJH	17:14	2.20	4.16	152.52	18.60	3.45	3.26					
VMJH	17:44	2.57	4.31	151.07	18.21	3.39	3.30					
VMJH	18:14	2.20	4.13	151.25	17.94	3.45	3.21					
VMJH	18:44	2.37	4.17	150.34	18.50	3.38	3.33					
VMJH	19:14	2.53	4.18	153.81	17.95	3.43	3.32					
VMJH	19:44	1.70	4.22	150.35	18.02	3.45	3.31					
VMJH	20:14	1.87	4.31	152.93	18.10	3.40	3.29					
VMJH	20:44	2.63	4.16	152.68	18.27	3.50	3.32					
VMJH	21:14	1.97	4.17	151.00	18.23	3.45	3.35					
VMJH	21:44	1.97	4.16	149.60	18.48	3.44	3.30					
VMJH	22:14	2.60	4.20	152.17	18.41	3.32	3.36					
VMJH	22:36	1.45	4.25	153.59	18.44	3.43	3.37					
VMZ		2.11	3.98	145.82	17.08	3.25	3.09					

# Valori inregistrate MIR-IS HP-1500

Data:13/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.80		4.35		150.80		18.44		3.41		3.32	
VMJH	07:59	1.97		4.20		151.05		17.51		3.41		3.30	
VMJH	08:29	1.97		4.16		152.86		18.26		3.43		3.21	
VMJH	08:59	2.37		4.40		152.15		18.20		3.40		3.35	
VMJH	09:29	2.10		3.94		153.43		17.86		3.41		3.26	
VMJH	09:59	2.03		4.17		152.85		18.55		3.52		3.20	
VMJH	10:29	1.90		4.21		153.67		18.35		3.47		3.28	
VMJH	10:59	2.30		4.25		151.89		18.15		3.49		3.35	
VMJH	11:29	2.53		4.16		153.03		18.48		3.47		3.24	
VMJH	11:59	2.20		4.22		151.65		18.56		3.41		3.33	
VMJH	12:29	1.80		4.12		151.11		17.91		3.49		3.37	
VMJH	12:59	2.37		4.29		151.24		17.98		3.32		3.32	
VMJH	13:29	1.13		4.05		152.93		18.30		3.41		3.38	
VMJH	13:59	1.23		4.18		152.65		18.90		3.48		3.30	
VMJH	14:29	1.87		4.24		153.50		18.28		3.45		3.27	
VMJH	14:59	2.23		4.18		151.81		18.11		3.48		3.30	
VMJH	15:29	2.70		4.16		151.18		17.97		3.43		3.26	
VMJH	15:59	1.37		4.12		151.92		18.26		3.41		3.27	
VMJH	16:29	2.30		4.27		152.18		18.24		3.40		3.28	
VMJH	16:59	1.93		4.12		153.25		18.06		3.38		3.31	
VMJH	17:29	2.27		4.30		152.27		18.64		3.45		3.33	
VMJH	17:59	2.53		4.23		150.57		18.22		3.49		3.30	
VMJH	18:29	2.73		4.18		150.98		17.71		3.47		3.42	
VMJH	18:59	2.27		4.21		151.99		17.75		3.45		3.26	
VMJH	19:29	2.23		4.23		153.33		18.19		3.45		3.37	
VMJH	19:59	2.63		4.12		152.71		18.01		3.39		3.26	
VMJH	20:29	2.47		4.29		151.97		17.77		3.35		3.27	
VMJH	20:59	2.10		4.24		152.81		18.79		3.38		3.41	
VMJH	21:29	2.60		4.20		153.10		18.18		3.46		3.27	
VMJH	21:59	2.17		4.19		151.15		18.17		3.35		3.28	
VMJH	22:12	2.31		3.92		151.95		18.14		3.40		3.25	
VMZ		2.14		4.20		152.20		18.19		3.43		3.30	



# Valori inregistrate MIR-IS HP-1500

Data:14/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	2.50	4.18	151.82	18.38	3.36	3.29					
VMJH	07:59	1.63	4.14	151.14	18.37	3.45	3.32					
VMJH	08:29	2.87	4.20	150.62	18.08	3.45	3.39					
VMJH	08:59	2.37	4.21	152.74	18.03	3.41	3.29					
VMJH	09:29	2.57	5.66	160.15	20.90	3.89	3.69					
VMJH	09:59	2.53	5.60	164.02	21.79	4.04	3.87					
VMJH	10:29	1.83	5.69	168.45	21.51	4.09	3.77					
VMJH	10:59	3.03	5.52	165.02	22.14	3.96	3.82					
VMJH	11:29	2.63	5.26	165.08	22.60	4.05	3.89					
VMJH	11:59	2.70	5.81	165.63	22.41	4.01	3.73					
VMJH	12:29	2.47	5.42	162.93	21.76	4.02	3.78					
VMJH	12:59	1.97	5.51	166.43	21.54	3.96	3.82					
VMJH	13:29	2.10	5.59	165.98	21.93	3.95	3.72					
VMJH	13:59	2.53	5.97	169.01	21.79	4.05	3.72					
VMJH	14:29	2.37	5.54	167.47	21.92	4.08	3.79					
VMJH	14:59	2.43	5.51	164.66	21.55	4.03	3.76					
VMJH	15:29	2.47	5.52	169.56	21.72	3.99	3.84					
VMJH	15:59	2.10	5.66	167.39	22.17	4.02	3.82					
VMJH	16:29	2.30	5.70	164.75	21.86	3.97	3.86					
VMJH	16:59	2.33	5.49	162.99	22.52	3.96	3.82					
VMJH	17:29	1.80	5.48	167.32	21.74	4.07	3.92					
VMJH	17:59	1.23	5.83	164.72	22.81	4.07	3.80					
VMJH	18:29	1.43	5.59	163.94	21.58	4.03	3.75					
VMJH	18:59	1.03	5.61	168.71	21.28	4.03	3.75					
VMJH	19:29	0.63	5.60	167.16	21.75	4.01	3.79					
VMJH	19:59	1.07	5.56	166.25	21.69	4.03	3.84					
VMJH	20:29	1.83	5.55	164.44	22.57	3.99	3.87					
VMJH	20:59	1.00	5.64	167.80	21.86	4.04	3.80					
VMJH	21:29	1.73	5.58	168.35	22.19	4.00	3.89					
VMJH	21:59	1.23	5.42	163.63	21.65	4.01	3.67					
VMJH	22:25	1.77	5.54	163.73	21.69	4.03	3.60					
VMZ		2.02	5.41	163.93	21.41	3.94	3.73					

# Valori inregistrate MIR-IS HP-1500

Data:15/06/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.70	5.62	165.33	22.05	3.96	3.73					
VMJH	07:59	1.70	5.56	165.51	21.81	4.10	3.75					
VMJH	08:29	1.83	5.52	168.02	21.61	3.98	3.88					
VMJH	08:59	1.07	5.76	167.07	22.68	4.00	3.72					
VMJH	09:29	1.30	5.69	164.27	21.29	3.99	3.83					
VMJH	09:59	1.17	5.49	163.87	22.36	3.97	3.80					
VMJH	10:29	0.83	5.42	164.83	22.12	4.08	3.89					
VMJH	10:59	1.00	5.49	166.08	21.63	4.09	3.88					
VMJH	11:29	1.23	5.65	162.14	21.63	3.98	3.72					
VMJH	11:59	1.07	5.46	164.23	21.74	3.96	3.81					
VMJH	12:29	0.93	5.79	164.88	21.42	4.00	3.84					
VMJH	12:59	1.20	5.82	166.21	21.60	3.94	3.84					
VMJH	13:29	0.80	5.83	164.11	21.94	4.05	3.79					
VMJH	13:59	1.77	5.46	165.50	21.30	4.06	3.81					
VMJH	14:29	1.17	5.63	167.16	22.61	4.01	3.80					
VMJH	14:59	2.30	5.80	166.53	21.70	3.98	3.97					
VMJH	15:29	1.17	5.72	162.26	21.84	4.06	3.69					
VMJH	15:59	0.93	5.53	167.15	21.48	4.01	3.71					
VMJH	16:29	2.10	5.59	162.57	22.13	4.04	3.72					
VMJH	16:59	1.17	5.56	164.70	21.73	4.01	3.81					
VMJH	17:28	0.10	5.68	167.05	22.45	4.03	3.70					
VMZ		1.27	5.62	165.21	21.86	4.01	3.80					

# Valori inregistrate MIR-IS HP-1500

Data:16/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.57		3.84		148.37		18.43		3.31		3.24	
VMJH	07:59	0.33		2.66		138.64		14.38		2.82		2.92	
VMJH	08:29	0.37		2.69		137.22		15.53		2.82		2.85	
VMJH	08:59	0.40		2.77		137.36		14.21		2.75		2.81	
VMJH	09:29	0.77		2.71		138.29		14.16		2.89		2.75	
VMJH	09:59	0.63		2.73		140.22		14.63		2.85		2.82	
VMJH	10:29	1.07		2.77		138.37		15.22		2.78		2.84	
VMJH	10:59	0.47		2.71		137.87		13.85		2.78		2.82	
VMJH	11:29	0.57		2.74		139.16		14.83		2.92		2.73	
VMJH	11:59	0.30		2.71		139.13		14.28		2.76		2.82	
VMJH	12:29	0.77		2.92		139.27		14.48		3.07		2.81	
VMJH	12:59	0.80		2.77		138.84		15.35		2.84		2.71	
VMJH	13:29	0.53		2.79		139.42		14.55		2.84		2.74	
VMJH	13:59	0.50		2.83		139.04		14.63		2.79		2.94	
VMJH	14:29	0.47		2.69		138.52		13.59		2.67		2.87	
VMJH	14:59	0.27		2.94		137.12		15.10		2.73		2.72	
VMJH	15:29	0.70		2.71		137.85		13.69		2.74		2.86	
VMJH	15:59	0.23		2.78		139.34		14.76		3.03		2.91	
VMJH	16:29	0.93		2.71		138.61		15.05		2.77		2.85	
VMJH	16:59	0.43		2.77		138.38		15.16		2.80		2.85	
VMJH	17:29	0.27		2.81		137.82		14.38		2.75		2.89	
VMJH	17:59	0.27		2.81		137.91		14.69		2.76		2.82	
VMJH	18:29	0.27		2.96		137.94		14.08		2.87		2.81	
VMJH	18:59	0.17		2.86		138.79		14.52		2.85		2.80	
VMJH	19:29	0.47		2.61		138.45		13.79		2.82		2.82	
VMJH	19:59	0.47		2.70		138.50		14.42		2.85		2.86	
VMJH	20:29	0.70		2.80		138.86		15.02		2.88		2.75	
VMJH	20:59	0.50		2.82		138.59		13.92		2.76		2.73	
VMJH	21:29	0.90		2.69		138.84		14.28		2.88		2.83	
VMJH	21:42	1.00		2.83		139.37		14.62		2.96		2.86	
VMZ		0.53		2.80		138.86		14.65		2.84		2.83	



# Valori inregistrate MIR-IS HP-1500

Data:19/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:49	0.63		2.86		139.65		13.74		2.65		2.83
VMJH	08:19	0.83		2.87		137.74		14.29		2.84		2.84
VMJH	08:49	1.03		2.79		138.94		14.49		2.88		2.85
VMJH	09:19	1.97		2.82		139.00		14.43		2.81		2.85
VMJH	09:49	1.07		2.72		138.90		14.49		2.68		2.76
VMJH	10:19	0.83		2.74		139.01		14.06		2.81		2.83
VMJH	10:49	0.53		2.77		138.71		14.98		2.89		2.87
VMJH	11:19	0.60		2.79		137.71		14.46		2.79		2.82
VMJH	11:49	0.77		2.79		139.52		14.51		2.87		2.88
VMJH	12:19	1.33		2.77		138.25		15.10		2.92		2.72
VMJH	12:49	0.90		2.77		139.45		14.45		2.78		2.83
VMJH	13:19	0.97		2.73		138.28		14.05		2.90		2.88
VMJH	13:49	1.07		2.70		139.16		14.64		2.94		2.77
VMJH	14:19	0.67		2.83		138.51		15.40		2.73		2.85
VMJH	14:49	0.43		2.80		138.86		14.00		2.90		2.77
VMJH	15:19	1.10		2.82		137.74		14.20		2.87		2.84
VMJH	15:49	0.23		2.81		137.40		13.62		2.77		2.89
VMJH	16:19	1.10		2.85		139.48		13.83		2.87		2.77
VMJH	16:49	0.53		2.76		138.53		14.77		2.74		2.90
VMJH	17:19	0.83		2.35		140.41		15.38		2.47		3.11
VMJH	17:49	1.23		2.44		139.15		14.40		2.51		3.15
VMJH	18:19	0.47		2.38		141.42		14.31		2.54		3.16
VMJH	18:49	0.90		2.33		139.44		14.57		2.54		3.10
VMJH	19:19	1.37		2.38		140.31		14.83		2.51		3.01
VMJH	19:49	1.30		2.37		139.75		14.68		2.51		2.98
VMJH	20:19	1.27		2.39		139.29		14.88		2.42		3.20
VMJH	20:49	1.00		2.32		139.92		14.89		2.59		3.11
VMJH	21:19	0.83		2.44		140.77		14.97		2.57		3.26
VMJH	21:49	1.20		2.40		138.70		14.31		2.57		3.17
VMJH	22:19	0.63		2.38		137.81		14.81		2.45		3.28
VMJH	22:49	0.87		2.43		140.18		14.93		2.50		3.01
VMZ		0.92		2.63		139.10		14.53		2.70		2.94

# Valori inregistrate MIR-IS HP-1500

Data:20/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.57		2.36		141.10		14.40		2.51		3.10	
VMJH	07:59	0.97		2.34		139.78		14.83		2.41		3.16	
VMJH	08:29	0.67		2.41		139.20		14.61		2.46		2.90	
VMJH	08:59	0.90		2.43		140.82		15.01		2.54		3.16	
VMJH	09:29	0.40		2.40		140.11		15.21		2.51		3.09	
VMJH	09:59	1.87		2.35		140.38		14.82		2.54		3.28	
VMJH	10:29	0.70		2.38		139.90		15.01		2.51		3.27	
VMJH	10:59	0.53		2.35		138.56		14.69		2.55		3.25	
VMJH	11:29	0.23		2.37		140.68		14.87		2.56		3.18	
VMJH	11:59	0.30		2.45		139.51		14.50		2.50		3.11	
VMJH	12:29	0.80		2.43		139.07		14.39		2.42		3.04	
VMJH	12:59	0.53		2.37		137.87		14.37		2.41		2.98	
VMJH	13:29	1.27		2.37		140.38		14.27		2.50		3.22	
VMJH	13:59	1.00		2.37		140.92		14.69		2.45		3.27	
VMJH	14:29	1.30		2.32		139.84		14.84		2.44		3.02	
VMJH	14:59	1.07		2.35		140.27		14.54		2.58		3.11	
VMJH	15:29	0.87		2.39		139.33		14.40		2.57		3.28	
VMJH	15:59	0.57		2.33		141.70		15.15		2.46		2.86	
VMJH	16:29	0.40		2.35		141.03		14.84		2.55		3.11	
VMJH	16:59	0.50		2.40		141.44		14.86		2.56		3.14	
VMJH	17:29	0.73		2.28		139.61		14.46		2.44		3.14	
VMJH	17:59	0.73		2.41		139.11		15.14		2.55		3.08	
VMJH	18:29	0.63		2.30		137.93		14.92		2.48		3.04	
VMJH	18:59	0.37		2.39		139.53		14.66		2.47		3.09	
VMJH	19:29	0.43		2.37		140.77		14.44		2.56		3.10	
VMJH	19:59	0.43		2.39		142.16		14.57		2.44		3.13	
VMJH	20:29	0.80		2.37		140.48		14.76		2.43		3.12	
VMJH	20:59	0.60		2.38		140.38		14.58		2.36		3.06	
VMJH	21:29	0.47		2.34		139.02		14.89		2.43		3.19	
VMJH	21:59	0.23		2.36		140.30		15.28		2.54		2.92	
VMJH	22:29	0.47		2.38		139.25		14.93		2.47		3.08	
VMJH	22:43	0.21		2.42		137.46		14.96		2.41		2.96	
VMZ		0.68		2.37		139.97		14.74		2.49		3.11	



# Valori inregistrate MIR-IS HP-1500

Data:21/06/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.83		2.32		140.05		14.99		2.58		3.17	
VMJH	07:59	0.17		2.43		140.38		14.51		2.50		3.09	
VMJH	08:29	0.70		2.44		139.32		14.73		2.48		3.28	
VMJH	08:59	0.20		2.43		138.51		14.34		2.52		3.04	
VMJH	09:29	0.23		4.09		151.26		17.63		3.07		3.60	
VMJH	09:59	0.30		5.61		167.00		21.34		3.83		3.87	
VMJH	10:29	0.37		5.47		166.94		21.22		3.88		3.84	
VMJH	10:59	0.37		5.79		163.29		21.17		3.86		3.87	
VMJH	11:29	0.33		5.65		165.38		21.51		3.86		3.81	
VMJH	11:59	0.70		5.54		166.39		21.27		3.86		3.85	
VMJH	12:29	0.43		5.64		164.79		21.16		3.84		3.88	
VMJH	12:59	0.77		5.85		163.20		21.37		3.83		3.86	
VMJH	13:29	1.13		5.69		165.43		21.04		3.85		3.86	
VMJH	13:59	0.90		5.71		165.66		21.39		3.87		3.86	
VMJH	14:29	0.70		5.44		164.01		20.87		3.81		3.87	
VMJH	14:59	0.57		5.63		165.49		21.13		3.87		3.83	
VMJH	15:29	0.90		5.72		167.95		21.29		3.86		3.87	
VMJH	15:59	0.73		5.50		165.17		20.25		3.84		3.85	
VMJH	16:29	0.97		5.93		164.23		20.90		3.88		3.86	
VMJH	16:59	1.10		5.61		166.57		21.38		3.84		3.86	
VMJH	17:29	0.83		5.77		164.60		21.58		3.84		3.86	
VMJH	17:59	1.27		5.58		162.96		21.73		3.83		3.83	
VMJH	18:29	1.40		5.83		165.26		20.74		3.84		3.87	
VMJH	18:59	1.33		5.68		167.19		21.30		3.85		3.88	
VMJH	19:29	0.97		5.56		163.73		22.59		3.85		3.84	
VMJH	19:59	0.87		5.78		167.37		20.92		3.82		3.85	
VMJH	20:29	1.53		5.81		163.17		21.05		3.85		3.86	
VMJH	20:59	1.50		5.62		167.01		20.99		3.82		3.84	
VMJH	21:29	1.20		5.61		165.61		21.67		3.85		3.88	
VMJH	21:59	1.30		5.66		167.33		20.86		3.84		3.85	
VMJH	22:32	0.21		5.60		166.62		21.40		3.87		3.84	
VMZ		0.80		5.19		161.69		20.27		3.65		3.76	



# Valori inregistrate MIR-IS HP-1500

Data:22/06/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	15:29	0.60	5.70	163.31	21.60	3.88	3.85
VMJH	15:59	1.17	5.69	166.86	21.32	3.86	3.86
VMJH	16:29	0.37	5.56	165.62	21.37	3.79	3.86
VMJH	16:59	0.90	5.60	166.36	20.87	3.86	3.85
VMJH	17:29	1.20	5.48	164.05	21.01	3.83	3.89
VMJH	17:59	0.90	5.31	165.92	20.81	3.86	3.87
VMJH	18:29	1.00	5.57	166.11	20.91	3.83	3.85
VMJH	18:59	1.23	5.55	163.67	21.30	3.82	3.88
VMJH	19:29	1.30	5.85	169.81	21.12	3.84	3.84
VMJH	19:59	0.80	5.86	167.67	21.16	3.85	3.84
VMJH	20:29	1.20	5.41	164.15	21.26	3.86	3.85
VMJH	20:59	1.03	5.69	164.41	21.27	3.89	3.83
VMJH	21:29	1.27	5.37	165.18	21.45	3.85	3.85
VMJH	21:59	1.13	5.60	165.19	21.47	3.86	3.81
VMJH	22:29	1.00	5.81	165.60	21.50	3.86	3.88
VMJH	22:43	0.93	5.63	165.48	21.52	3.85	3.88
VMZ		1.00	5.60	165.59	21.24	3.85	3.85

# Valori inregistrate MIR-IS HP-1500

Data:23/06/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	08:59	1.43	5.88	165.58	21.66	3.87	3.84
VMJH	09:29	1.40	5.54	166.31	20.92	3.83	3.84
VMJH	09:59	0.43	5.35	165.01	21.04	3.87	3.86
VMJH	10:29	1.30	5.70	166.84	21.46	3.85	3.89
VMJH	10:59	0.83	5.60	164.53	21.00	3.90	3.90
VMJH	11:29	1.33	5.54	163.82	20.55	3.79	3.84
VMJH	11:59	0.33	4.09	153.00	17.72	3.16	3.46
VMJH	12:29	2.77	4.04	152.33	18.53	3.17	3.44
VMJH	12:59	1.60	3.95	154.44	18.15	3.20	3.43
VMJH	13:29	0.23	4.07	154.00	18.46	3.17	3.44
VMJH	13:59	2.20	3.90	152.32	18.12	3.15	3.35
VMJH	14:29	1.80	3.98	152.13	17.92	3.19	3.37
VMJH	14:59	1.97	3.92	152.13	18.21	3.17	3.39
VMJH	15:29	1.80	4.00	154.12	17.83	3.16	3.41
VMJH	15:59	1.90	3.95	151.75	18.16	3.19	3.42
VMJH	16:29	1.77	3.94	152.09	18.44	3.16	3.40
VMJH	16:59	2.23	4.01	152.88	18.21	3.15	3.41
VMJH	17:29	1.77	4.09	151.75	18.01	3.13	3.38
VMJH	17:59	1.53	3.95	152.81	18.03	3.20	3.37
VMJH	18:29	1.77	4.00	154.21	17.66	3.15	3.45
VMJH	18:59	1.73	3.82	152.68	18.07	3.15	3.46
VMJH	19:29	0.30	4.08	153.28	17.94	3.19	3.39
VMJH	19:59	1.47	4.08	152.24	18.03	3.18	3.30
VMJH	20:29	2.00	4.05	153.11	17.45	3.18	3.46
VMJH	20:59	0.20	4.01	152.15	17.99	3.18	3.45
VMJH	21:29	1.90	4.02	152.25	18.10	3.19	3.37
VMJH	21:59	2.03	4.09	150.40	17.57	3.22	3.40
VMJH	22:29	1.40	4.10	151.35	18.29	3.15	3.42
VMJH	22:44	1.07	3.98	152.74	18.19	3.11	3.25
VMZ		1.47	4.34	155.29	18.69	3.31	3.50

# Valori inregistrate MIR-IS HP-1500

Data:26/06/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	10:48	1.97	4.02	151.90	18.04	3.16	3.39
VMJH	11:18	1.37	4.04	153.97	17.85	3.13	3.43
VMJH	11:48	0.77	3.98	152.13	17.88	3.17	3.37
VMJH	12:18	0.80	4.01	153.63	17.90	3.20	3.52
VMJH	12:48	2.37	4.01	152.07	17.91	3.18	3.36
VMJH	13:18	1.17	4.06	153.23	18.32	3.17	3.46
VMJH	13:48	1.20	4.05	152.04	17.94	3.20	3.41
VMJH	14:18	2.60	3.92	153.39	18.20	3.13	3.43
VMJH	14:48	0.67	3.98	152.02	18.00	3.22	3.35
VMJH	15:18	1.80	4.01	152.99	18.35	3.19	3.44
VMJH	15:48	0.77	3.86	151.65	17.84	3.14	3.42
VMJH	16:18	1.07	3.99	152.09	17.40	3.19	3.42
VMJH	16:48	1.57	3.92	151.12	17.99	3.15	3.45
VMJH	17:18	2.37	3.90	154.87	18.22	3.18	3.28
VMJH	17:48	1.93	3.99	153.07	17.90	3.19	3.43
VMJH	18:18	0.80	4.04	153.11	18.03	3.19	3.33
VMJH	18:48	0.63	4.06	152.87	17.59	3.21	3.37
VMJH	19:18	0.70	3.99	152.00	17.65	3.16	3.28
VMJH	19:48	1.70	3.85	152.95	18.50	3.14	3.40
VMJH	20:18	1.80	3.88	152.97	17.74	3.22	3.46
VMJH	20:25	0.86	4.09	155.20	17.09	3.18	3.45
VMZ		1.39	3.98	152.74	17.95	3.18	3.40



# Valori inregistrate MIR-IS HP-1500

Data:27/06/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	07:29	0.53	3.90	153.42	18.03	3.16	3.44
VMJH	07:59	0.43	4.00	152.74	17.73	3.18	3.41
VMJH	08:29	2.70	4.03	152.91	18.06	3.18	3.37
VMJH	08:59	1.17	3.80	152.47	18.30	3.23	3.31
VMJH	09:29	0.00	3.96	152.10	18.01	3.17	3.45
VMJH	09:59	0.77	2.80	143.21	16.38	2.55	3.33
VMJH	10:29	0.67	2.50	141.51	14.84	2.47	3.21
VMJH	10:59	1.37	2.62	138.94	15.42	2.43	3.18
VMJH	11:29	2.17	2.62	141.47	14.65	2.34	3.11
VMJH	11:59	1.57	2.57	138.76	16.04	2.42	3.13
VMJH	12:29	0.43	2.52	140.97	14.14	2.42	3.07
VMJH	12:59	1.83	2.52	140.00	15.49	2.43	3.01
VMJH	13:29	1.90	2.64	140.99	15.00	2.44	3.14
VMJH	13:59	0.93	2.54	140.40	15.35	2.43	3.12
VMJH	14:29	0.00	2.62	143.56	15.32	2.45	3.28
VMJH	14:59	2.03	2.53	140.15	14.64	2.44	3.22
VMJH	15:29	0.63	2.59	138.41	14.71	2.45	2.94
VMJH	15:59	1.70	2.50	141.39	15.65	2.38	3.09
VMJH	16:29	2.03	2.62	138.29	14.65	2.37	3.13
VMJH	16:59	1.23	2.50	139.87	15.03	2.41	3.15
VMJH	17:29	2.00	2.56	138.97	15.65	2.41	2.99
VMJH	17:59	1.93	2.65	140.49	14.92	2.42	3.01
VMJH	18:29	2.93	2.49	138.53	14.61	2.39	3.02
VMJH	18:42	1.54	2.47	139.85	14.88	2.32	3.15
VMZ		1.35	2.87	142.96	15.75	2.58	3.18

# Valori inregistrate MIR-IS HP-1500

Data:28/06/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10	
VMJH	07:29	0.97	2.57	140.72	14.91	2.45	3.08
VMJH	07:59	1.20	2.60	141.21	14.67	2.43	3.17
VMJH	08:29	0.93	2.68	137.97	15.07	2.49	3.16
VMJH	08:59	1.93	2.51	139.67	15.05	2.36	3.30
VMJH	09:29	1.17	2.44	140.89	15.38	2.35	3.12
VMJH	09:59	1.73	2.42	138.12	14.38	2.42	3.15
VMJH	10:29	1.33	2.46	141.25	14.80	2.45	3.16
VMJH	10:59	1.87	2.62	140.49	15.42	2.45	3.12
VMJH	11:29	1.47	2.59	138.89	15.01	2.42	3.14
VMJH	11:59	1.00	2.55	140.53	15.66	2.37	3.25
VMJH	12:29	1.37	2.55	140.01	15.00	2.39	3.17
VMJH	12:59	1.17	2.64	140.36	15.51	2.48	3.12
VMJH	13:29	0.77	2.64	139.77	15.27	2.39	3.17
VMJH	13:59	0.50	2.51	140.23	15.49	2.38	3.14
VMJH	14:29	1.20	2.63	140.60	15.09	2.39	3.15
VMJH	14:59	0.93	2.53	140.00	16.08	2.45	3.08
VMJH	15:29	0.80	2.54	140.71	15.21	2.40	3.20
VMJH	15:59	0.93	2.60	138.71	15.23	2.44	3.23
VMJH	16:29	0.47	2.57	139.19	14.99	2.43	3.10
VMJH	16:59	1.83	2.50	139.47	14.67	2.43	3.10
VMJH	17:29	0.57	2.51	140.20	14.79	2.38	3.13
VMJH	17:59	0.83	2.53	140.10	15.02	2.48	3.05
VMJH	18:29	0.57	2.62	140.81	15.59	2.37	3.11
VMJH	18:59	0.40	2.49	141.31	16.19	2.40	3.00
VMJH	19:15	0.31	2.70	139.04	15.12	2.39	2.86
VMZ		1.06	2.56	140.03	15.19	2.42	3.14

# Valori inregistrate MIR-IS HP-1500

Data:29/06/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	13:57	0.37	2.43	139.15	15.28	2.40	3.10
VMJH	14:27	0.53	2.56	138.43	15.60	2.41	3.17
VMJH	14:57	0.43	2.53	141.56	14.26	2.37	3.18
VMJH	15:27	1.03	2.59	138.33	15.39	2.44	3.13
VMJH	15:57	0.83	2.52	140.59	15.63	2.39	3.09
VMJH	16:27	1.47	4.28	161.56	19.64	3.46	3.77
VMJH	16:57	0.57	5.09	166.85	21.00	3.78	4.06
VMJH	17:27	0.83	5.09	168.44	21.31	3.79	3.84
VMJH	17:57	0.93	4.92	169.88	20.50	3.78	3.96
VMJH	18:27	0.57	5.05	167.34	21.22	3.77	4.10
VMJH	18:57	0.50	5.11	169.04	21.46	3.80	4.20
VMJH	19:27	0.90	4.94	168.01	21.57	3.80	4.08
VMJH	19:57	0.70	5.02	167.06	21.33	3.79	3.96
VMJH	20:27	0.67	4.92	168.58	21.05	3.80	4.07
VMJH	20:48	0.86	4.89	170.12	20.59	3.80	4.03
VMZ		0.74	4.11	158.10	19.02	3.30	3.71



# Valori inregistrate MIR-IS HP-1500

Data 30/06/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	0.80	4.89	167.21	21.49	3.80	4.07				
VMJH	07:59	1.13	5.11	168.61	21.01	3.81	4.13				
VMJH	08:29	0.77	5.08	168.11	21.03	3.81	4.02				
VMJH	08:59	1.00	5.01	167.80	21.18	3.80	3.92				
VMJH	09:29	1.07	4.92	167.68	21.75	3.83	3.84				
VMJH	09:59	0.93	4.97	169.00	21.29	3.79	4.10				
VMJH	10:29	0.67	5.16	166.51	21.64	3.83	4.06				
VMJH	10:59	0.37	5.11	167.27	20.96	3.78	4.21				
VMJH	11:29	0.57	4.98	165.90	21.08	3.77	3.75				
VMJH	11:59	0.90	5.16	169.02	21.58	3.80	4.22				
VMJH	12:29	1.27	4.93	168.56	20.92	3.80	3.93				
VMJH	12:59	1.17	5.08	166.94	20.87	3.78	3.99				
VMJH	13:29	1.13	4.95	167.77	21.33	3.79	4.03				
VMJH	13:59	1.00	4.96	168.56	20.87	3.81	4.19				
VMJH	14:29	0.10	5.13	168.36	21.91	3.79	4.18				
VMJH	14:59	0.83	5.04	167.90	21.40	3.85	4.01				
VMJH	15:29	1.03	5.14	168.36	20.50	3.79	4.00				
VMJH	15:59	0.10	4.91	167.72	21.32	3.79	4.27				
VMJH	16:29	0.73	4.91	168.29	20.67	3.82	4.05				
VMJH	16:59	0.33	4.94	167.93	20.62	3.79	4.13				
VMJH	17:29	1.43	4.87	168.96	20.89	3.78	4.15				
VMJH	17:42	0.69	5.09	170.66	20.17	3.81	4.09				
VMZ		0.82	5.01	167.98	21.14	3.80	4.06				

# Valori inregistrate MIR-IS HP-1500

Data:03/07/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	10:49	2.03	2.73	145.28	14.91	2.52	3.00
VMJH	11:19	2.60	2.39	140.60	15.20	2.57	3.00
VMJH	11:49	2.13	2.74	143.08	15.37	2.62	2.94
VMJH	12:19	2.83	2.69	140.37	14.54	2.61	2.89
VMJH	12:49	3.27	2.54	140.20	15.12	2.46	2.93
VMJH	13:19	2.73	2.53	142.16	14.04	2.55	2.95
VMJH	13:49	3.20	2.74	140.78	15.03	2.54	2.93
VMJH	14:19	2.50	2.73	141.79	14.80	2.55	2.85
VMJH	14:49	2.73	2.57	143.33	13.92	2.52	2.86
VMJH	15:19	2.90	2.78	140.87	14.45	2.49	3.00
VMJH	15:49	3.43	2.53	140.53	14.86	2.55	3.02
VMJH	16:19	2.13	2.58	142.12	15.01	2.57	2.98
VMJH	16:49	1.27	2.56	140.47	14.87	2.44	3.15
VMJH	17:19	1.13	2.77	142.56	15.27	2.47	2.99
VMJH	17:45	1.04	2.53	143.96	15.04	2.51	2.85
VMZ		2.41	2.63	141.86	14.83	2.53	2.96

# Valori inregistrate MIR-IS HP-1500

Data:04/07/2023

Ora	Pulberi mg/Nm <sup>2</sup>		SO <sub>2</sub> L1 mg/Nm <sup>3</sup>		NO <sub>x</sub> L1 mg/Nm <sup>3</sup>		CO L1 mg/Nm <sup>3</sup>	COT L1 mg/Nm <sup>3</sup>		HCL L1 mg/Nm <sup>3</sup>	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	2.70	2.54	143.03	15.09	2.56	2.91				
VMJH	07:59	2.33	2.62	142.16	14.02	2.61	3.03				
VMJH	08:29	3.27	2.64	142.51	15.16	2.53	3.03				
VMJH	08:59	2.27	2.57	140.48	13.89	2.49	3.05				
VMJH	09:29	2.77	2.62	144.18	15.41	2.61	2.96				
VMJH	09:59	2.47	2.82	140.45	14.38	2.59	2.92				
VMJH	10:29	2.20	2.68	143.55	14.58	2.51	2.97				
VMJH	10:59	2.77	2.80	142.10	14.66	2.38	2.90				
VMJH	11:29	1.53	2.53	142.44	15.91	2.47	2.95				
VMJH	11:59	2.40	2.66	141.38	14.86	2.56	2.91				
VMJH	12:29	3.10	2.51	143.96	14.92	2.54	2.91				
VMJH	12:59	2.47	2.64	141.24	15.53	2.48	2.82				
VMJH	13:29	2.60	2.72	143.73	14.77	2.47	2.86				
VMJH	13:59	2.30	2.42	140.11	13.85	2.63	3.01				
VMJH	14:29	2.34	2.58	143.99	15.26	2.60	2.91				
VMJH	14:59	2.57	2.76	141.88	15.27	2.58	2.98				
VMJH	15:29	2.67	2.68	143.24	13.89	2.57	2.95				
VMJH	15:59	3.13	2.85	143.39	14.27	2.53	2.90				
VMJH	16:29	2.53	2.59	140.50	14.39	2.47	2.92				
VMJH	16:38	2.44	2.39	142.84	14.73	2.63	3.04				
VMZ		2.61	2.68	142.52	14.62	2.55	2.94				



# Valori inregistrate MIR-IS HP-1500

Data:05/07/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:54	2.33	2.70	142.44	15.46	2.56	2.96
VMJH	08:24	1.80	2.88	142.06	15.44	2.56	3.08
VMJH	08:54	2.23	2.91	141.29	15.49	2.58	2.89
VMJH	09:24	2.57	2.77	141.37	15.10	2.51	2.99
VMJH	09:54	1.77	2.38	142.03	16.08	2.60	2.90
VMJH	10:24	2.30	2.78	145.85	13.71	2.52	3.01
VMJH	10:54	1.97	2.34	142.59	13.91	2.56	2.95
VMJH	11:24	2.50	2.61	144.92	14.97	2.58	2.96
VMJH	11:54	2.80	3.03	145.10	15.35	2.52	3.02
VMJH	12:24	2.17	2.68	140.66	15.15	2.56	2.89
VMJH	12:54	2.47	2.26	142.06	15.05	2.54	3.10
VMJH	13:24	1.77	2.87	140.59	14.73	2.54	2.99
VMJH	13:54	3.00	2.68	143.75	14.58	2.58	2.95
VMJH	14:24	2.83	2.94	146.29	15.98	2.72	3.09
VMJH	14:54	2.17	4.09	174.99	21.01	3.87	3.65
VMJH	15:24	2.20	4.51	173.19	21.70	3.94	3.62
VMJH	15:54	2.37	4.44	172.10	21.91	3.87	3.65
VMJH	16:24	1.70	4.23	173.49	20.90	3.89	3.59
VMJH	16:54	1.50	4.07	172.02	20.90	3.82	3.64
VMJH	17:24	1.27	3.94	174.71	21.63	3.95	3.55
VMJH	17:42	1.06	4.18	171.93	20.88	3.85	3.43
VMZ		2.15	3.19	152.66	17.07	2.99	3.18

# Valori inregistrate MIR-IS HP-1500

Data:11/07/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:29	1.37	4.06	175.39	21.00	3.92	3.55
VMJH	15:59	2.37	4.23	172.76	22.05	3.86	3.58
VMJH	16:29	3.33	4.24	174.98	21.18	3.87	3.49
VMJH	16:59	2.93	4.41	173.98	21.30	3.88	3.56
VMJH	17:29	3.03	4.20	174.56	21.79	3.91	3.57
VMJH	17:59	4.27	4.45	173.34	21.48	3.80	3.51
VMJH	18:29	4.40	4.13	174.13	21.37	3.89	3.67
VMJH	18:59	2.77	3.98	172.55	21.31	3.86	3.66
VMJH	19:29	2.23	4.17	175.71	21.55	3.82	3.63
VMJH	19:59	2.17	3.95	171.11	21.23	3.87	3.53
VMJH	20:29	1.73	4.04	172.73	22.05	3.89	3.49
VMJH	20:59	2.40	4.24	175.42	21.44	3.87	3.62
VMJH	21:29	1.60	4.22	174.38	20.82	3.90	3.49
VMJH	21:59	3.23	3.77	174.04	21.08	3.89	3.56
VMJH	22:29	3.40	4.03	171.68	21.54	3.96	3.58
VMJH	22:43	3.79	4.68	177.66	21.41	3.91	3.58
VMZ		2.78	4.16	173.91	21.41	3.88	3.57

# Valori inregistrate MIR-IS HP-1500

Data:12/07/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	2.97		4.42		175.18		21.20		3.82		3.47	
VMJH	07:59	2.70		4.20		174.76		21.63		3.83		3.57	
VMJH	08:29	2.70		3.81		174.60		20.88		3.84		3.62	
VMJH	08:59	3.20		4.15		172.28		21.67		3.93		3.54	
VMJH	09:29	3.00		4.34		175.49		21.09		3.87		3.51	
VMJH	09:59	3.80		4.20		172.00		21.74		3.82		3.60	
VMJH	10:29	2.77		4.47		173.67		21.63		3.97		3.51	
VMJH	10:59	2.63		4.06		173.14		20.27		3.87		3.62	
VMJH	11:29	2.97		4.18		172.26		20.90		3.97		3.54	
VMJH	11:59	2.80		3.89		172.45		21.26		3.91		3.55	
VMJH	12:29	2.27		4.15		173.89		21.39		3.89		3.58	
VMJH	12:59	2.67		4.09		175.39		21.88		3.87		3.49	
VMJH	13:29	1.27		4.07		172.49		20.80		3.80		3.56	
VMJH	13:59	2.33		3.89		176.51		21.79		3.88		3.59	
VMJH	14:29	0.87		4.27		172.85		20.40		3.94		3.52	
VMJH	14:59	1.63		3.99		171.96		22.22		3.89		3.53	
VMJH	15:29	1.20		4.37		174.30		21.40		3.82		3.52	
VMJH	15:59	1.07		3.99		174.10		21.06		3.86		3.61	
VMJH	16:29	2.30		3.91		173.06		21.47		3.89		3.54	
VMJH	16:59	1.67		4.31		172.12		20.69		3.90		3.60	
VMJH	17:29	1.20		3.89		170.87		20.71		3.96		3.56	
VMJH	17:59	0.97		4.32		174.31		21.63		3.85		3.65	
VMJH	18:29	1.63		4.36		171.98		21.22		3.87		3.47	
VMJH	18:59	0.87		4.36		171.73		21.20		3.85		3.55	
VMJH	19:29	1.40		4.09		174.22		21.06		3.86		3.52	
VMJH	19:59	2.60		3.94		169.84		20.56		3.65		3.45	
VMJH	20:29	1.80		3.48		159.97		17.75		3.20		3.28	
VMJH	20:59	1.40		3.47		156.37		18.65		3.30		3.35	
VMJH	21:29	2.20		3.53		158.04		18.75		3.24		3.27	
VMJH	21:59	1.63		3.47		155.98		17.54		3.21		3.26	
VMJH	22:29	1.37		3.21		156.66		17.94		3.14		3.28	
VMJH	22:50	0.38		3.30		158.09		17.73		3.26		3.25	
VMZ		2.02		4.01		170.44		20.66		3.75		3.50	



# Valori inregistrate MIR-IS HP-1500

Data:13/07/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.77	3.46	157.00	18.13	3.21	3.23
VMJH	07:59	0.80	3.34	158.49	17.76	3.24	3.18
VMJH	08:29	1.80	3.46	157.66	18.13	3.21	3.21
VMJH	08:59	1.83	3.54	158.97	17.72	3.17	3.24
VMJH	09:29	0.73	3.41	157.67	18.27	3.23	3.30
VMJH	09:59	1.93	3.47	157.01	18.30	3.23	3.27
VMJH	10:29	1.53	3.40	157.80	18.23	3.14	3.34
VMJH	10:59	1.63	3.46	157.51	18.45	3.15	3.35
VMJH	11:29	1.17	3.29	158.88	18.05	3.19	3.24
VMJH	11:59	0.97	3.32	159.02	18.03	3.21	3.24
VMJH	12:29	1.80	3.41	156.49	17.73	3.24	3.31
VMJH	12:59	0.93	3.22	157.92	18.75	3.22	3.26
VMJH	13:29	1.70	3.42	157.48	17.72	3.16	3.33
VMJH	13:59	0.97	3.40	159.50	18.08	3.25	3.24
VMJH	14:29	1.50	3.32	157.08	17.92	3.24	3.23
VMJH	14:59	0.87	3.41	158.29	17.76	3.25	3.28
VMJH	15:29	1.43	3.63	159.04	18.13	3.09	3.20
VMJH	15:59	1.17	3.36	158.88	18.43	3.16	3.26
VMJH	16:29	0.57	3.30	157.48	18.26	3.20	3.22
VMJH	16:59	1.03	3.27	158.75	18.10	3.23	3.27
VMJH	17:29	0.50	3.53	157.76	18.41	3.19	3.14
VMJH	17:59	1.10	3.47	158.45	18.07	3.15	3.25
VMJH	18:29	0.67	3.32	156.51	17.83	3.26	3.27
VMJH	18:59	1.33	3.41	158.79	17.96	3.26	3.27
VMJH	19:29	1.13	3.55	156.62	18.02	3.25	3.23
VMJH	19:59	1.43	3.32	157.97	17.60	3.27	3.28
VMJH	20:29	1.67	3.45	158.91	17.81	3.19	3.25
VMJH	20:59	2.13	3.32	158.48	17.88	3.20	3.18
VMJH	21:29	1.67	3.23	157.39	18.28	3.20	3.29
VMJH	21:59	1.17	3.42	158.30	18.09	3.19	3.34
VMJH	22:30	2.39	3.53	157.65	18.37	3.25	3.21
VMZ		1.33	3.40	157.99	18.07	3.21	3.25

# Valori inregistrate MIR-IS HP-1500

Data:14/07/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.23		3.49		156.61		18.54		3.22		3.25	
VMJH	07:59	2.03		3.32		157.78		18.75		3.20		3.26	
VMJH	08:29	1.33		3.46		159.29		17.67		3.20		3.24	
VMJH	08:59	1.07		3.20		159.27		17.61		3.23		3.28	
VMJH	09:29	2.13		3.35		158.59		18.00		3.22		3.26	
VMJH	09:59	0.83		3.43		157.86		18.02		3.23		3.28	
VMJH	10:29	1.50		3.47		157.23		18.07		3.21		3.29	
VMJH	10:59	2.10		3.41		157.11		18.24		3.23		3.30	
VMJH	11:29	1.33		3.49		156.77		18.24		3.20		3.27	
VMJH	11:59	1.23		3.50		157.46		17.62		3.21		3.20	
VMJH	12:29	2.07		3.41		158.34		17.92		3.15		3.24	
VMJH	12:59	1.40		4.41		158.50		18.93		4.17		3.30	
VMJH	13:29	1.40		4.88		159.17		19.48		4.25		3.31	
VMJH	13:59	1.27		4.70		158.27		19.23		4.09		3.34	
VMJH	14:29	1.63		4.51		159.07		19.50		4.42		3.38	
VMJH	14:59	1.13		4.80		158.92		19.19		4.28		3.25	
VMJH	15:29	1.07		4.53		158.23		19.43		4.13		3.23	
VMJH	15:59	1.47		4.70		159.31		19.45		4.09		3.18	
VMJH	16:29	1.07		4.78		159.89		19.86		4.23		3.30	
VMJH	16:59	1.40		4.65		157.16		18.94		4.28		3.33	
VMJH	17:29	1.17		4.87		159.96		18.83		3.99		3.16	
VMJH	17:59	1.60		4.61		158.48		19.11		4.17		3.27	
VMJH	18:29	1.63		4.73		159.62		18.82		4.24		3.33	
VMJH	18:59	1.00		4.71		160.86		19.34		4.17		3.22	
VMJH	19:29	1.87		4.85		157.26		19.46		4.33		3.25	
VMJH	19:59	0.70		4.95		157.36		18.95		4.26		3.31	
VMJH	20:29	1.23		4.55		158.57		19.61		4.09		3.27	
VMJH	20:59	1.80		4.45		157.25		19.30		4.36		3.30	
VMJH	21:29	1.30		4.77		158.24		19.11		4.35		3.30	
VMJH	21:59	1.77		4.63		158.12		19.23		4.26		3.31	
VMJH	22:29	1.30		4.28		158.54		18.88		4.27		3.24	
VMJH	22:45	2.50		4.57		158.13		19.27		4.44		3.25	
VMZ		1.44		4.23		158.35		18.83		3.87		3.27	

# Valori inregistrate MIR-IS HP-1500

Data:17/07/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	15:13	2.20	5.14	158.30	19.08	4.21	3.28					
VMJH	15:43	2.43	4.65	157.52	19.17	4.19	3.23					
VMJH	16:13	2.07	4.66	159.21	19.36	4.14	3.25					
VMJH	16:43	1.93	4.86	157.76	18.87	4.19	3.18					
VMJH	17:13	1.50	4.78	159.24	19.40	4.20	3.24					
VMJH	17:43	1.37	4.19	159.20	19.34	4.29	3.26					
VMJH	18:13	1.90	4.53	157.45	19.29	4.29	3.19					
VMJH	18:43	2.33	4.64	158.29	19.16	4.14	3.20					
VMJH	19:13	1.27	4.77	158.64	19.27	4.26	3.32					
VMJH	19:43	0.77	4.76	158.83	19.14	4.18	3.22					
VMJH	20:13	1.10	4.50	159.14	19.30	4.05	3.22					
VMJH	20:43	1.17	4.79	160.42	19.04	4.15	3.27					
VMJH	21:13	1.40	4.81	160.20	19.23	4.06	3.22					
VMJH	21:43	1.03	4.74	158.80	18.98	4.11	3.20					
VMJH	22:03	1.00	4.63	158.87	18.76	3.94	3.26					
VMZ		1.58	4.70	158.79	19.17	4.17	3.24					



# Valori inregistrate MIR-IS HP-1500

Data:18/07/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	14:53	0.83	4.82	159.51	18.91	4.08	3.33				
VMJH	15:23	1.50	4.74	158.59	19.29	4.35	3.28				
VMJH	15:53	1.13	4.94	159.35	19.00	4.33	3.29				
VMJH	16:23	1.47	4.62	158.84	19.39	4.30	3.27				
VMJH	16:53	2.10	5.04	157.42	19.41	4.12	3.34				
VMJH	17:23	2.33	4.66	159.43	19.34	4.08	3.25				
VMJH	17:53	1.50	4.79	157.46	19.09	4.19	3.28				
VMJH	18:23	1.40	4.39	158.67	19.30	4.20	3.25				
VMJH	18:53	2.30	4.95	158.64	19.06	4.16	3.28				
VMJH	19:23	2.00	4.93	158.19	18.99	4.25	3.25				
VMJH	19:53	1.23	4.63	160.86	19.39	4.24	3.29				
VMJH	20:23	1.17	4.91	159.58	19.47	4.29	3.31				
VMJH	20:53	2.13	4.41	163.52	19.87	4.19	3.36				
VMJH	21:23	1.00	5.69	172.70	20.83	5.09	3.73				
VMJH	21:53	1.50	5.60	175.65	21.92	5.33	3.64				
VMJH	22:21	1.68	5.57	174.94	20.91	4.98	3.75				
VMZ		1.58	4.91	162.03	19.63	4.38	3.37				

# Valori inregistrate MIR-IS HP-1500

Data:19/07/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	100	400/200	50		10	20/10	10	60/10
VMJH	07:29	1.60	5.58	176.67	22.16	5.47	3.70					
VMJH	07:59	0.63	5.69	175.46	20.77	5.06	3.52					
VMJH	08:29	0.83	5.49	175.72	21.92	5.25	3.56					
VMJH	08:59	1.07	5.66	175.56	21.38	4.93	3.58					
VMJH	09:29	1.23	5.67	176.12	22.45	5.42	3.60					
VMJH	09:59	0.80	5.85	173.29	21.14	5.21	3.64					
VMJH	10:29	1.90	6.12	176.04	20.69	5.08	3.47					
VMJH	10:59	0.10	5.31	176.05	20.86	5.12	3.64					
VMJH	11:29	0.93	5.88	177.15	20.88	5.30	3.63					
VMJH	11:59	1.23	5.12	176.82	21.60	5.27	3.59					
VMJH	12:29	1.03	5.85	173.34	21.41	5.42	3.66					
VMJH	12:59	1.17	5.55	171.77	20.56	5.46	3.63					
VMJH	13:29	1.03	5.63	174.61	21.92	4.98	3.60					
VMJH	13:59	1.40	5.33	171.83	21.66	5.51	3.71					
VMJH	14:29	1.70	5.54	174.98	21.51	5.38	3.55					
VMJH	14:59	2.20	5.47	175.01	21.55	5.36	3.56					
VMJH	15:29	1.50	5.05	175.53	20.69	5.30	3.64					
VMJH	15:59	1.97	5.89	174.94	21.39	5.33	3.64					
VMJH	16:29	1.63	5.52	173.60	21.16	5.47	3.65					
VMJH	16:59	1.83	5.48	175.35	21.35	4.91	3.58					
VMJH	17:29	1.70	5.78	175.76	21.48	5.16	3.52					
VMJH	17:59	0.93	5.99	175.85	20.70	5.27	3.60					
VMJH	18:29	1.63	5.53	173.92	21.41	5.19	3.66					
VMJH	18:59	1.90	5.26	174.50	21.08	5.34	3.62					
VMJH	19:29	1.93	5.66	172.48	21.92	5.36	3.51					
VMJH	19:59	0.80	5.25	173.90	21.04	5.33	3.57					
VMJH	20:29	1.10	6.44	174.99	21.47	4.91	3.59					
VMJH	20:59	2.37	5.87	176.20	21.13	5.15	3.60					
VMJH	21:29	1.33	5.98	175.37	21.24	5.09	3.60					
VMJH	21:59	1.20	5.46	176.55	21.39	5.17	3.45					
VMJH	22:24	1.52	4.92	174.01	21.43	5.19	3.59					
VMZ		1.36	5.61	174.95	21.33	5.24	3.60					

# Valori inregistrate MIR-IS HP-1500

Data:20/07/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	07:29	1.13	5.70	177.82	20.42	5.07	3.66				
VMJH	07:59	1.63	5.72	176.66	21.08	4.74	3.71				
VMJH	08:29	2.10	5.78	173.69	21.09	5.41	3.60				
VMJH	08:59	1.03	5.84	175.41	20.87	5.49	3.59				
VMJH	09:29	1.57	5.48	176.16	20.94	5.33	3.67				
VMJH	09:59	1.17	6.01	173.79	21.75	5.48	3.58				
VMJH	10:29	2.03	5.18	173.20	21.99	4.90	3.69				
VMJH	10:59	1.20	5.63	174.62	21.39	5.17	3.59				
VMJH	11:29	1.57	5.03	175.01	21.39	5.20	3.62				
VMJH	11:59	0.77	5.87	173.57	21.07	5.04	3.60				
VMJH	12:29	0.87	5.68	174.00	21.37	5.36	3.50				
VMJH	12:59	0.73	4.94	177.98	21.56	5.05	3.56				
VMJH	13:29	1.23	5.76	176.38	20.89	5.47	3.68				
VMJH	13:59	3.07	5.80	178.79	21.78	4.67	3.66				
VMJH	14:29	1.90	3.55	145.68	17.10	3.54	2.88				
VMJH	14:59	1.40	3.84	142.73	17.09	3.19	2.98				
VMJH	15:29	1.60	3.99	141.73	17.11	3.17	2.96				
VMJH	15:59	0.63	3.70	141.45	17.59	3.42	3.02				
VMJH	16:29	1.77	3.91	142.93	17.21	3.34	2.99				
VMJH	16:59	1.10	3.41	140.45	17.29	3.12	2.88				
VMJH	17:29	0.77	3.97	143.32	17.50	3.08	2.78				
VMJH	17:59	0.87	3.66	142.07	16.97	3.24	3.02				
VMJH	18:29	1.40	3.56	142.70	16.66	3.23	2.99				
VMJH	18:59	1.07	3.70	142.98	16.96	2.98	2.88				
VMJH	19:29	0.83	3.51	141.04	17.50	3.12	2.87				
VMJH	19:59	2.40	3.97	143.25	16.70	3.23	3.02				
VMJH	20:29	1.93	4.19	143.62	17.23	3.13	2.85				
VMJH	20:59	1.50	3.87	140.83	17.27	3.22	2.87				
VMJH	21:29	0.87	4.07	142.81	17.35	3.01	2.94				
VMJH	21:59	1.43	3.71	142.89	17.40	3.23	2.94				
VMJH	22:29	0.80	3.63	142.60	16.78	3.30	2.91				
VMJH	22:42	2.54	3.68	139.94	17.11	3.04	3.15				
VMZ		1.38	4.59	157.17	18.98	4.08	3.24				



# Valori inregistrate MIR-IS HP-1500

Data:21/07/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.87	3.74	142.72	16.67	3.22	3.00						
VMJH	07:59	1.20	3.98	141.04	17.25	3.25	2.95						
VMJH	08:29	1.03	3.53	142.49	17.05	3.34	2.91						
VMJH	08:59	2.33	3.89	141.50	17.06	3.22	2.87						
VMJH	09:29	1.20	4.13	139.06	16.93	3.17	2.92						
VMJH	09:59	2.43	3.78	143.17	16.72	3.10	2.89						
VMJH	10:29	2.00	3.65	142.08	17.10	3.36	2.81						
VMJH	10:59	2.00	3.97	143.61	17.48	3.02	2.90						
VMJH	11:29	2.17	3.22	141.36	17.50	3.26	2.88						
VMJH	11:59	2.27	3.42	142.54	17.31	3.22	2.80						
VMJH	12:29	2.10	3.41	142.06	16.70	3.20	2.85						
VMJH	12:59	2.03	3.75	143.06	17.30	3.10	3.03						
VMJH	13:29	0.90	3.87	144.59	17.29	3.30	2.89						
VMJH	13:59	1.17	3.28	141.45	16.91	3.12	2.86						
VMJH	14:29	0.93	3.38	143.18	16.95	3.01	2.95						
VMJH	14:59	1.97	4.16	144.73	16.88	3.02	2.87						
VMJH	15:29	0.70	4.53	143.36	17.11	3.13	2.85						
VMJH	15:59	1.40	3.91	140.77	17.20	3.18	2.88						
VMJH	16:29	1.53	3.75	144.33	17.15	3.29	3.00						
VMJH	16:59	0.90	3.66	141.89	17.21	3.21	2.85						
VMJH	17:29	1.00	3.77	142.17	17.44	3.09	3.00						
VMJH	17:59	0.60	4.28	142.85	17.16	3.13	2.93						
VMJH	18:29	1.50	3.69	141.48	16.68	3.13	3.01						
VMJH	18:59	0.80	4.08	143.90	16.87	3.12	2.88						
VMJH	19:29	0.93	3.80	142.64	16.82	3.31	2.90						
VMJH	19:59	1.33	3.82	143.33	17.36	3.21	2.98						
VMJH	20:29	0.67	4.33	140.04	17.00	3.14	2.89						
VMJH	20:59	2.33	4.21	142.90	17.12	3.28	3.00						
VMJH	21:29	1.67	3.99	144.44	17.20	3.23	3.03						
VMJH	21:59	1.00	3.91	143.42	17.83	3.14	2.94						
VMJH	22:20	1.67	3.40	141.86	17.16	3.28	3.01						
VMZ		1.47	3.82	142.52	17.11	3.19	2.92						

# Valori inregistrate MIR-IS HP-1500

Data 24/07/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	15:29	0.63	3.58	141.80	15.82	2.91	3.02
VMJH	15:59	2.03	3.20	139.93	15.67	3.01	3.16
VMJH	16:29	1.40	2.94	141.29	15.56	2.97	3.11
VMJH	16:59	1.23	3.08	140.26	15.76	3.09	3.20
VMJH	17:29	2.33	3.15	140.39	15.75	2.98	3.05
VMJH	17:59	1.37	2.88	138.96	15.73	2.97	3.04
VMJH	18:29	1.23	2.87	140.13	15.80	2.96	3.10
VMJH	18:59	2.10	2.83	138.90	15.76	2.95	3.25
VMJH	19:29	1.37	3.48	140.91	15.55	3.09	3.09
VMJH	19:59	2.13	3.50	140.65	15.93	2.97	3.15
VMJH	20:29	1.23	3.36	140.59	15.62	3.15	3.09
VMJH	20:59	1.17	2.98	137.37	15.71	3.03	3.11
VMJH	21:29	1.40	3.22	139.18	15.95	3.05	3.06
VMJH	21:59	0.77	3.21	139.23	15.76	3.00	3.07
VMJH	22:29	2.13	3.25	140.96	15.59	2.95	3.21
VMJH	22:48	2.11	2.86	143.16	15.54	2.89	3.00
VMZ		1.53	3.16	140.17	15.72	3.00	3.11

# Valori inregistrate MIR-IS HP-1500

Data:25/07/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.90	3.31	141.58	15.61	2.85	3.07						
VMJH	07:59	1.97	2.94	140.36	15.77	2.95	3.07						
VMJH	08:29	1.87	3.10	139.72	15.74	2.99	3.12						
VMJH	08:59	0.33	3.00	140.06	15.78	2.94	3.11						
VMJH	09:29	1.13	3.03	140.60	15.78	3.01	3.18						
VMJH	09:59	2.20	3.07	138.98	15.69	2.81	3.15						
VMJH	10:29	1.60	3.00	140.04	15.81	3.11	3.13						
VMJH	10:59	1.43	4.33	165.99	18.97	4.19	3.61						
VMJH	11:29	1.50	4.38	172.74	19.79	4.57	3.69						
VMJH	11:59	1.53	4.51	173.21	21.11	4.45	3.65						
VMJH	12:29	1.20	3.87	173.93	20.26	4.25	3.69						
VMJH	12:59	2.03	4.47	172.25	20.26	4.65	3.67						
VMJH	13:29	1.27	4.33	173.21	20.33	4.46	3.69						
VMJH	13:59	1.43	4.49	171.62	20.83	4.45	3.63						
VMJH	14:29	1.27	4.94	171.55	19.81	4.78	3.57						
VMJH	14:59	2.07	4.73	172.37	20.88	4.42	3.61						
VMJH	15:29	1.53	4.51	171.96	20.12	4.46	3.73						
VMJH	15:59	2.07	4.76	170.56	20.26	4.32	3.66						
VMJH	16:29	0.00	4.59	174.61	20.74	4.24	3.56						
VMJH	16:59	1.93	4.57	171.84	21.22	4.61	3.67						
VMJH	17:29	1.63	4.23	172.39	20.76	4.57	3.64						
VMJH	17:59	1.23	4.27	171.46	20.85	4.49	3.67						
VMJH	18:29	1.53	4.31	173.28	20.22	4.27	3.74						
VMJH	18:59	0.83	4.54	175.17	20.40	4.41	3.85						
VMJH	19:29	0.87	4.34	174.11	19.75	4.38	3.69						
VMJH	19:59	2.10	4.55	170.06	20.64	4.43	3.71						
VMJH	20:29	1.40	4.20	174.61	20.01	4.46	3.63						
VMJH	20:59	1.43	4.68	173.53	20.31	4.29	3.72						
VMJH	21:29	0.37	4.77	173.45	20.34	4.37	3.55						
VMJH	21:48	2.05	4.35	175.48	20.65	4.38	3.67						
VMZ		1.45	4.14	164.90	19.27	4.08	3.54						



# Valori inregistrate MIR-IS HP-1500

Data:26/07/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	0.17	4.47	171.70	20.22	4.55	3.70					
VMJH	07:59	1.50	4.18	171.45	20.34	4.48	3.68					
VMJH	08:29	1.37	4.48	171.73	20.08	4.32	3.68					
VMJH	08:59	1.13	4.37	174.07	20.83	4.49	3.59					
VMJH	09:29	0.83	4.64	175.05	20.35	4.48	3.66					
VMJH	09:59	1.77	4.35	172.41	20.78	4.58	3.70					
VMJH	10:29	1.67	4.69	173.56	20.08	4.62	3.71					
VMJH	10:59	1.70	4.38	173.38	20.06	4.51	3.73					
VMJH	11:29	0.83	4.09	173.10	20.75	4.54	3.60					
VMJH	11:59	1.57	4.41	173.66	20.63	4.48	3.69					
VMJH	12:29	1.70	4.68	172.47	21.04	4.44	3.67					
VMJH	12:59	1.77	4.21	172.90	20.68	4.46	3.62					
VMJH	13:29	2.10	4.33	173.95	20.33	4.51	3.61					
VMJH	13:59	2.60	4.28	174.38	20.42	4.47	3.61					
VMJH	14:29	2.77	4.46	173.68	20.96	4.51	3.73					
VMJH	14:59	0.67	4.50	172.25	20.71	4.26	3.75					
VMJH	15:29	1.73	4.37	172.62	20.94	4.51	3.75					
VMJH	15:59	1.93	4.46	173.69	20.06	4.50	3.62					
VMJH	16:29	0.93	4.36	173.71	20.68	4.47	3.76					
VMJH	16:59	2.97	4.31	171.04	20.48	4.53	3.73					
VMJH	17:29	1.90	4.56	171.86	20.71	4.41	3.64					
VMJH	17:59	1.67	4.11	175.10	20.88	4.34	3.61					
VMJH	18:29	2.70	4.32	171.90	20.43	4.56	3.65					
VMJH	18:59	1.67	4.62	173.28	20.94	4.43	3.56					
VMJH	19:29	0.97	4.26	173.59	20.57	4.47	3.66					
VMJH	19:59	1.80	4.56	166.79	19.53	4.23	3.51					
VMJH	20:29	1.47	3.90	157.51	17.91	3.73	3.47					
VMJH	20:59	3.10	3.72	156.28	18.03	3.70	3.37					
VMJH	21:29	3.27	3.64	157.31	18.17	3.64	3.37					
VMJH	21:59	2.00	3.69	157.60	17.83	3.77	3.46					
VMJH	22:25	0.15	3.53	155.65	18.32	3.77	3.41					
VMZ		1.70	4.29	170.31	20.13	4.35	3.62					

# Valori inregistrate MIR-IS HP-1500

Data:27/07/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	14:53	1.90	3.86	157.49	18.09	3.74	3.41
VMJH	15:23	3.37	3.95	156.84	17.82	3.69	3.33
VMJH	15:53	1.53	4.03	155.39	18.07	3.86	3.37
VMJH	16:23	3.07	4.01	155.65	18.20	3.60	3.43
VMJH	16:53	1.43	3.81	155.62	17.94	3.63	3.38
VMJH	17:23	1.47	3.91	156.64	18.28	3.55	3.38
VMJH	17:53	2.40	3.77	156.42	18.21	3.70	3.35
VMJH	18:23	1.87	3.59	156.95	18.51	3.86	3.36
VMJH	18:53	1.40	3.83	154.75	18.39	3.76	3.41
VMJH	19:23	1.50	3.96	156.85	17.89	3.68	3.41
VMJH	19:53	3.03	3.81	157.24	17.97	3.66	3.53
VMJH	20:23	3.13	3.90	157.51	17.85	3.77	3.51
VMJH	20:53	2.43	3.68	156.62	17.90	3.64	3.30
VMJH	21:23	3.17	3.85	156.93	18.03	3.75	3.45
VMJH	21:53	3.77	3.69	156.88	17.91	3.75	3.36
VMJH	22:00	1.43	3.84	156.03	17.61	3.72	3.46
VMZ		2.35	3.84	156.51	18.06	3.71	3.40

# Valori inregistrate MIR-IS HP-1500

Data:28/07/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	2.67	4.10	156.64	18.07	3.62	3.30					
VMJH	07:59	2.03	3.80	155.95	18.08	3.63	3.37					
VMJH	08:29	2.70	4.02	155.67	17.97	3.74	3.40					
VMJH	08:59	2.37	3.92	156.61	18.05	3.84	3.45					
VMJH	09:29	2.47	3.87	157.94	17.94	3.75	3.36					
VMJH	09:59	2.20	3.91	157.63	18.25	3.78	3.41					
VMJH	10:29	2.33	3.73	156.85	18.06	3.87	3.43					
VMJH	10:59	3.03	4.00	155.07	18.07	3.71	3.37					
VMJH	11:29	2.87	4.10	157.53	17.90	3.84	3.47					
VMJH	11:59	1.93	3.66	157.31	17.70	3.78	3.39					
VMJH	12:29	0.73	3.50	156.22	18.25	3.76	3.38					
VMJH	12:59	1.67	3.65	156.47	18.41	3.81	3.38					
VMJH	13:29	1.57	3.97	156.77	18.45	3.72	3.29					
VMJH	13:59	1.63	3.81	156.78	18.16	3.75	3.45					
VMJH	14:29	1.30	3.88	156.38	17.94	3.77	3.36					
VMJH	14:59	1.23	3.94	157.26	18.20	3.74	3.31					
VMJH	15:29	1.83	3.84	157.05	18.32	3.72	3.47					
VMJH	15:59	1.00	3.68	156.02	18.31	3.60	3.45					
VMJH	16:29	1.10	3.80	157.25	18.12	3.72	3.51					
VMJH	16:59	1.23	3.87	156.65	17.85	3.70	3.37					
VMJH	17:29	1.43	4.06	157.03	18.06	3.79	3.52					
VMJH	17:59	0.73	3.61	156.06	17.95	3.82	3.35					
VMJH	18:29	1.27	3.94	155.84	18.13	3.65	3.45					
VMJH	18:59	1.23	3.48	157.98	18.34	3.67	3.30					
VMJH	19:29	0.73	3.84	155.80	18.03	3.77	3.29					
VMJH	19:59	1.80	3.86	156.66	18.24	3.70	3.48					
VMJH	20:29	1.87	3.90	156.77	18.10	3.79	3.37					
VMJH	20:59	2.77	4.14	156.48	18.44	3.83	3.45					
VMJH	21:29	3.00	4.00	158.30	18.64	3.99	3.49					
VMJH	21:59	3.20	4.21	161.34	18.54	4.01	3.52					
VMJH	22:17	2.56	4.22	159.97	18.52	4.27	3.43					
VMZ		1.88	3.88	156.94	18.16	3.77	3.41					



# Valori inregistrate MIR-IS HP-1500

Data:31/07/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH 10 30/10	VMA VMJH 50 200/50	VMA VMJH 200 400/200	VMA 50	VMA VMJH 10 20/10	VMA VMJH 10 60/10
VMJH 11:19	2.37	4.02	158.11	18.45	4.25	3.48
VMJH 11:49	2.13	3.86	158.72	18.92	3.89	3.57
VMJH 12:19	2.37	3.93	157.26	18.78	4.12	3.56
VMJH 12:49	3.30	4.06	156.13	18.53	4.08	3.40
VMJH 13:19	3.00	4.29	159.24	18.66	4.04	3.46
VMJH 13:49	3.10	4.03	159.03	18.10	4.07	3.53
VMJH 14:19	1.87	4.07	159.25	18.64	3.83	3.48
VMJH 14:49	2.77	4.13	159.23	18.64	3.97	3.46
VMJH 15:19	3.37	3.97	158.50	19.06	3.97	3.59
VMJH 15:49	2.77	3.92	157.19	18.27	4.27	3.56
VMJH 16:19	2.63	3.96	160.46	18.91	4.01	3.54
VMJH 16:49	2.73	4.37	160.38	18.65	4.14	3.43
VMJH 17:19	2.27	4.13	159.48	18.16	4.08	3.47
VMJH 17:49	2.17	4.02	158.98	18.32	4.03	3.56
VMJH 18:19	1.90	4.08	159.15	18.93	4.15	3.46
VMJH 18:49	2.30	4.27	159.47	18.30	4.16	3.48
VMJH 19:19	2.73	4.19	158.48	18.16	4.09	3.59
VMJH 19:49	2.47	3.96	159.31	18.58	4.12	3.56
VMJH 20:19	2.80	4.36	158.79	18.68	4.11	3.49
VMJH 20:49	2.83	4.13	159.03	18.56	3.96	3.52
VMJH 21:19	2.77	4.14	159.65	18.56	3.98	3.61
VMJH 21:42	1.61	3.81	160.42	18.45	4.15	3.46
VMZ	2.57	4.08	158.90	18.56	4.07	3.51

# Valori inregistrate MIR-IS HP-1500

Data:01/08/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 14:49	2.40	1.98	143.93	17.13	2.93	3.04
VMJH 15:19	2.70	1.98	142.58	16.91	3.05	2.81
VMJH 15:49	2.13	1.95	146.04	17.26	3.15	3.03
VMJH 16:19	2.57	1.96	145.75	17.26	2.90	2.94
VMJH 16:49	3.43	1.92	142.72	17.23	2.85	2.94
VMJH 17:19	2.63	1.99	146.52	17.51	2.89	2.92
VMJH 17:49	3.10	1.88	144.64	16.17	3.04	2.84
VMJH 18:19	2.80	1.94	148.13	16.63	2.96	2.92
VMJH 18:49	2.50	1.99	143.32	18.07	2.80	3.01
VMJH 19:19	2.90	1.88	146.15	17.24	3.04	2.99
VMJH 19:49	3.43	1.94	142.27	18.46	2.95	2.89
VMJH 20:19	2.17	1.97	143.88	17.77	2.88	2.97
VMJH 20:49	1.40	2.02	145.68	17.98	3.16	3.01
VMJH 21:19	1.20	1.92	149.52	18.31	2.86	2.85
VMJH 21:49	1.00	1.97	146.78	17.13	3.07	2.91
VMJH 22:19	2.73	2.11	147.74	17.41	2.99	2.88
VMJH 22:24	2.80	1.95	140.78	17.99	2.66	2.96
VMZ	2.45	1.96	145.30	17.41	2.97	2.93

# Valori inregistrate MIR-IS HP-1500

Data:02/08/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	15:15	2.63		2.04		146.53		18.73		2.97		3.04	
VMJH	15:45	3.00		1.96		149.79		17.23		2.90		2.92	
VMJH	16:15	2.27		1.94		148.51		17.12		2.90		3.04	
VMJH	16:45	2.53		2.01		144.88		17.22		2.99		2.99	
VMJH	17:15	2.47		2.02		144.17		16.59		2.99		2.99	
VMJH	17:45	2.47		1.93		143.91		17.02		3.14		2.99	
VMJH	18:15	2.70		2.00		146.78		17.37		2.98		3.02	
VMJH	18:45	1.43		1.90		145.39		16.88		2.91		2.90	
VMJH	19:15	2.70		1.99		143.51		18.47		2.99		2.88	
VMJH	19:45	2.90		1.97		144.22		17.48		2.86		3.00	
VMJH	20:15	2.50		1.98		147.32		17.45		2.83		2.94	
VMJH	20:45	2.43		1.96		143.24		16.76		2.87		2.97	
VMJH	21:15	2.63		2.00		151.70		17.38		2.99		2.99	
VMJH	21:45	1.73		1.97		148.87		16.94		3.01		2.85	
VMJH	22:15	2.03		2.01		147.48		17.38		2.96		2.98	
VMJH	22:24	3.00		1.97		141.38		17.21		2.95		2.70	
VMZ		2.44		1.98		146.31		17.33		2.95		2.96	



# Valori inregistrate MIR-IS HP-1500

Data:03/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	14:55	2.03	1.91	144.54	18.61	2.97	2.86
VMJH	15:25	2.40	1.93	142.20	17.19	2.96	3.14
VMJH	15:55	2.93	1.92	145.76	17.29	2.93	3.00
VMJH	16:25	2.13	1.99	137.64	16.70	3.03	2.82
VMJH	16:55	2.47	1.99	144.75	17.10	3.22	2.97
VMJH	17:25	1.83	1.90	150.56	17.35	2.95	2.95
VMJH	17:55	2.97	1.87	147.99	18.21	2.94	3.02
VMJH	18:25	2.80	1.88	149.03	17.16	2.92	2.88
VMJH	18:55	2.17	1.99	150.24	17.36	3.10	3.08
VMJH	19:25	2.23	1.94	147.24	18.76	2.99	2.93
VMJH	19:55	2.33	1.93	147.66	17.87	2.91	2.86
VMJH	20:25	1.70	1.80	147.75	16.48	2.80	3.07
VMJH	20:55	1.57	2.04	144.12	17.15	2.92	2.98
VMJH	21:25	1.20	1.89	146.89	17.59	3.02	2.84
VMJH	21:55	0.93	1.86	147.22	17.17	3.00	2.95
VMJH	22:20	1.92	1.96	147.57	17.31	2.96	3.02
VMZ		2.10	1.92	146.31	17.46	2.98	2.96

# Valori inregistrate MIR-IS HP-1500

Data:04/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	2.37	2.68	151.62	19.20	3.32	3.14
VMJH	07:59	3.37	4.33	165.48	21.17	4.12	3.63
VMJH	08:29	3.13	4.44	166.17	21.98	4.19	3.65
VMJH	08:59	2.77	4.20	166.30	21.32	4.14	3.69
VMJH	09:29	4.37	4.36	166.05	21.56	4.10	3.67
VMJH	09:59	4.30	4.29	166.76	20.69	4.27	3.68
VMJH	10:29	2.57	4.38	165.96	20.55	4.12	3.62
VMJH	10:59	2.33	3.97	166.63	20.63	4.17	3.50
VMJH	11:29	2.17	3.75	166.29	20.78	4.15	3.65
VMJH	11:59	1.87	4.15	166.21	21.01	4.06	3.60
VMJH	12:29	2.37	4.14	166.30	21.11	4.22	3.61
VMJH	12:59	1.67	4.17	165.80	20.92	4.24	3.56
VMJH	13:29	3.23	3.94	165.25	21.40	4.18	3.59
VMJH	13:59	3.23	4.00	166.06	21.60	4.09	3.55
VMJH	14:29	3.33	4.36	164.74	21.19	4.14	3.81
VMJH	14:59	3.27	4.49	165.10	21.28	4.23	3.63
VMJH	15:29	2.43	4.16	166.15	20.73	4.27	3.55
VMJH	15:59	3.13	4.19	166.10	21.78	4.22	3.65
VMJH	16:29	2.80	4.32	164.84	21.15	4.09	3.61
VMJH	16:59	3.53	4.10	165.80	21.14	4.11	3.48
VMJH	17:29	3.20	4.20	165.81	21.19	4.10	3.61
VMJH	17:59	2.63	4.42	165.03	20.79	4.25	3.76
VMJH	18:29	2.77	4.26	166.68	21.64	4.15	3.71
VMJH	18:59	2.80	4.47	165.71	21.64	4.19	3.69
VMJH	19:29	2.60	3.77	166.55	20.56	4.01	3.61
VMJH	19:59	2.37	4.50	165.40	21.28	4.16	3.69
VMJH	20:29	2.40	4.12	165.80	21.25	4.12	3.62
VMJH	20:59	2.30	4.15	165.71	21.77	4.19	3.47
VMJH	21:29	1.27	4.26	165.40	21.37	4.17	3.68
VMJH	21:59	2.13	4.03	165.22	21.66	4.07	3.69
VMJH	22:14	0.00	4.23	167.30	20.20	4.17	3.69
VMZ		2.71	4.15	165.40	21.13	4.13	3.61

# Valori inregistrate MIR-IS HP-1500

Data:07/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	11:01	2.13	4.73	165.26	22.15	4.13	3.66
VMJH	11:31	0.90	4.53	165.81	21.89	4.05	3.70
VMJH	12:01	1.50	4.17	164.87	21.53	4.16	3.63
VMJH	12:31	1.80	4.24	166.72	21.36	4.15	3.64
VMJH	13:01	1.67	4.25	165.29	21.84	4.18	3.62
VMJH	13:31	1.67	3.99	166.17	21.13	4.17	3.66
VMJH	14:01	0.60	4.16	166.18	21.99	4.18	3.63
VMJH	14:31	1.70	4.23	165.95	21.12	4.19	3.55
VMJH	15:01	0.33	4.39	166.52	21.76	4.08	3.63
VMJH	15:31	2.17	4.42	167.17	21.19	4.14	3.64
VMJH	16:01	1.87	4.40	164.93	20.62	4.07	3.67
VMJH	16:31	2.20	3.98	166.44	20.98	4.09	3.57
VMJH	17:01	1.33	4.12	164.97	21.42	4.13	3.64
VMJH	17:31	1.87	4.37	166.83	21.82	4.13	3.76
VMJH	18:01	2.27	3.87	166.03	21.36	4.19	3.73
VMJH	18:31	1.43	4.06	164.38	21.33	4.20	3.67
VMJH	19:01	0.40	4.36	165.95	21.54	4.20	3.63
VMJH	19:31	1.77	3.96	165.04	22.11	4.04	3.63
VMJH	20:01	0.80	3.46	157.13	20.26	3.71	3.38
VMJH	20:29	1.89	3.04	155.59	19.31	3.52	3.32
VMZ		1.51	4.14	164.89	21.34	4.09	3.62



# Valori inregistrate MIR-IS HP-1500

Data:08/08/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3		
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH		
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	15:02	1.73	3.08	157.03	19.69	3.59	3.30				
VMJH	15:32	0.77	3.12	157.49	19.21	3.54	3.32				
VMJH	16:02	1.97	3.00	153.29	19.29	3.55	3.32				
VMJH	16:32	1.60	3.11	156.58	19.33	3.62	3.26				
VMJH	17:02	1.53	3.25	157.20	18.44	3.56	3.23				
VMJH	17:32	1.23	3.09	156.37	19.10	3.58	3.27				
VMJH	18:02	1.60	3.18	156.92	18.94	3.57	3.30				
VMJH	18:32	0.90	3.04	155.75	19.38	3.61	3.22				
VMJH	19:02	1.00	2.83	155.91	19.12	3.58	3.28				
VMJH	19:32	1.63	3.11	156.99	19.47	3.69	3.28				
VMJH	20:02	1.63	3.16	154.58	19.21	3.50	3.28				
VMJH	20:32	0.77	2.98	160.19	19.85	3.59	3.29				
VMJH	21:02	2.17	3.17	154.79	18.63	3.56	3.39				
VMJH	21:32	1.03	3.20	156.18	19.57	3.69	3.21				
VMJH	22:02	1.07	3.13	157.19	18.89	3.55	3.31				
VMJH	22:32	1.20	3.15	156.15	19.55	3.54	3.24				
VMJH	22:40	0.88	3.35	152.38	18.77	3.35	3.22				
VMZ		1.36	3.10	156.34	19.22	3.58	3.28				

# Valori inregistrate MIR-IS HP-1500

Data:09/08/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	0.47		3.14		157.07		19.02		3.63		3.15	
VMJH	07:59	1.23		3.24		156.49		19.54		3.53		3.29	
VMJH	08:29	0.20		3.01		155.61		18.67		3.63		3.29	
VMJH	08:59	1.20		3.14		155.93		19.45		3.60		3.37	
VMJH	09:29	1.23		3.23		156.10		18.82		3.56		3.34	
VMJH	09:59	1.30		2.97		154.61		19.59		3.58		3.27	
VMJH	10:29	1.13		3.07		156.83		18.67		3.57		3.30	
VMJH	10:59	1.53		3.25		155.87		19.81		3.51		3.31	
VMJH	11:29	1.57		3.05		155.28		19.19		3.60		3.30	
VMJH	11:59	2.23		3.05		155.38		19.54		3.56		3.20	
VMJH	12:29	1.43		3.04		156.67		19.39		3.42		3.31	
VMJH	12:59	1.40		2.89		155.04		18.75		3.59		3.32	
VMJH	13:29	2.17		3.07		154.52		19.84		3.59		3.33	
VMJH	13:59	1.27		3.06		153.93		20.07		3.58		3.35	
VMJH	14:29	2.17		3.14		155.63		19.16		3.55		3.27	
VMJH	14:59	1.17		3.17		157.44		19.31		3.60		3.32	
VMJH	15:29	1.10		2.81		154.65		19.67		3.59		3.32	
VMJH	15:59	2.23		3.15		156.35		18.91		3.62		3.23	
VMJH	16:29	0.90		3.15		157.50		18.74		3.65		3.30	
VMJH	16:59	1.03		3.20		155.29		19.03		3.53		3.30	
VMJH	17:29	2.73		3.01		154.96		19.37		3.53		3.21	
VMJH	17:59	1.10		3.14		157.47		18.31		3.53		3.31	
VMJH	18:29	1.27		3.00		154.70		19.58		3.54		3.36	
VMJH	18:59	1.87		3.19		156.54		18.96		3.47		3.32	
VMJH	19:29	1.53		3.05		156.33		19.81		3.50		3.29	
VMJH	19:59	1.50		3.24		153.02		19.10		3.49		3.31	
VMJH	20:29	1.03		2.91		155.88		19.30		3.66		3.38	
VMJH	20:59	1.53		3.05		155.51		19.25		3.61		3.34	
VMJH	21:29	1.37		2.90		159.83		19.68		3.51		3.20	
VMJH	21:40	1.45		2.99		155.07		19.96		3.57		3.24	
VMZ		1.41		3.08		155.87		19.27		3.56		3.30	

# Valori inregistrate MIR-IS HP-1500

Data:10/08/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	12:09	1.10	3.42	157.72	20.67	3.46	3.27				
VMJH	12:39	1.40	3.63	164.13	20.53	3.33	3.33				
VMJH	13:09	1.10	3.68	164.37	20.44	3.39	3.33				
VMJH	13:39	1.63	3.55	163.99	20.86	3.35	3.36				
VMJH	14:09	0.77	3.60	164.53	20.10	3.33	3.20				
VMJH	14:39	1.63	3.70	163.85	20.03	3.31	3.29				
VMJH	15:09	1.53	3.73	164.11	21.05	3.34	3.38				
VMJH	15:39	1.10	3.65	163.76	20.63	3.30	3.31				
VMJH	16:09	1.93	3.69	162.63	20.22	3.35	3.25				
VMJH	16:39	0.67	3.60	163.89	19.69	3.26	3.22				
VMJH	17:09	1.23	3.70	163.76	20.22	3.27	3.31				
VMJH	17:39	1.83	3.58	163.53	20.87	3.33	3.31				
VMJH	18:09	1.27	3.58	163.42	20.18	3.34	3.33				
VMJH	18:39	1.73	3.60	163.50	21.03	3.37	3.38				
VMJH	19:09	1.30	3.65	163.71	20.57	3.31	3.29				
VMJH	19:39	2.43	3.61	163.82	20.68	3.33	3.28				
VMJH	20:09	2.33	3.59	162.69	20.56	3.37	3.32				
VMJH	20:39	2.17	3.62	163.50	20.25	3.33	3.40				
VMJH	21:09	1.57	3.65	163.76	20.60	3.33	3.30				
VMJH	21:39	2.07	3.66	164.72	20.76	3.34	3.36				
VMJH	22:09	1.60	3.56	163.40	20.71	3.38	3.27				
VMJH	22:39	1.43	3.60	161.52	19.70	3.31	3.30				
VMJH	22:48	2.67	3.59	165.45	20.55	3.38	3.31				
VMZ		1.55	3.62	163.41	20.47	3.34	3.31				



# Valori inregistrate MIR-IS HP-1500

Data:11/08/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.83	3.63	163.81	20.16	3.35	3.32
VMJH	07:59	1.77	3.71	162.98	20.47	3.27	3.28
VMJH	08:29	0.73	3.65	163.28	20.25	3.31	3.28
VMJH	08:59	1.33	3.54	163.77	20.14	3.35	3.37
VMJH	09:29	1.20	3.55	162.69	20.61	3.36	3.33
VMJH	09:59	1.27	3.61	164.41	20.35	3.36	3.35
VMJH	10:29	0.90	3.57	164.35	20.58	3.34	3.38
VMJH	10:59	1.20	3.67	164.67	20.46	3.33	3.42
VMJH	11:29	0.63	3.60	162.20	20.29	3.29	3.29
VMJH	11:59	1.83	3.66	163.15	20.85	3.34	3.32
VMJH	12:29	0.90	3.68	163.10	19.94	3.32	3.30
VMJH	12:59	1.70	3.73	163.60	20.19	3.35	3.37
VMJH	13:29	1.83	3.67	163.98	20.72	3.37	3.32
VMJH	13:59	2.23	3.57	164.43	20.21	3.36	3.32
VMJH	14:29	1.93	3.58	162.91	20.83	3.27	3.35
VMJH	15:00	1.00	3.56	162.47	20.42	3.32	3.42
VMZ		1.39	3.62	163.49	20.41	3.33	3.34

# Valori inregistrate MIR-IS HP-1500

Data:14/08/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	11:29	2.30	3.66	165.67	20.55	3.38	3.36					
VMJH	11:59	2.07	3.56	166.63	20.36	3.34	3.34					
VMJH	12:29	1.17	3.62	162.73	20.62	3.28	3.32					
VMJH	12:59	1.57	3.65	162.88	20.48	3.34	3.23					
VMJH	13:29	1.83	3.63	163.03	19.76	3.30	3.35					
VMJH	13:59	1.30	3.61	164.79	20.52	3.32	3.35					
VMJH	14:29	1.20	3.63	163.34	20.23	3.34	3.31					
VMJH	14:59	1.67	3.75	162.42	20.40	3.41	3.33					
VMJH	15:29	1.70	3.60	164.24	21.05	3.29	3.19					
VMJH	15:59	0.57	3.63	164.26	20.83	3.31	3.27					
VMJH	16:29	1.00	4.76	169.79	22.01	3.72	3.51					
VMJH	16:59	1.00	5.39	169.99	21.10	3.97	3.72					
VMJH	17:29	1.13	5.32	171.16	21.09	3.89	3.70					
VMJH	17:59	0.80	5.27	170.63	22.22	4.02	3.81					
VMJH	18:29	1.90	5.20	170.71	21.24	3.93	3.82					
VMJH	18:59	0.20	5.50	170.71	20.63	4.00	3.80					
VMJH	19:29	1.00	5.37	169.59	22.03	3.98	3.67					
VMJH	19:59	1.13	5.34	170.06	20.97	3.95	3.66					
VMJH	20:29	1.13	5.43	169.83	21.87	4.02	3.72					
VMJH	20:59	1.10	5.44	171.53	21.84	3.92	3.63					
VMJH	21:29	1.00	5.34	172.30	21.56	3.90	3.81					
VMJH	21:59	1.33	5.29	170.16	21.93	3.93	3.70					
VMJH	22:29	1.73	5.27	170.38	21.28	3.94	3.74					
VMJH	22:48	0.63	5.19	169.98	22.54	4.07	3.82					
VMZ		1.28	4.59	167.75	21.11	3.68	3.54					

# Valori inregistrate MIR-IS HP-1500

Data:15/08/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:13	1.40	5.36	170.54	21.65	4.02	3.62
VMJH	15:43	1.13	5.33	170.75	22.25	3.96	3.63
VMJH	16:13	1.67	5.24	168.42	22.13	3.95	3.63
VMJH	16:43	2.17	5.31	169.52	21.36	3.94	3.72
VMJH	17:13	1.43	5.39	169.53	22.06	3.92	3.68
VMJH	17:43	2.37	5.44	171.65	21.45	3.97	3.71
VMJH	18:13	1.40	5.24	171.39	21.30	4.08	3.85
VMJH	18:43	1.67	5.30	168.02	21.24	4.03	3.70
VMJH	19:13	1.67	5.32	170.76	22.71	4.03	3.80
VMJH	19:43	0.90	5.24	169.86	21.56	4.03	3.76
VMJH	20:13	2.00	5.40	169.19	21.44	3.95	3.75
VMJH	20:43	1.67	5.23	169.88	21.14	3.98	3.76
VMJH	21:13	2.07	5.24	170.38	22.54	3.99	3.68
VMJH	21:43	0.70	5.33	170.38	22.32	3.91	3.67
VMJH	22:13	1.07	5.32	170.99	21.72	3.97	3.65
VMJH	22:43	2.27	5.20	171.98	20.90	3.89	3.78
VMJH	22:48	2.40	5.42	168.50	23.36	3.84	3.75
VMZ		1.61	5.31	170.18	21.75	3.98	3.71



# Valori inregistrate MIR-IS HP-1500

Data:18/08/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 07:29	1.63	5.28	168.25	21.99	3.96	3.62
VMJH 07:59	0.83	5.29	171.47	21.79	4.04	3.71
VMJH 08:29	1.67	5.41	167.39	21.27	3.98	3.82
VMJH 08:59	1.43	5.49	169.12	21.87	3.94	3.69
VMJH 09:29	1.33	5.40	169.79	21.47	3.97	3.67
VMJH 09:59	2.17	5.33	169.75	21.80	3.94	3.67
VMJH 10:29	0.90	5.14	169.15	21.63	4.09	3.76
VMJH 10:59	1.70	5.20	170.09	21.58	3.89	3.88
VMJH 11:29	1.00	5.27	169.75	22.39	3.93	3.59
VMJH 11:59	2.17	5.20	171.90	22.09	3.90	3.69
VMJH 12:29	1.07	5.36	169.39	21.47	3.99	3.70
VMJH 12:59	1.77	5.25	170.11	21.35	3.92	3.78
VMJH 13:29	0.70	5.46	169.08	21.77	4.02	3.60
VMJH 13:59	0.90	5.20	170.00	22.32	4.00	3.70
VMJH 14:29	0.97	5.35	171.02	21.73	4.02	3.70
VMJH 14:59	1.33	5.50	168.56	21.60	3.93	3.75
VMJH 15:29	2.53	5.38	171.25	21.78	3.97	3.62
VMJH 15:59	2.33	5.34	170.05	21.33	3.95	3.71
VMJH 16:29	1.20	3.62	165.83	20.50	3.27	3.36
VMJH 16:59	2.07	1.92	157.14	19.62	2.67	2.95
VMJH 17:29	0.77	1.97	157.93	19.28	2.65	2.84
VMJH 17:59	1.13	1.90	158.02	19.24	2.69	2.78
VMJH 18:29	1.63	1.99	158.07	19.39	2.66	2.92
VMJH 18:59	0.97	1.93	156.87	19.54	2.68	2.99
VMJH 19:29	0.77	1.99	158.43	18.65	2.66	2.99
VMJH 19:59	1.10	1.98	156.48	19.20	2.65	2.95
VMJH 20:29	1.03	1.99	155.61	18.91	2.74	2.85
VMJH 20:59	1.27	1.89	157.35	19.79	2.68	2.87
VMJH 21:29	1.50	1.91	156.35	19.35	2.67	2.90
VMJH 21:59	2.33	1.85	155.67	20.01	2.73	3.12
VMJH 22:29	1.70	1.95	156.55	18.96	2.72	2.85
VMJH 23:00	0.87	1.97	156.53	19.54	2.76	2.95
VMZ	1.40	3.89	164.46	20.72	3.43	3.37

# Valori inregistrate MIR-IS HP-1500

Data:21/08/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	13:29	1.17	1.94	156.13	19.09	2.79	2.90
VMJH	13:59	1.40	1.92	157.91	19.36	2.61	2.78
VMJH	14:29	1.40	1.88	155.96	19.23	2.67	2.90
VMJH	14:59	1.80	1.92	159.12	19.16	2.67	2.85
VMJH	15:29	1.27	1.91	157.56	20.46	2.68	2.97
VMJH	15:59	1.07	1.88	157.20	19.29	2.64	3.02
VMJH	16:29	2.30	1.90	156.24	19.05	2.78	2.87
VMJH	16:59	1.23	1.91	155.21	19.66	2.75	2.85
VMJH	17:29	2.47	1.92	157.31	19.08	2.74	2.87
VMJH	17:59	1.97	2.08	156.93	19.31	2.59	3.05
VMJH	18:29	2.10	1.99	156.64	19.70	2.71	2.82
VMJH	18:59	1.93	1.92	157.30	19.16	2.70	2.89
VMJH	19:29	2.30	1.79	155.78	19.24	2.78	2.83
VMJH	19:59	2.07	1.92	155.87	19.09	2.64	3.01
VMJH	20:29	2.03	1.90	159.36	19.17	2.75	3.01
VMJH	20:59	0.90	2.01	157.38	19.32	2.67	3.00
VMJH	21:29	1.13	1.88	157.64	19.39	2.64	2.83
VMJH	21:59	0.97	1.98	155.11	18.81	2.63	2.81
VMJH	22:29	1.97	2.03	157.87	18.64	2.75	2.91
VMJH	22:43	0.14	2.03	157.71	19.96	2.58	2.92
VMZ		1.62	1.93	156.99	19.29	2.69	2.90

# Valori inregistrate MIR-IS HP-1500

Data:23/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.30	1.98	157.14	18.94	2.62	2.86
VMJH	07:59	1.40	1.92	158.65	19.37	2.68	2.81
VMJH	08:29	0.97	1.85	158.27	19.17	2.71	2.88
VMJH	08:59	1.03	1.96	156.28	19.82	2.64	3.14
VMJH	09:29	1.13	1.93	158.47	19.44	2.67	2.95
VMJH	09:59	0.93	2.05	160.65	18.76	2.68	2.98
VMJH	10:29	0.87	1.89	159.31	19.83	2.70	3.01
VMJH	10:59	1.00	1.94	156.08	18.87	2.72	2.76
VMJH	11:29	1.07	1.96	155.25	20.04	2.68	2.84
VMJH	11:59	1.10	1.94	159.30	19.59	2.65	2.94
VMJH	12:29	1.73	1.91	157.72	19.44	2.73	2.95
VMJH	12:59	2.07	1.91	156.95	19.03	2.73	2.78
VMJH	13:29	1.37	1.95	156.39	19.70	2.66	2.95
VMJH	13:59	1.37	1.87	157.22	18.93	2.60	2.94
VMJH	14:29	0.53	1.93	156.17	19.68	2.73	2.88
VMJH	14:59	2.07	2.28	159.43	20.11	2.58	2.91
VMJH	15:29	1.17	2.17	160.45	19.99	2.59	2.96
VMJH	15:59	1.53	2.26	161.70	20.24	2.59	2.90
VMJH	16:29	2.07	2.23	159.32	20.31	2.50	3.01
VMJH	16:59	1.57	2.07	159.43	19.71	2.61	2.92
VMJH	17:29	0.93	2.13	160.64	20.39	2.53	2.92
VMJH	17:59	2.37	2.17	159.10	20.21	2.57	2.98
VMJH	18:29	1.13	2.31	158.72	19.85	2.55	2.92
VMJH	18:59	2.23	2.13	160.67	19.89	2.64	2.96
VMJH	19:29	1.47	2.37	160.08	20.30	2.68	2.96
VMJH	19:59	2.03	2.35	159.37	20.19	2.50	2.91
VMJH	20:29	1.63	2.22	159.32	19.66	2.61	2.84
VMJH	20:59	1.03	2.05	161.63	21.15	2.64	3.08
VMJH	21:29	1.80	2.27	160.90	19.80	2.56	3.13
VMJH	21:59	0.60	2.23	159.18	20.18	2.51	2.87
VMJH	22:30	2.00	2.01	160.38	20.57	2.52	2.96
VMZ		1.40	2.07	158.85	19.78	2.62	2.93



# Valori inregistrate MIR-IS HP-1500

Data:24/08/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	15:01	1.50	2.13	160.21	20.42	2.61	2.89
VMJH	15:31	1.33	2.26	160.81	20.27	2.62	2.98
VMJH	16:01	2.13	2.07	160.91	20.22	2.61	2.94
VMJH	16:31	1.80	2.28	160.76	20.12	2.52	3.08
VMJH	17:01	0.77	2.25	158.83	19.86	2.57	2.89
VMJH	17:31	2.13	2.16	158.91	20.56	2.62	2.95
VMJH	18:01	1.13	2.08	159.43	19.94	2.55	2.93
VMJH	18:31	1.80	2.23	157.62	19.65	2.51	2.98
VMJH	19:01	1.70	2.25	159.68	20.18	2.57	2.87
VMJH	19:31	1.30	2.32	159.63	19.81	2.59	2.92
VMJH	20:01	1.27	2.20	159.42	20.06	2.58	2.96
VMJH	20:31	1.30	2.24	159.91	20.31	2.59	3.09
VMJH	21:01	1.13	2.27	160.36	20.44	2.56	2.92
VMJH	21:31	1.63	2.22	159.25	20.02	2.60	2.87
VMJH	22:01	2.47	2.32	159.70	19.65	2.56	3.06
VMJH	22:19	2.22	2.29	161.27	20.33	2.62	3.02
VMZ		1.59	2.22	159.76	20.11	2.58	2.96

# Valori inregistrate MIR-IS HP-1500

Data:25/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:49	1.93	2.22	160.25	19.81	2.60	2.94
VMJH	08:19	1.17	2.30	159.38	20.55	2.61	3.03
VMJH	08:49	1.63	2.27	158.03	19.90	2.58	2.93
VMJH	09:19	0.87	2.20	161.75	20.22	2.63	2.99
VMJH	09:49	1.67	2.16	160.71	20.67	2.56	3.07
VMJH	10:19	1.10	2.09	160.10	20.09	2.53	2.92
VMJH	10:49	2.03	2.34	161.11	20.28	2.62	2.97
VMJH	11:19	0.93	2.23	159.47	20.31	2.57	3.07
VMJH	11:49	2.40	2.25	160.35	19.80	2.53	2.97
VMJH	12:19	1.50	2.38	159.96	19.50	2.61	2.89
VMJH	12:49	2.47	2.21	159.12	20.21	2.63	3.07
VMJH	13:19	1.27	2.25	159.94	20.09	2.65	2.92
VMJH	13:49	2.03	2.26	160.08	20.17	2.60	3.05
VMJH	14:19	2.13	2.22	162.47	19.77	2.52	2.97
VMJH	14:49	1.87	2.20	160.63	20.35	2.55	2.85
VMJH	15:19	2.47	2.17	160.20	20.18	2.60	2.90
VMJH	15:49	2.43	4.17	166.08	20.53	3.37	3.57
VMJH	16:19	1.37	5.17	170.34	22.04	3.93	3.81
VMJH	16:49	1.57	5.33	170.17	21.56	3.86	3.74
VMJH	17:19	2.17	5.43	171.40	21.38	3.83	3.71
VMJH	17:49	2.07	5.39	170.99	21.53	3.89	3.70
VMJH	18:19	2.43	5.31	170.34	21.88	3.90	3.86
VMJH	18:49	2.00	5.41	170.78	21.32	3.81	3.70
VMJH	19:19	2.33	5.27	169.91	21.99	3.92	3.67
VMJH	19:49	1.37	5.34	169.95	21.59	3.96	3.67
VMJH	20:19	1.40	5.40	171.46	20.92	3.93	3.64
VMJH	20:49	1.50	5.24	170.89	22.23	3.90	3.74
VMJH	21:19	0.63	5.25	169.98	21.53	3.86	3.68
VMJH	21:49	1.67	5.39	171.63	22.19	3.88	3.72
VMJH	22:21	2.25	5.44	169.22	22.07	3.87	3.68
VMZ		1.76	3.65	164.90	20.83	3.18	3.31

# Valori inregistrate MIR-IS HP-1500

Data:28/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	11:29	0.80	5.41	171.15	21.66	3.79	3.76
VMJH	11:59	1.13	5.30	168.68	22.07	3.88	3.64
VMJH	12:29	0.83	5.36	169.28	21.34	3.90	3.76
VMJH	12:59	1.13	5.28	170.76	21.28	3.84	3.83
VMJH	13:29	1.10	5.29	169.91	21.66	3.84	3.77
VMJH	13:59	1.27	5.35	171.99	22.03	3.87	3.77
VMJH	14:29	0.93	5.42	170.09	21.31	3.85	3.85
VMJH	14:59	0.97	5.35	169.79	21.64	3.85	3.68
VMJH	15:29	1.27	5.27	170.22	22.43	3.86	3.70
VMJH	15:59	0.87	5.40	169.08	21.19	3.84	3.64
VMJH	16:29	1.07	5.21	170.24	21.62	3.88	3.83
VMJH	16:59	1.20	5.28	171.70	22.42	3.90	3.74
VMJH	17:29	1.47	5.36	169.62	21.63	3.89	3.60
VMJH	17:59	1.73	5.23	171.67	22.12	3.86	3.81
VMJH	18:29	1.93	5.33	171.16	22.57	3.87	3.78
VMJH	18:59	2.13	5.32	169.89	21.57	3.93	3.65
VMJH	19:29	1.10	5.36	169.83	21.29	3.88	3.66
VMJH	19:59	1.17	5.34	171.31	21.43	3.87	3.77
VMJH	20:29	1.67	5.35	170.20	21.82	3.87	3.81
VMJH	20:59	1.07	5.36	171.08	22.16	3.95	3.58
VMJH	21:29	1.33	5.21	169.20	21.51	3.85	3.67
VMJH	21:59	1.80	5.31	168.92	21.58	3.81	3.67
VMJH	22:29	0.77	5.34	170.36	21.08	3.79	3.66
VMJH	22:49	1.85	5.39	171.26	22.13	3.91	3.74
VMZ		1.27	5.32	170.29	21.72	3.87	3.72



# Valori inregistrate MIR-IS HP-1500

Data:30/08/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	0.97	3.66	165.43	20.54	3.20	3.34
VMJH	07:59	0.80	3.88	162.89	20.94	3.17	3.38
VMJH	08:29	0.17	3.70	165.14	20.93	3.22	3.37
VMJH	08:59	0.17	3.75	164.61	20.91	3.24	3.40
VMJH	09:29	0.37	3.70	166.47	21.16	3.24	3.28
VMJH	09:59	0.13	3.74	165.32	20.21	3.18	3.41
VMJH	10:29	0.20	3.83	164.19	21.04	3.21	3.36
VMJH	10:59	0.20	3.76	165.63	21.01	3.27	3.33
VMJH	11:29	0.13	3.77	164.68	20.92	3.20	3.33
VMJH	11:59	1.00	3.75	168.12	20.94	3.20	3.25
VMJH	12:29	1.23	3.88	164.88	21.18	3.23	3.26
VMJH	12:59	0.27	3.88	165.39	21.16	3.19	3.36
VMJH	13:29	0.00	3.86	164.81	20.68	3.26	3.32
VMJH	13:59	0.23	3.74	165.88	20.75	3.21	3.37
VMJH	14:29	0.37	3.74	162.75	21.44	3.22	3.46
VMJH	14:59	0.43	3.81	165.48	20.96	3.24	3.36
VMJH	15:29	0.40	4.45	166.92	21.81	3.51	3.54
VMJH	15:59	0.03	5.32	171.14	21.96	3.83	3.83
VMJH	16:29	1.77	5.32	172.11	22.14	3.88	3.75
VMJH	16:59	0.90	5.43	170.85	21.24	3.84	3.76
VMJH	17:29	0.40	5.44	168.72	22.39	3.93	3.81
VMJH	17:59	0.70	5.40	172.08	21.63	3.88	3.83
VMJH	18:29	0.70	5.21	170.40	21.26	3.91	3.63
VMJH	18:59	1.30	5.37	170.62	21.66	3.87	3.80
VMJH	19:29	1.07	5.39	170.51	22.06	3.85	3.65
VMJH	19:59	1.07	5.30	170.09	22.23	3.90	3.84
VMJH	20:29	0.50	5.24	171.26	21.45	3.88	3.73
VMJH	20:59	1.03	3.80	166.66	21.24	3.82	3.38
VMJH	21:29	0.87	3.38	164.40	20.38	3.86	3.21
VMJH	21:59	0.77	3.29	165.98	21.55	3.82	3.20
VMJH	22:29	0.87	3.37	164.23	20.79	3.73	3.21
VMJH	22:36	1.43	3.36	163.97	21.71	3.90	3.27
VMZ		0.62	4.26	167.00	21.25	3.52	3.47

# Valori inregistrate MIR-IS HP-1500

Data:01/09/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	2.13	1.95	131.63	17.86	2.58	2.94
VMJH	07:59	1.87	1.86	132.11	17.49	2.55	3.09
VMJH	08:29	1.50	2.14	131.92	17.89	2.69	2.83
VMJH	08:59	1.60	1.77	131.30	17.54	2.57	3.03
VMJH	09:29	2.43	1.81	132.43	18.45	2.67	3.07
VMJH	09:59	1.40	1.88	132.43	18.09	2.54	2.94
VMJH	10:29	1.27	1.96	133.05	18.12	2.57	3.12
VMJH	10:59	2.27	1.77	130.52	18.12	2.59	2.93
VMJH	11:29	2.67	1.84	126.89	17.21	2.56	3.00
VMJH	11:59	1.60	1.92	131.84	18.18	2.62	2.89
VMJH	12:29	2.10	1.97	130.99	17.97	2.62	3.00
VMJH	12:59	2.87	1.85	134.28	18.21	2.57	2.93
VMJH	13:29	2.80	1.97	132.49	18.46	2.55	2.99
VMJH	13:59	2.33	1.99	130.83	18.26	2.48	2.95
VMJH	14:29	1.67	1.97	132.78	18.16	2.54	2.90
VMJH	14:59	2.13	1.93	131.38	18.57	2.57	2.81
VMJH	15:29	2.43	1.89	131.11	18.12	2.57	3.05
VMJH	15:59	2.00	1.92	131.89	17.65	2.57	3.03
VMJH	16:29	2.47	1.81	132.47	18.18	2.63	2.95
VMJH	16:59	2.87	1.90	132.54	17.48	2.55	3.07
VMJH	17:29	2.57	1.92	134.03	17.81	2.66	2.87
VMJH	17:59	2.23	1.90	133.10	18.15	2.50	2.94
VMJH	18:29	1.60	1.88	132.95	18.56	2.59	2.83
VMJH	18:59	1.37	1.81	129.96	17.79	2.55	2.86
VMJH	19:29	1.53	1.96	132.13	17.37	2.56	3.10
VMJH	19:59	1.33	1.90	133.26	18.18	2.58	3.04
VMJH	20:29	1.73	2.07	133.58	18.15	2.59	2.78
VMJH	20:59	1.97	1.88	135.52	18.36	2.56	2.87
VMJH	21:29	1.30	1.91	134.03	17.56	2.56	3.00
VMJH	21:59	1.60	1.90	131.87	18.10	2.55	3.01
VMJH	22:29	1.80	1.77	130.79	18.11	2.59	2.95
VMJH	22:36	2.29	1.93	130.62	16.99	2.60	3.01
VMZ		1.98	1.90	132.12	18.00	2.58	2.96



# Valori inregistrate MIR-IS HP-1500

Data:04/09/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	10:29	2.00	1.96	133.00	17.80	2.55	2.85
VMJH	10:59	2.30	1.96	132.05	17.77	2.56	2.94
VMJH	11:29	1.80	1.98	130.95	17.88	2.67	2.91
VMJH	11:59	1.93	1.85	130.67	17.79	2.54	3.01
VMJH	12:29	2.00	1.92	133.06	17.51	2.58	3.01
VMJH	12:59	2.43	1.98	131.27	17.93	2.57	2.97
VMJH	13:29	2.07	1.99	134.71	17.81	2.56	2.94
VMJH	13:59	1.57	1.94	132.80	17.66	2.56	2.84
VMJH	14:29	1.60	1.85	131.62	17.93	2.61	2.86
VMJH	14:59	1.50	2.03	134.76	18.05	2.54	2.98
VMJH	15:29	1.93	1.80	131.73	18.11	2.52	2.99
VMJH	15:59	1.50	1.82	130.93	17.31	2.61	2.98
VMJH	16:29	1.57	1.86	132.64	18.45	2.51	3.02
VMJH	16:59	1.30	1.91	133.47	17.80	2.61	2.92
VMJH	17:29	1.53	1.92	133.03	18.01	2.64	2.93
VMJH	17:59	1.73	1.98	132.69	17.67	2.58	2.87
VMJH	18:29	1.73	2.15	141.73	18.96	2.73	3.09
VMJH	18:59	1.60	3.09	163.77	21.22	3.15	3.58
VMJH	19:29	1.60	3.06	165.80	21.12	3.18	3.61
VMJH	19:59	1.93	3.08	166.71	21.80	3.16	3.40
VMJH	20:29	1.60	3.06	168.36	21.83	3.12	3.56
VMJH	20:59	1.37	3.09	167.14	20.79	3.14	3.48
VMJH	21:29	1.77	3.07	167.05	21.18	3.15	3.58
VMJH	21:59	2.00	3.05	163.69	20.99	3.10	3.53
VMJH	22:31	1.81	3.10	166.92	21.03	3.17	3.49
VMZ		1.77	2.30	143.68	18.98	2.77	3.13



# Valori inregistrate MIR-IS HP-1500

Data:05/09/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	14:59	1.53	3.12	165.33	21.01	3.14	3.52
VMJH	15:29	2.27	3.13	165.12	20.22	3.12	3.61
VMJH	15:59	1.23	3.11	164.71	21.79	3.16	3.50
VMJH	16:29	1.27	3.07	164.65	21.49	3.10	3.59
VMJH	16:59	1.23	3.07	166.61	20.80	3.13	3.43
VMJH	17:29	1.23	3.07	165.48	21.27	3.14	3.49
VMJH	17:59	1.60	3.13	165.82	21.28	3.20	3.50
VMJH	18:29	1.40	3.04	166.49	21.15	3.21	3.52
VMJH	18:59	1.17	3.11	164.51	22.10	3.13	3.50
VMJH	19:29	1.97	3.07	166.24	21.27	3.16	3.54
VMJH	19:59	1.83	3.11	166.64	21.25	3.18	3.55
VMJH	20:29	1.67	3.07	167.44	21.04	3.14	3.47
VMJH	20:59	1.27	3.10	167.63	20.69	3.14	3.50
VMJH	21:29	0.97	3.09	165.53	21.61	3.19	3.55
VMJH	21:59	1.00	3.12	166.04	21.24	3.22	3.53
VMJH	22:30	1.58	3.09	168.63	21.01	3.13	3.52
VMZ		1.45	3.09	166.06	21.20	3.16	3.52

# Valori inregistrate MIR-IS HP-1500

Data:06/09/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	08:04	1.10		3.08		166.16		21.60		3.20		3.46	
VMJH	08:34	1.36		3.10		168.23		21.23		3.14		3.49	
VMJH	09:04	1.21		3.13		164.72		21.61		3.13		3.52	
VMJH	09:34	1.33		3.16		166.21		21.63		3.20		3.57	
VMJH	10:04	1.17		3.11		165.90		20.52		3.19		3.56	
VMJH	10:34	1.33		3.11		164.75		21.13		3.17		3.52	
VMJH	11:04	1.14		3.07		165.97		21.33		3.15		3.51	
VMJH	11:34	1.17		3.01		166.59		21.41		3.09		3.57	
VMJH	12:04	1.55		3.13		165.68		21.03		3.11		3.55	
VMJH	12:34	1.89		3.12		165.65		21.87		3.17		3.47	
VMJH	13:04	2.25		3.09		165.97		21.52		3.11		3.53	
VMJH	13:34	1.10		3.15		167.01		20.68		3.17		3.59	
VMJH	14:04	1.10		3.09		168.04		20.56		3.13		3.58	
VMJH	14:34	1.36		3.11		166.30		20.94		3.18		3.48	
VMJH	15:04	1.33		3.11		165.85		20.36		3.16		3.51	
VMJH	15:34	2.17		3.12		164.18		20.69		3.14		3.58	
VMJH	16:04	1.49		3.04		163.88		21.83		3.17		3.52	
VMJH	16:34	1.40		3.13		165.18		20.68		3.15		3.54	
VMJH	17:04	1.82		3.11		164.03		21.79		3.15		3.54	
VMJH	17:34	1.45		3.17		166.22		20.88		3.11		3.49	
VMJH	18:04	1.34		3.10		164.61		21.69		3.13		3.51	
VMJH	18:34	1.37		3.02		164.53		21.15		3.13		3.57	
VMJH	19:04	1.66		3.10		165.33		20.81		3.14		3.58	
VMJH	19:34	1.25		2.91		160.75		20.04		3.08		3.46	
VMJH	20:04	2.20		2.49		148.94		19.50		2.87		3.25	
VMJH	20:34	1.52		2.54		148.73		19.25		2.90		3.27	
VMJH	21:04	1.50		2.54		148.83		19.99		2.90		3.21	
VMJH	21:34	1.08		2.40		150.28		19.65		2.85		3.24	
VMJH	22:04	1.55		2.49		149.51		19.62		2.89		3.30	
VMJH	22:33	1.59		2.49		150.49		19.37		2.82		3.28	
VMZ		1.46		2.97		162.28		20.81		3.09		3.47	

# Valori inregistrate MIR-IS HP-1500

Data:07/09/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	14:41	1.60	2.45	148.38	19.81	2.84	3.31
VMJH	15:11	1.47	2.48	147.61	19.46	2.86	3.19
VMJH	15:41	1.24	2.50	146.65	19.33	2.87	3.24
VMJH	16:11	1.72	2.50	148.72	19.20	2.88	3.28
VMJH	16:41	1.44	2.52	148.08	19.79	2.89	3.24
VMJH	17:11	1.11	2.50	148.72	19.99	2.81	3.22
VMJH	17:41	1.65	2.53	149.42	19.50	2.84	3.23
VMJH	18:11	1.41	2.52	149.31	19.81	2.82	3.22
VMJH	18:41	1.66	2.52	148.84	19.66	2.87	3.21
VMJH	19:11	1.80	2.49	148.55	19.82	2.88	3.19
VMJH	19:41	1.83	2.54	148.00	20.14	2.87	3.28
VMJH	20:11	1.99	2.46	149.53	19.54	2.87	3.26
VMJH	20:41	1.90	2.48	149.52	19.61	2.89	3.26
VMJH	21:11	1.45	2.50	149.82	19.14	2.86	3.22
VMJH	21:41	1.47	2.49	151.37	19.35	2.88	3.19
VMJH	22:11	1.27	2.48	149.00	19.83	2.86	3.20
VMJH	22:30	1.37	2.51	148.97	20.23	2.90	3.22
VMZ		1.55	2.50	148.85	19.65	2.86	3.23



# Valori inregistrate MIR-IS HP-1500

Data:08/09/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	15:00	1.47	2.46	148.95	19.50	2.87	3.17
VMJH	15:30	1.18	2.49	149.84	19.24	2.85	3.31
VMJH	16:00	1.84	2.51	150.00	19.81	2.88	3.27
VMJH	16:30	1.45	2.60	149.65	19.73	2.86	3.14
VMJH	17:00	0.82	2.52	151.23	20.11	2.86	3.23
VMJH	17:30	2.09	2.51	149.64	19.25	2.89	3.25
VMJH	18:00	1.45	2.49	148.99	19.53	2.86	3.30
VMJH	18:30	1.05	2.46	147.79	19.72	2.86	3.22
VMJH	19:00	1.23	2.48	150.20	19.60	2.86	3.20
VMJH	19:30	1.43	2.52	148.91	19.11	2.81	3.28
VMJH	20:00	1.85	2.54	147.76	19.82	2.91	3.18
VMJH	20:30	1.09	2.51	148.00	19.67	2.88	3.29
VMJH	21:00	1.16	2.49	148.96	19.38	2.84	3.24
VMJH	21:30	1.20	2.53	149.90	19.37	2.86	3.31
VMJH	22:00	1.10	2.55	151.24	19.09	2.87	3.23
VMJH	22:07	1.43	2.62	148.63	20.12	2.85	3.18
VMZ		1.36	2.51	149.40	19.54	2.86	3.24

# Valori inregistrate MIR-IS HP-1500

Data:11/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	13:44	1.73	2.54	149.71	19.12	2.84	3.16
VMJH	14:14	1.67	2.48	147.88	19.04	2.89	3.21
VMJH	14:44	1.57	2.54	149.15	20.00	2.85	3.28
VMJH	15:14	1.37	2.47	148.57	19.41	2.83	3.24
VMJH	15:44	1.27	2.45	147.89	19.59	2.88	3.29
VMJH	16:14	1.52	2.51	148.72	19.49	2.84	3.24
VMJH	16:44	1.53	2.51	149.50	19.74	2.85	3.22
VMJH	17:14	1.05	2.49	148.60	19.66	2.88	3.25
VMJH	17:44	1.58	2.53	149.48	19.48	2.86	3.23
VMJH	18:14	1.37	2.50	149.31	19.36	2.86	3.21
VMJH	18:44	1.62	2.81	145.05	20.10	2.81	3.19
VMJH	19:14	1.73	2.69	143.65	19.71	2.80	3.20
VMJH	19:44	1.60	2.69	144.75	19.88	2.82	3.21
VMJH	20:14	1.99	2.77	144.27	19.92	2.81	3.22
VMJH	20:44	3.19	2.75	145.70	20.11	2.80	3.20
VMJH	21:14	2.01	2.82	145.56	19.70	2.81	3.18
VMJH	21:44	2.36	2.78	144.78	20.12	2.81	3.14
VMJH	22:14	2.82	2.75	145.90	20.31	2.82	3.16
VMJH	22:45	2.48	2.79	145.10	19.93	2.83	3.15
VMZ		1.82	2.63	147.02	19.72	2.84	3.21

# Valori inregistrate MIR-IS HP-1500

Data:12/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	15:01	2.37	2.75	143.78	20.05	2.80	3.19
VMJH	15:31	2.24	2.73	144.59	19.80	2.77	3.17
VMJH	16:01	1.33	2.70	145.18	20.19	2.81	3.21
VMJH	16:31	2.01	2.79	142.56	19.95	2.77	3.20
VMJH	17:01	2.00	2.83	144.12	19.96	2.82	3.17
VMJH	17:31	2.52	2.74	145.27	20.06	2.80	3.20
VMJH	18:01	1.79	2.73	144.50	19.84	2.83	3.13
VMJH	18:31	1.70	2.79	145.92	19.90	2.78	3.20
VMJH	19:01	1.73	2.75	144.33	20.14	2.87	3.24
VMJH	19:31	1.99	2.77	142.98	20.40	2.81	3.20
VMJH	20:01	2.19	2.81	145.51	20.19	2.80	3.19
VMJH	20:31	3.33	2.75	143.59	19.73	2.80	3.16
VMJH	21:01	2.11	2.77	144.71	19.90	2.80	3.16
VMJH	21:31	2.78	2.72	145.72	20.18	2.80	3.26
VMJH	22:01	2.38	2.79	145.49	20.22	2.78	3.19
VMJH	22:31	2.40	2.78	144.87	20.05	2.84	3.19
VMJH	22:44	2.62	2.95	144.94	19.69	2.80	3.24
VMZ		2.19	2.77	144.58	20.03	2.80	3.19



# Valori inregistrate MIR-IS HP-1500

Data:13/09/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	3.00	2.77	144.06	20.38	2.82	3.18					
VMJH	07:59	2.03	2.86	144.82	19.92	2.80	3.24					
VMJH	08:29	2.42	2.73	145.68	20.25	2.75	3.24					
VMJH	08:59	1.47	2.75	141.19	20.49	2.81	3.18					
VMJH	09:29	1.85	2.85	144.36	19.84	2.76	3.15					
VMJH	09:59	1.77	2.84	144.48	20.16	2.82	3.17					
VMJH	10:29	2.35	2.75	142.32	19.98	2.76	3.18					
VMJH	10:59	2.33	2.78	147.13	20.39	2.80	3.13					
VMJH	11:29	1.62	2.80	144.28	19.78	2.83	3.15					
VMJH	11:59	1.89	2.75	144.53	19.97	2.78	3.19					
VMJH	12:29	2.16	2.73	143.50	19.94	2.78	3.23					
VMJH	12:59	1.42	2.84	142.13	20.27	2.84	3.24					
VMJH	13:29	1.53	2.75	143.32	20.01	2.82	3.18					
VMJH	13:59	2.98	2.71	143.83	19.88	2.78	3.13					
VMJH	14:29	2.00	2.76	145.34	20.25	2.83	3.22					
VMJH	14:59	2.03	2.80	145.33	20.19	2.81	3.18					
VMJH	15:29	3.00	2.72	144.51	20.31	2.83	3.21					
VMJH	15:59	2.65	2.87	142.92	20.03	2.87	3.24					
VMJH	16:29	3.18	2.82	148.16	20.26	2.83	3.18					
VMJH	16:59	2.62	2.80	146.02	19.92	2.82	3.22					
VMJH	17:29	2.89	2.86	144.58	20.23	2.80	3.14					
VMJH	17:59	3.06	2.88	144.46	20.12	2.76	3.26					
VMJH	18:29	2.84	3.12	155.72	20.50	3.01	3.40					
VMJH	18:59	2.83	3.40	166.52	20.84	3.14	3.62					
VMJH	19:29	1.96	3.32	166.46	21.19	3.12	3.47					
VMJH	19:59	0.55	3.43	164.96	20.89	3.13	3.54					
VMJH	20:29	0.31	3.41	166.47	21.08	3.20	3.56					
VMJH	20:59	0.56	3.44	165.70	21.34	3.10	3.50					
VMJH	21:29	1.15	3.49	165.69	20.55	3.14	3.52					
VMJH	21:59	1.20	3.47	165.02	21.91	3.18	3.49					
VMJH	22:17	0.72	3.39	164.07	21.25	3.10	3.42					
VMZ		2.03	2.96	150.09	20.38	2.89	3.28					

# Valori inregistrate MIR-IS HP-1500

Data:14/09/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 14:59	0.97	3.44	166.78	21.11	3.14	3.51
VMJH 15:29	0.87	3.38	165.71	20.87	3.10	3.55
VMJH 15:59	0.77	3.39	166.15	20.89	3.11	3.50
VMJH 16:29	1.83	3.46	164.78	21.51	3.14	3.52
VMJH 16:59	2.87	3.44	165.87	20.95	3.13	3.54
VMJH 17:29	3.64	3.42	164.88	21.32	3.17	3.49
VMJH 17:59	1.15	3.33	166.35	21.03	3.15	3.50
VMJH 18:29	1.00	3.39	166.49	20.80	3.14	3.45
VMJH 18:59	1.81	3.47	164.76	21.14	3.13	3.55
VMJH 19:29	1.96	3.40	165.89	21.79	3.14	3.53
VMJH 19:59	1.87	3.38	166.63	21.74	3.20	3.54
VMJH 20:29	1.03	3.50	166.82	21.41	3.13	3.56
VMJH 20:59	1.26	3.44	165.82	20.43	3.17	3.52
VMJH 21:29	1.11	3.51	166.46	20.89	3.12	3.56
VMJH 21:59	0.42	3.34	167.04	21.26	3.13	3.58
VMJH 22:29	0.34	3.40	165.69	21.42	3.20	3.43
VMJH 22:50	0.81	3.35	166.13	20.98	3.17	3.50
VMZ	1.40	3.41	166.01	21.15	3.14	3.52

# Valori inregistrate MIR-IS HP-1500

Data:15/09/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:29	0.37	3.38	167.25	20.96	3.13	3.53					
VMJH	07:59	0.66	3.43	166.56	21.58	3.20	3.58					
VMJH	08:29	0.15	3.54	164.84	21.38	3.16	3.53					
VMJH	08:59	1.00	3.50	164.27	21.75	3.13	3.56					
VMJH	09:29	0.71	3.35	164.64	21.05	3.09	3.58					
VMJH	09:59	0.57	3.49	164.81	21.56	3.13	3.45					
VMJH	10:29	1.02	3.39	164.96	20.87	3.14	3.47					
VMJH	10:59	0.77	3.47	164.22	21.12	3.11	3.55					
VMJH	11:29	0.64	3.47	167.12	21.61	3.11	3.45					
VMJH	11:59	0.79	3.51	165.57	20.65	3.11	3.48					
VMJH	12:29	1.80	3.40	165.55	21.29	3.15	3.53					
VMJH	12:59	0.86	3.47	165.15	21.33	3.12	3.51					
VMJH	13:29	1.48	3.51	164.49	21.50	3.19	3.60					
VMJH	13:59	0.37	3.46	166.38	20.55	3.16	3.54					
VMJH	14:29	1.04	3.28	165.02	21.16	3.17	3.47					
VMJH	14:59	2.26	3.38	165.19	21.77	3.19	3.54					
VMJH	15:29	1.11	3.46	167.45	20.71	3.12	3.51					
VMJH	15:59	1.91	3.49	166.30	22.00	3.13	3.54					
VMJH	16:29	2.09	3.48	167.61	21.10	3.18	3.57					
VMJH	16:59	0.39	3.38	166.50	21.35	3.12	3.55					
VMJH	17:29	2.43	3.46	167.78	20.87	3.12	3.48					
VMJH	17:59	1.01	3.54	166.32	21.57	3.15	3.51					
VMJH	18:29	1.90	3.47	165.93	21.07	3.16	3.56					
VMJH	18:59	1.71	2.29	128.53	19.09	2.50	2.98					
VMJH	19:29	0.54	2.16	121.77	18.81	2.48	2.80					
VMJH	19:59	1.95	1.92	125.00	18.77	2.49	2.90					
VMJH	20:29	0.51	2.06	121.54	18.93	2.50	2.88					
VMJH	20:59	1.56	2.15	126.20	19.03	2.44	2.87					
VMJH	21:29	1.05	2.11	123.19	18.47	2.50	2.85					
VMJH	22:00	0.00	2.10	126.68	18.95	2.47	2.86					
VMZ		1.09	3.13	156.15	20.69	2.99	3.37					



# Valori inregistrate MIR-IS HP-1500

Data:18/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	15:49	1.40	2.09	123.95	19.01	2.49	2.83
VMJH	16:19	1.43	2.03	125.83	18.91	2.52	2.82
VMJH	16:49	0.72	2.18	121.31	19.01	2.52	2.79
VMJH	17:19	0.60	2.11	121.89	18.71	2.43	2.81
VMJH	17:49	0.79	1.99	124.72	19.13	2.46	2.91
VMJH	18:19	0.67	2.07	122.13	18.96	2.46	2.93
VMJH	18:49	0.57	2.24	122.74	18.67	2.42	2.82
VMJH	19:19	0.28	2.15	124.41	18.84	2.48	2.86
VMJH	19:49	1.17	2.05	120.07	18.91	2.48	2.83
VMJH	20:19	1.46	2.12	126.89	18.86	2.50	2.83
VMJH	20:49	1.37	2.06	126.42	18.48	2.53	2.97
VMJH	21:19	0.85	2.23	119.05	19.00	2.45	2.87
VMJH	21:49	0.41	2.10	123.11	18.90	2.44	2.82
VMJH	22:19	1.05	2.08	120.89	18.97	2.48	2.87
VMJH	22:46	0.89	1.96	123.47	19.02	2.43	2.71
VMZ		0.91	2.10	123.12	18.89	2.47	2.84

# Valori inregistrate MIR-IS HP-1500

Data:19/09/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	0.57	2.05	124.03	19.16	2.49	2.92
VMJH	07:59	0.82	2.25	125.64	18.90	2.38	2.94
VMJH	08:29	1.25	2.19	122.57	18.94	2.45	2.85
VMJH	08:59	0.81	2.33	124.03	18.90	2.56	2.89
VMJH	09:29	1.12	2.19	121.70	18.88	2.43	2.85
VMJH	09:59	2.42	2.09	124.11	18.77	2.43	2.96
VMJH	10:29	1.24	2.01	124.83	19.14	2.38	2.86
VMJH	10:59	1.36	2.13	121.12	19.08	2.49	2.86
VMJH	11:29	0.50	2.24	123.56	19.00	2.42	2.77
VMJH	11:59	0.60	2.14	123.82	18.90	2.49	2.89
VMJH	12:29	0.79	2.22	119.08	19.14	2.44	2.87
VMJH	12:59	0.74	1.93	126.53	18.91	2.47	2.72
VMJH	13:29	0.54	2.18	123.75	18.70	2.51	2.93
VMJH	13:59	0.40	2.03	124.33	18.82	2.40	2.82
VMJH	14:29	0.40	2.12	120.83	18.58	2.50	2.88
VMJH	14:59	1.24	2.12	120.91	19.04	2.47	2.89
VMJH	15:29	0.62	2.02	121.07	19.19	2.44	2.86
VMJH	15:59	1.28	2.16	121.28	19.02	2.42	2.78
VMJH	16:29	1.20	2.19	125.93	18.90	2.48	2.94
VMJH	16:59	0.75	2.12	123.58	19.31	2.48	2.82
VMJH	17:29	1.06	2.02	120.98	18.91	2.58	2.88
VMJH	17:59	1.65	2.19	121.19	19.21	2.47	2.84
VMJH	18:29	0.70	2.10	128.45	18.80	2.57	2.91
VMJH	18:59	0.44	2.28	124.25	18.93	2.51	2.88
VMJH	19:29	0.63	2.33	122.94	18.59	2.45	2.77
VMJH	19:59	0.60	2.17	121.44	19.25	2.39	3.02
VMJH	20:29	0.44	2.22	122.56	19.07	2.44	2.86
VMJH	20:59	0.40	2.22	124.24	18.99	2.40	2.90
VMJH	21:29	0.66	2.00	118.76	18.62	2.49	2.90
VMJH	21:59	0.60	2.19	121.20	19.14	2.46	2.86
VMJH	22:29	0.44	2.11	121.60	18.69	2.51	2.77
VMJH	22:40	0.45	2.06	123.40	18.89	2.57	2.78
VMZ		0.84	2.15	122.92	18.95	2.47	2.87

# Valori inregistrate MIR-IS HP-1500

Data:20/09/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 07:29	1.13	2.17	121.78	18.85	2.49	2.89
VMJH 07:59	0.23	2.12	118.75	18.85	2.39	2.76
VMJH 08:29	0.88	2.18	124.32	18.87	2.48	2.82
VMJH 08:59	1.74	2.16	121.95	18.98	2.47	2.82
VMJH 09:29	0.96	2.17	124.28	19.21	2.49	2.88
VMJH 09:59	0.45	2.33	123.52	18.76	2.40	2.95
VMJH 10:29	0.50	2.16	123.75	18.87	2.48	2.80
VMJH 10:59	0.56	2.25	115.63	18.73	2.51	2.83
VMJH 11:29	0.73	2.18	121.26	18.88	2.46	2.89
VMJH 11:59	0.57	2.24	122.26	19.15	2.52	2.90
VMJH 12:29	0.21	2.18	120.64	19.15	2.46	2.80
VMJH 12:59	1.10	2.30	123.94	19.01	2.47	2.84
VMJH 13:29	0.55	2.20	121.91	18.80	2.48	2.82
VMJH 13:59	1.02	2.19	119.50	19.19	2.45	2.84
VMJH 14:29	0.97	2.23	123.18	19.13	2.46	2.84
VMJH 14:59	0.29	2.17	125.80	19.01	2.52	2.95
VMJH 15:29	0.36	2.32	120.06	19.09	2.47	2.90
VMJH 15:59	0.43	2.11	125.69	18.89	2.45	2.88
VMJH 16:29	0.40	2.14	126.89	19.01	2.40	2.97
VMJH 16:59	0.85	2.21	123.02	18.92	2.45	2.92
VMJH 17:29	0.64	2.23	122.92	19.08	2.50	2.89
VMJH 17:59	1.18	2.19	122.35	18.88	2.55	2.77
VMJH 18:29	1.36	2.12	117.26	19.13	2.54	2.84
VMJH 18:59	1.08	2.03	122.26	18.93	2.48	2.92
VMJH 19:29	0.58	2.11	124.77	18.68	2.47	2.86
VMJH 19:59	1.34	2.16	126.79	18.74	2.51	2.89
VMJH 20:29	1.56	2.25	122.41	19.04	2.41	2.87
VMJH 20:59	2.47	2.18	123.81	18.92	2.45	2.95
VMJH 21:29	3.31	2.31	124.40	18.79	2.55	2.91
VMJH 21:59	1.27	2.23	117.72	18.76	2.45	2.83
VMJH 22:29	1.72	2.19	121.60	18.56	2.52	2.90
VMJH 22:46	1.35	2.17	122.60	19.11	2.60	2.80
VMZ	0.99	2.19	122.40	18.93	2.48	2.87



# Valori inregistrate MIR-IS HP-1500

Data:22/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 07:29	0.50	2.31	120.84	18.99	2.44	2.89
VMJH 07:59	0.69	2.00	123.92	18.68	2.52	2.85
VMJH 08:29	0.83	2.24	122.92	18.56	2.50	2.88
VMJH 08:59	0.90	2.16	124.25	18.98	2.46	2.84
VMJH 09:29	0.67	2.17	123.84	18.83	2.47	2.94
VMJH 09:59	1.18	2.06	122.34	19.30	2.39	2.82
VMJH 10:29	1.59	2.10	121.59	18.78	2.55	2.86
VMJH 10:59	0.70	2.18	123.02	19.20	2.51	2.88
VMJH 11:29	1.70	2.26	123.22	18.83	2.46	2.90
VMJH 11:59	1.76	2.26	123.92	18.88	2.44	2.88
VMJH 12:29	1.80	2.15	124.31	19.07	2.54	2.98
VMJH 12:59	1.54	2.12	127.10	18.68	2.53	2.91
VMJH 13:29	1.40	2.00	129.13	18.94	2.50	2.84
VMJH 13:59	1.56	2.18	125.70	19.19	2.40	2.78
VMJH 14:29	0.70	2.14	130.07	19.03	2.45	2.86
VMJH 14:59	0.86	2.01	129.92	18.83	2.46	2.83
VMJH 15:29	1.51	2.03	125.94	18.83	2.49	2.90
VMJH 15:59	0.92	2.09	128.60	19.03	2.43	2.81
VMJH 16:29	1.74	2.02	129.30	18.68	2.39	2.92
VMJH 16:59	1.99	1.99	129.09	18.95	2.37	2.79
VMJH 17:29	2.06	1.93	128.19	18.57	2.44	2.91
VMJH 17:59	2.26	2.09	130.63	18.97	2.33	2.79
VMJH 18:29	0.62	1.95	128.11	18.96	2.45	2.86
VMJH 18:59	1.02	1.92	127.65	19.21	2.36	2.84
VMJH 19:29	1.87	1.95	125.33	19.34	2.43	2.90
VMJH 19:59	2.32	2.09	128.96	19.34	2.47	2.90
VMJH 20:29	2.24	1.99	126.99	19.14	2.37	2.77
VMJH 20:59	2.88	2.03	128.47	18.80	2.43	2.73
VMJH 21:29	2.54	1.96	126.29	18.85	2.44	2.73
VMJH 21:59	2.24	2.08	130.51	18.72	2.36	2.87
VMJH 22:29	1.94	1.98	127.23	18.81	2.45	2.86
VMJH 22:42	2.15	2.05	128.51	19.03	2.35	2.95
VMZ	1.51	2.08	126.40	18.94	2.44	2.86

# Valori inregistrate MIR-IS HP-1500

Data:22/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 10:29	2.20	1.98	129.53	18.94	2.39	2.90
VMJH 10:59	2.10	1.99	130.35	18.92	2.47	2.79
VMJH 11:29	2.29	2.03	128.71	18.98	2.49	2.84
VMJH 11:59	0.94	2.03	126.70	18.68	2.41	2.98
VMJH 12:29	1.64	2.06	132.38	18.86	2.46	2.88
VMJH 12:59	1.44	2.23	127.21	18.75	2.37	2.81
VMJH 13:29	1.85	1.91	125.86	18.79	2.38	2.82
VMJH 13:59	1.54	2.13	130.51	18.81	2.46	2.76
VMJH 14:32	1.12	2.09	128.21	18.94	2.39	2.80
VMZ	1.67	2.05	128.83	18.85	2.42	2.84

# Valori inregistrate MIR-IS HP-1500

Data:26/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 08:29	1.53	2.09	129.59	18.74	2.35	2.87
VMJH 08:59	0.05	2.06	129.48	18.81	2.41	2.92
VMJH 09:29	1.74	1.93	126.74	18.89	2.44	2.94
VMJH 09:59	1.99	1.91	127.89	19.07	2.51	2.83
VMJH 10:29	1.61	2.01	127.26	19.10	2.45	2.84
VMJH 10:59	0.41	1.94	127.89	18.93	2.43	2.78
VMJH 11:29	0.63	2.11	127.14	19.21	2.44	2.86
VMJH 11:59	1.99	1.95	127.17	18.57	2.43	2.84
VMJH 12:29	1.48	2.14	128.44	18.79	2.43	2.85
VMJH 12:59	0.82	2.05	127.28	18.72	2.43	2.90
VMJH 13:29	0.32	2.02	129.55	18.96	2.42	2.84
VMJH 13:59	2.14	1.98	127.75	18.77	2.51	2.88
VMJH 14:29	1.10	2.14	130.11	19.07	2.40	2.85
VMJH 14:59	1.45	1.95	128.57	19.00	2.47	2.89
VMJH 15:29	0.89	2.24	128.98	19.07	2.40	2.81
VMJH 15:53	1.88	1.89	126.16	18.69	2.39	2.98
VMZ	1.24	2.03	128.15	18.90	2.43	2.87



# Valori inregistrate MIR-IS HP-1500

Data:27/09/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	07:41	2.13	1.98		132.71		19.10		2.45		2.86	
VMJH	08:11	0.62	2.09		127.35		18.79		2.52		2.89	
VMJH	08:41	1.54	2.13		133.92		19.26		2.49		2.83	
VMJH	09:11	1.57	3.13		151.02		20.96		3.03		3.29	
VMJH	09:41	0.60	3.19		152.32		19.79		3.01		3.40	
VMJH	10:11	0.02	3.15		152.65		20.21		3.10		3.39	
VMJH	10:41	1.77	3.11		152.92		20.39		3.06		3.37	
VMJH	11:11	1.90	3.12		152.88		20.34		3.06		3.34	
VMJH	11:41	2.25	3.15		153.35		20.74		3.04		3.43	
VMJH	12:11	1.91	3.16		152.12		20.55		3.07		3.38	
VMJH	12:41	1.84	3.05		153.03		20.98		3.06		3.41	
VMJH	13:11	2.74	3.18		151.49		20.30		3.02		3.35	
VMJH	13:41	2.38	3.15		151.98		20.44		3.04		3.41	
VMJH	14:11	0.75	3.15		151.57		20.47		3.06		3.38	
VMJH	14:41	1.93	3.19		152.80		20.13		3.10		3.36	
VMJH	15:06	1.04	3.16		152.89		19.80		3.03		3.45	
VMZ		1.57	2.94		148.43		20.15		2.95		3.28	

# Valori inregistrate MIR-IS HP-1500

Data:28/09/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.60	3.15	152.75	19.93	3.07	3.40
VMJH	07:59	1.66	3.14	151.39	19.80	3.04	3.38
VMJH	08:29	1.67	3.16	152.10	19.66	3.06	3.36
VMJH	08:59	1.54	3.17	150.86	20.07	3.05	3.35
VMJH	09:29	1.76	3.15	152.45	20.26	3.05	3.42
VMJH	09:58	1.57	3.15	150.35	20.64	3.08	3.39
VMJH	10:29	1.71	3.08	152.64	20.23	3.05	3.46
VMJH	10:59	1.76	3.16	152.48	20.85	3.10	3.40
VMJH	11:29	1.73	3.10	153.05	20.17	3.07	3.42
VMJH	11:59	1.80	3.20	152.11	20.02	3.05	3.39
VMJH	12:29	1.77	3.08	150.92	20.90	3.08	3.41
VMJH	12:59	1.77	3.13	152.57	20.35	3.09	3.42
VMJH	13:29	0.38	3.22	152.33	20.42	3.07	3.41
VMJH	13:59	0.50	3.09	152.50	20.08	3.05	3.33
VMJH	14:29	1.73	3.09	152.00	20.16	3.06	3.45
VMJH	14:59	1.67	3.17	151.49	20.33	3.03	3.45
VMJH	15:29	1.67	3.09	153.66	20.08	3.07	3.44
VMJH	15:52	2.70	3.16	153.17	20.45	3.05	3.38
VMZ		1.60	3.14	152.15	20.24	3.06	3.40

# Valori inregistrate MIR-IS HP-1500

Data:28/09/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	2.00	3.15	152.26	20.37	3.06	3.46
VMJH	07:59	0.71	3.13	152.23	20.52	3.07	3.40
VMJH	08:29	0.02	3.14	151.84	20.38	3.06	3.42
VMJH	08:59	1.10	3.20	153.38	20.48	3.04	3.33
VMJH	09:29	2.33	3.08	151.32	20.33	3.08	3.37
VMJH	09:59	1.59	3.25	152.57	20.47	3.05	3.45
VMJH	10:29	1.73	3.18	153.02	19.83	3.06	3.38
VMJH	10:59	2.12	3.12	153.02	20.37	3.06	3.38
VMJH	11:29	1.04	3.15	151.12	19.79	3.05	3.39
VMJH	11:59	1.71	3.18	153.00	20.33	3.07	3.41
VMJH	12:29	0.73	3.15	153.28	20.30	3.06	3.37
VMJH	12:59	1.96	3.15	151.75	20.00	3.05	3.39
VMJH	13:29	1.84	3.14	151.94	20.11	3.05	3.41
VMJH	13:59	1.09	3.17	152.86	20.04	3.08	3.40
VMJH	14:29	2.07	3.22	152.59	20.14	3.05	3.39
VMJH	14:43	0.71	3.10	153.14	21.01	3.08	3.39
VMZ		1.45	3.16	152.44	20.25	3.06	3.40



# Valori inregistrate MIR-IS HP-1250

Data:02/10/2023

Ora	Pulberi	SO2 L2	NOx L2	CO L2	COT L2	HCL L2
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 11:19	2.17	4.15	138.53	14.79	3.12	3.36
VMJH 11:49	2.03	4.31	138.04	15.00	3.03	3.19
VMJH 12:19	1.67	4.28	139.38	15.09	3.03	3.33
VMJH 12:49	2.20	4.19	138.32	14.93	2.91	3.36
VMJH 13:19	1.60	4.30	137.64	14.92	2.87	3.14
VMJH 13:49	2.53	4.26	137.35	14.71	2.90	3.23
VMJH 14:19	2.00	3.55	132.65	17.47	2.81	3.12
VMJH 14:49	1.80	2.76	124.36	20.21	2.48	2.72
VMJH 15:19	1.90	2.78	126.86	20.24	2.40	2.64
VMJH 15:49	2.17	2.84	124.97	20.03	2.50	2.65
VMJH 16:19	2.60	2.95	124.98	20.39	2.40	2.75
VMJH 16:49	1.80	2.81	125.12	20.15	2.45	2.73
VMJH 17:19	2.70	2.79	126.91	20.36	2.45	2.69
VMJH 17:49	1.80	2.80	127.08	19.65	2.42	2.79
VMJH 18:19	2.67	2.95	125.88	19.96	2.38	2.77
VMJH 18:49	2.47	2.80	127.96	20.32	2.44	2.66
VMJH 19:19	1.93	2.74	125.59	20.13	2.46	2.73
VMJH 19:49	2.80	2.66	126.75	19.99	2.22	2.55
VMJH 20:19	2.50	2.62	126.81	19.52	2.25	2.55
VMJH 20:49	2.40	2.48	126.50	19.75	2.23	2.50
VMJH 21:19	2.37	2.57	126.86	19.96	2.24	2.53
VMJH 21:49	1.97	2.52	127.07	19.82	2.38	2.60
VMJH 22:19	2.27	2.56	127.72	20.01	2.28	2.54
VMJH 22:49	2.13	2.53	126.41	20.00	2.04	2.54
VMJH 22:54	2.60	2.61	130.28	19.14	2.19	2.64
VMZ	2.19	3.13	129.58	18.65	2.53	2.82

# Valori inregistrate MIR-IS HP-1500

Data:03/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	14:41	2.70	2.93	122.59	20.65	2.42	2.84
VMJH	15:11	2.63	2.80	124.37	19.90	2.47	2.72
VMJH	15:41	2.17	2.76	128.63	20.18	2.42	2.74
VMJH	16:11	2.60	2.80	125.54	20.49	2.46	2.77
VMJH	16:41	1.97	2.90	127.54	20.37	2.45	2.75
VMJH	17:11	1.83	2.76	126.61	20.46	2.54	2.73
VMJH	17:41	2.40	2.82	129.23	20.09	2.42	2.72
VMJH	18:11	1.93	2.85	128.39	20.62	2.46	2.86
VMJH	18:41	1.63	2.80	124.59	19.85	2.48	2.73
VMJH	19:11	1.57	2.90	123.93	20.07	2.38	2.74
VMJH	19:41	1.97	2.79	125.86	19.65	2.47	2.80
VMJH	20:11	2.77	2.78	125.38	19.99	2.45	2.84
VMJH	20:41	1.73	2.78	124.69	20.15	2.48	2.72
VMJH	21:11	1.63	2.82	124.79	20.25	2.42	2.72
VMJH	21:41	2.87	2.76	126.21	20.04	2.44	2.77
VMJH	22:05	2.96	2.68	126.81	20.01	2.35	2.74
VMZ		2.20	2.81	125.94	20.17	2.45	2.76

# Valori inregistrate MIR-IS HP-1500

Data:04/10/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	09:54	2.30	5.03	153.19	21.34	3.56	3.39					
VMJH	10:24	2.37	4.83	150.54	20.89	3.57	3.42					
VMJH	10:54	2.10	4.75	150.37	20.82	3.41	3.33					
VMJH	11:24	2.00	4.81	153.80	20.42	3.49	3.43					
VMJH	11:54	2.33	4.51	152.74	21.00	3.45	3.36					
VMJH	12:24	2.40	4.88	149.85	20.87	3.55	3.41					
VMJH	12:54	3.23	4.69	148.24	20.75	3.61	3.39					
VMJH	13:24	2.10	4.73	148.36	19.91	3.48	3.34					
VMJH	13:54	1.93	4.77	149.75	20.55	3.52	3.39					
VMJH	14:24	2.67	4.84	151.46	20.92	3.49	3.36					
VMJH	14:54	2.63	4.76	150.87	21.11	3.53	3.41					
VMJH	15:24	1.67	4.63	148.73	21.16	3.46	3.40					
VMJH	15:54	2.23	4.54	149.15	20.60	3.56	3.36					
VMJH	16:24	2.67	4.72	147.46	20.03	3.45	3.41					
VMJH	16:54	1.83	3.57	137.53	20.21	2.87	3.00					
VMJH	17:24	1.93	2.49	127.97	19.64	2.03	2.57					
VMJH	17:54	1.57	2.56	128.01	19.87	2.17	2.47					
VMJH	18:24	1.63	2.55	127.82	20.07	2.23	2.49					
VMJH	18:54	1.97	2.43	127.77	19.38	2.26	2.37					
VMJH	19:24	2.77	2.52	127.29	19.84	2.25	2.55					
VMJH	19:54	1.70	2.52	127.09	20.08	2.17	2.58					
VMJH	20:24	1.67	2.44	126.65	19.40	2.36	2.55					
VMJH	20:54	2.87	2.55	127.47	19.21	2.15	2.51					
VMJH	21:24	2.93	2.55	127.49	19.37	2.09	2.51					
VMJH	21:54	2.30	2.56	126.54	19.82	2.15	2.47					
VMJH	22:24	2.37	2.51	127.41	19.55	2.20	2.61					
VMJH	22:43	2.05	2.50	127.53	19.66	2.01	2.55					
VMZ		2.23	3.73	139.83	20.25	2.90	2.99					



# Valori inregistrate MIR-IS HP-1500

Data: 05.10.2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:07	1.80	3.77	136.89	20.63	2.93	3.07
VMJH	15:37	2.17	3.63	139.15	20.27	2.99	3.05
VMJH	16:07	2.40	3.84	138.53	20.64	2.94	3.07
VMJH	16:37	2.23	3.88	138.34	20.58	3.00	3.04
VMJH	17:07	2.33	3.73	138.52	20.86	2.98	3.04
VMJH	17:37	2.43	3.80	139.11	20.23	3.01	3.07
VMJH	18:07	1.87	3.71	139.95	20.55	2.98	3.10
VMJH	18:37	2.60	3.82	137.66	20.32	3.05	3.07
VMJH	19:07	2.53	3.82	135.82	20.65	2.98	3.02
VMJH	19:37	2.27	3.86	137.86	20.49	2.93	3.05
VMJH	20:07	3.33	3.74	138.14	20.28	3.04	3.10
VMJH	20:37	1.90	3.71	137.05	20.44	2.97	3.05
VMJH	21:07	1.90	3.79	137.34	20.61	2.96	3.08
VMJH	21:37	2.50	3.85	136.50	20.60	3.01	3.07
VMJH	22:07	2.00	2.98	133.47	20.23	2.56	2.76
VMJH	22:37	2.00	2.50	126.69	19.57	2.18	2.50
VMJH	22:43	2.83	2.58	127.59	20.68	2.43	2.52
VMZ		2.27	3.64	136.81	20.44	2.90	3.00

# Valori inregistrate MIR-IS HP-1500

Data: 06.10.2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:13	2.90	4.79	148.98	21.03	3.60	3.43
VMJH	15:43	2.80	4.55	150.15	20.71	3.53	3.40
VMJH	16:13	2.50	4.69	149.54	21.17	3.51	3.41
VMJH	16:43	2.20	4.69	152.16	21.04	3.64	3.36
VMJH	17:13	2.60	4.19	143.86	20.72	3.34	3.26
VMJH	17:43	1.97	3.75	137.56	20.29	2.97	3.04
VMJH	18:13	1.57	3.71	139.82	20.38	2.97	3.00
VMJH	18:43	2.10	3.72	136.89	20.25	2.99	3.01
VMJH	19:13	1.57	3.91	138.77	20.71	2.97	3.06
VMJH	19:43	2.13	3.77	138.72	20.68	2.96	3.04
VMJH	20:13	2.50	3.73	139.74	20.66	2.98	3.04
VMJH	20:43	2.57	3.81	138.06	20.18	2.94	3.08
VMJH	21:13	2.20	3.75	138.10	20.23	2.92	3.06
VMJH	21:43	2.33	3.79	139.43	20.46	3.02	3.02
VMJH	22:13	2.57	3.74	137.22	20.39	2.96	3.09
VMJH	22:43	2.77	3.74	136.27	20.61	2.99	3.02
VMJH	22:49	2.67	3.71	139.63	21.48	2.89	3.13
VMZ		2.33	4.02	141.55	20.61	3.14	3.15

# Valori inregistrate MIR-IS HP-1500

Data 09.10.2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	12:39	2.17	2.53	141.40	19.76	2.92	3.04
VMJH	13:09	2.10	2.51	140.46	19.95	2.94	2.96
VMJH	13:39	2.43	2.56	139.77	19.59	2.93	3.05
VMJH	14:09	2.60	2.55	140.12	20.07	2.96	2.98
VMJH	14:39	2.20	2.57	141.19	20.04	2.91	3.09
VMJH	15:09	2.40	2.54	142.08	19.93	2.90	2.99
VMJH	15:39	2.17	2.53	141.57	19.38	2.89	3.01
VMJH	16:09	2.00	2.53	140.56	19.50	2.91	2.99
VMJH	16:39	1.53	2.56	143.01	20.49	2.91	2.95
VMJH	17:09	2.00	2.57	138.32	20.34	2.90	3.06
VMJH	17:39	1.53	2.52	137.60	20.63	2.94	3.06
VMJH	18:09	1.40	2.52	140.23	19.63	2.99	2.94
VMJH	18:39	2.37	2.55	140.06	19.03	2.98	3.05
VMJH	19:09	2.77	2.55	139.95	20.11	2.90	3.03
VMJH	19:39	2.47	2.53	142.20	19.94	3.01	3.04
VMJH	20:09	1.27	2.57	140.41	19.88	2.99	2.99
VMJH	20:39	1.57	2.57	139.63	20.39	2.95	3.03
VMJH	21:09	2.77	2.56	139.35	20.02	2.89	2.97
VMJH	21:39	1.57	2.50	141.76	19.89	2.91	3.03
VMJH	22:09	1.50	2.54	140.65	20.54	2.94	2.97
VMJH	22:39	1.40	2.55	141.18	19.98	2.94	3.02
VMJH	22:55	2.13	3.66	136.56	19.92	3.02	3.20
VMZ		2.01	2.57	140.45	19.96	2.94	3.02



# Valori inregistrate MIR-IS HP-1500

Data: 10.10.2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 14:41	1.67	2.58	140.51	20.08	2.82	3.05
VMJH 15:11	1.33	2.60	139.44	20.48	2.95	3.01
VMJH 15:41	1.03	2.53	141.80	19.84	2.97	3.01
VMJH 16:11	1.43	2.54	140.03	19.81	2.95	3.06
VMJH 16:41	0.83	2.56	140.46	20.03	2.86	3.03
VMJH 17:11	0.70	2.53	141.68	19.72	2.90	3.04
VMJH 17:41	0.63	2.54	141.78	19.79	3.01	3.03
VMJH 18:11	1.00	2.74	146.67	20.36	3.17	3.20
VMJH 18:41	1.03	2.88	153.25	21.25	3.31	3.36
VMJH 19:11	0.77	2.89	151.07	21.00	3.37	3.39
VMJH 19:41	0.97	2.93	152.32	21.51	3.29	3.44
VMJH 20:11	1.27	2.93	151.45	21.73	3.34	3.38
VMJH 20:41	1.27	2.89	152.98	20.78	3.45	3.37
VMJH 21:11	0.97	2.86	153.28	21.20	3.38	3.35
VMJH 21:41	1.00	2.89	150.73	20.60	3.40	3.41
VMJH 22:11	1.03	2.91	152.11	21.81	3.36	3.37
VMJH 22:40	1.38	3.59	155.92	19.75	3.18	3.31
VMZ	1.08	2.79	147.37	20.57	3.16	3.22

# Valori inregistrate MIR-IS HP-1500

Data:11/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 14:41	2.00	2.88	152.89	21.19	3.39	3.42
VMJH 15:11	1.10	2.88	154.02	21.01	3.31	3.36
VMJH 15:41	1.80	2.90	148.88	21.21	3.35	3.34
VMJH 16:11	1.20	2.89	152.77	21.12	3.46	3.40
VMJH 16:41	1.77	2.89	152.04	21.55	3.29	3.38
VMJH 17:11	1.03	2.90	148.26	21.40	3.37	3.41
VMJH 17:41	1.30	2.92	153.78	20.09	3.43	3.40
VMJH 18:11	1.17	2.92	150.54	21.15	3.33	3.36
VMJH 18:41	1.13	2.96	152.85	21.36	3.43	3.39
VMJH 19:11	1.17	2.90	153.61	20.53	3.43	3.30
VMJH 19:41	1.43	2.94	154.04	21.15	3.45	3.47
VMJH 20:11	1.40	2.93	155.68	20.83	3.37	3.36
VMJH 20:41	1.70	2.94	151.20	20.42	3.31	3.39
VMJH 21:11	1.13	2.92	154.06	20.08	3.33	3.38
VMJH 21:41	2.00	2.94	150.76	20.84	3.35	3.38
VMJH 22:11	1.50	2.92	152.62	21.13	3.43	3.33
VMJH 22:41	0.83	4.39	147.62	21.78	2.49	2.95
VMJH 23:11	0.73	4.39	144.40	21.88	2.32	2.95
VMJH 23:36	0.52	4.56	144.34	21.76	2.31	2.92
VMZ	1.32	3.14	151.34	21.07	3.23	3.31

# Valori inregistrate MIR-IS HP-1500

Data:12/10/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:19	1.57	2.21	127.99	18.88	2.47	2.82
VMJH	15:49	1.83	2.17	129.94	18.73	2.38	2.63
VMJH	16:19	1.40	2.13	129.29	18.17	2.41	2.63
VMJH	16:49	1.90	2.16	129.84	18.92	2.49	2.73
VMJH	17:19	1.53	2.18	129.92	19.21	2.40	2.49
VMJH	17:49	1.73	2.18	126.64	19.59	2.46	2.77
VMJH	18:19	2.23	2.19	127.13	19.82	2.44	2.71
VMJH	18:49	1.30	2.14	128.33	18.53	2.54	2.57
VMJH	19:19	1.30	2.20	128.97	17.74	2.57	2.60
VMJH	19:49	1.37	2.19	128.32	18.32	2.45	2.68
VMJH	20:19	1.63	2.19	131.17	19.38	2.56	2.72
VMJH	20:49	1.33	2.18	129.01	18.75	2.53	2.67
VMJH	21:19	1.80	2.22	128.06	19.15	2.51	2.63
VMJH	21:49	1.67	2.21	126.36	18.86	2.44	2.67
VMJH	22:19	0.90	2.09	130.00	18.50	2.48	2.72
VMJH	22:36	1.47	2.16	128.91	19.94	2.48	2.58
VMZ		1.56	2.18	128.74	18.88	2.48	2.67



# Valori inregistrate MIR-IS HP-1500

Data:13/10/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 15:05	1.90	2.20	127.63	18.90	2.53	2.67
VMJH 15:35	1.27	2.23	128.45	19.29	2.43	2.79
VMJH 16:05	2.90	2.25	129.62	19.50	2.41	2.61
VMJH 16:35	0.90	2.20	129.65	18.90	2.51	2.74
VMJH 17:05	0.90	2.21	129.87	18.23	2.56	2.59
VMJH 17:35	1.70	2.19	129.19	18.81	2.45	2.75
VMJH 18:05	1.63	2.17	127.31	18.80	2.42	2.62
VMJH 18:35	1.97	2.20	128.30	18.81	2.48	2.76
VMJH 19:05	2.03	2.14	128.88	18.58	2.41	2.62
VMJH 19:35	1.37	1.86	130.57	17.13	2.28	2.57
VMJH 20:05	2.10	1.62	130.28	17.56	2.32	2.50
VMJH 20:35	2.10	1.76	128.76	17.40	2.11	2.57
VMJH 21:05	2.50	1.79	128.69	16.83	2.22	2.59
VMJH 21:35	1.67	1.76	131.39	18.01	2.22	2.64
VMJH 22:05	1.63	1.71	128.38	17.22	2.24	2.51
VMJH 22:35	1.93	1.57	130.74	17.11	2.19	2.61
VMJH 22:42	3.00	1.79	126.53	18.05	2.07	2.60
VMZ	1.80	1.99	129.19	18.19	2.36	2.63

# Valori inregistrate MIR-IS HP-1500

Data:16/10/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	10:29	2.03		1.77		130.37		17.69		2.27		2.71	
VMJH	10:59	2.00		1.79		131.41		17.39		2.33		2.67	
VMJH	11:29	1.97		1.74		131.47		17.10		2.05		2.63	
VMJH	11:59	1.93		1.78		129.38		17.64		2.21		2.69	
VMJH	12:29	1.87		1.88		131.29		17.74		2.08		2.45	
VMJH	12:59	1.97		1.75		129.38		17.58		2.41		2.63	
VMJH	13:29	1.70		1.79		130.88		16.96		2.27		2.52	
VMJH	13:59	1.53		1.68		130.17		17.26		2.17		2.72	
VMJH	14:29	1.50		1.80		131.26		17.50		2.30		2.46	
VMJH	14:59	1.60		1.88		130.90		17.54		2.19		2.58	
VMJH	15:29	1.70		1.69		129.16		17.33		2.22		2.56	
VMJH	15:59	2.03		1.67		130.18		17.70		2.22		2.59	
VMJH	16:29	1.90		1.81		130.76		17.40		2.31		2.63	
VMJH	16:59	1.73		1.89		129.96		17.34		2.10		2.60	
VMJH	17:29	1.47		1.76		129.99		17.13		2.21		2.69	
VMJH	17:59	1.90		2.02		128.86		18.00		2.18		2.49	
VMJH	18:29	2.53		2.52		127.13		19.49		2.10		2.54	
VMJH	18:59	2.70		2.59		128.22		19.65		2.18		2.56	
VMJH	19:29	2.70		2.60		126.14		19.70		2.29		2.49	
VMJH	19:59	1.87		2.45		126.36		19.53		2.15		2.57	
VMJH	20:29	2.63		2.63		128.58		19.63		2.12		2.53	
VMJH	20:59	2.53		2.56		128.48		19.44		2.13		2.50	
VMJH	21:29	1.93		2.54		127.40		19.73		2.20		2.55	
VMJH	21:59	2.07		2.64		128.10		19.60		2.33		2.53	
VMJH	22:29	2.50		2.51		126.97		19.95		2.16		2.44	
VMJH	22:41	3.00		2.51		129.46		19.08		2.15		2.52	
VMZ		2.03		2.08		129.31		18.26		2.21		2.57	

# Valori inregistrate MIR-IS HP-1500

Data:17/10/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:14	1.60	2.24	128.00	19.39	2.59	2.54
VMJH	15:44	1.77	2.26	139.18	18.43	2.65	2.93
VMJH	16:14	2.17	2.69	138.38	19.77	2.39	2.75
VMJH	16:44	2.80	3.27	161.12	22.73	3.20	3.27
VMJH	17:14	2.47	3.30	161.91	22.39	3.26	3.27
VMJH	17:44	2.50	3.70	158.98	22.67	3.22	3.23
VMJH	18:14	2.43	3.69	162.05	23.05	3.22	3.27
VMJH	18:44	2.00	3.28	161.98	22.93	3.23	3.23
VMJH	19:14	1.43	3.38	162.43	22.71	3.25	3.26
VMJH	19:44	2.57	3.44	160.80	23.68	3.23	3.25
VMJH	20:14	1.93	3.43	160.67	22.76	3.23	3.23
VMJH	20:44	1.27	3.40	160.09	21.81	3.24	3.24
VMJH	21:14	2.50	3.40	161.40	23.05	3.21	3.21
VMJH	21:44	2.73	3.30	160.40	23.41	3.23	3.23
VMJH	22:14	2.10	3.28	160.77	22.77	3.21	3.25
VMJH	22:45	2.48	3.60	162.19	22.31	3.22	3.26
VMZ		2.17	3.23	156.28	22.12	3.10	3.15



# Valori inregistrate MIR-IS HP-1500

Data:18/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 15:47	2.43	3.64	160.89	23.55	3.24	3.26
VMJH 16:17	2.60	3.45	162.89	22.31	3.28	3.29
VMJH 16:47	2.73	3.38	161.70	22.87	3.20	3.29
VMJH 17:17	1.80	3.54	161.24	22.82	3.23	3.23
VMJH 17:47	2.17	3.51	161.50	22.81	3.26	3.25
VMJH 18:17	2.40	3.59	161.31	22.65	3.25	3.26
VMJH 18:47	2.23	3.45	161.70	23.25	3.23	3.25
VMJH 19:17	2.33	3.36	160.88	23.37	3.18	3.26
VMJH 19:47	2.43	3.46	161.31	23.03	3.27	3.24
VMJH 20:17	1.87	3.68	161.07	22.79	3.18	3.26
VMJH 20:47	2.60	3.47	160.39	23.89	3.27	3.25
VMJH 21:17	2.53	3.48	162.30	23.24	3.22	3.24
VMJH 21:47	2.27	3.46	160.29	22.16	3.27	3.27
VMJH 22:17	3.33	3.49	162.81	22.52	3.25	3.25
VMJH 22:39	1.82	3.31	163.27	22.84	3.29	3.25
VMZ	2.38	3.49	161.54	22.94	3.24	3.26

# Valori inregistrate MIR-IS HP-1500

Data:19/10/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	08:29	2.00	3.49	160.02	23.20	3.27	3.26
VMJH	08:59	2.27	3.49	159.97	23.13	3.27	3.26
VMJH	09:29	2.43	3.40	161.77	23.27	3.21	3.28
VMJH	09:59	1.43	3.78	161.69	22.19	3.21	3.23
VMJH	10:29	1.63	3.39	162.92	23.05	3.23	3.27
VMJH	10:59	1.27	3.35	161.73	22.48	3.24	3.26
VMJH	11:29	1.70	3.39	161.44	23.34	3.20	3.22
VMJH	11:59	1.63	3.23	159.91	22.91	3.26	3.23
VMJH	12:29	0.87	3.41	162.55	22.52	3.20	3.24
VMJH	12:59	1.00	3.52	160.05	22.48	3.26	3.26
VMJH	13:29	1.43	3.28	160.74	23.30	3.25	3.26
VMJH	13:59	0.87	3.45	160.25	23.05	3.27	3.26
VMJH	14:29	1.87	3.57	160.61	22.13	3.28	3.27
VMJH	14:59	1.00	3.36	161.10	22.47	3.30	3.29
VMJH	15:29	1.80	3.44	160.32	23.29	3.22	3.25
VMJH	15:59	2.33	3.60	161.19	23.39	3.23	3.22
VMJH	16:19	1.60	3.39	160.23	22.66	3.22	3.23
VMZ		1.60	3.44	160.98	22.88	3.24	3.25

# Valori inregistrate MIR-IS HP-1500

Data:20/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	08:29	2.30	3.31	160.82	22.21	3.21	3.25
VMJH	08:59	2.50	3.35	161.33	22.81	3.21	3.21
VMJH	09:29	2.53	3.42	160.39	23.19	3.27	3.25
VMJH	09:59	2.23	3.10	147.29	21.50	2.85	2.96
VMJH	10:29	2.60	2.90	144.03	20.79	2.66	2.90
VMJH	10:59	1.67	2.99	143.16	21.07	2.74	2.87
VMJH	11:29	1.80	3.07	143.74	21.46	2.67	2.86
VMJH	11:59	1.93	3.04	144.42	21.42	2.76	2.86
VMJH	12:29	1.47	2.89	145.38	21.34	2.75	2.89
VMJH	12:59	1.50	2.98	145.02	21.42	2.79	2.88
VMJH	13:29	1.80	2.92	143.44	21.45	2.77	2.90
VMJH	13:59	2.77	2.95	144.10	21.23	2.76	2.85
VMJH	14:29	2.70	2.94	144.24	20.89	2.70	2.90
VMJH	14:59	1.60	2.92	143.97	21.33	2.74	2.86
VMJH	15:29	1.87	2.97	142.99	21.51	2.69	2.88
VMJH	15:45	0.94	2.85	144.91	21.00	2.66	2.92
VMZ		2.04	3.04	147.53	21.55	2.83	2.95



# Valori inregistrate MIR-IS HP-1500

Data:23/10/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	10:29	2.83	3.07	144.36	20.81	2.72	2.92
VMJH	10:59	1.50	3.12	144.25	21.36	2.77	2.87
VMJH	11:29	1.57	2.93	144.64	21.06	2.71	2.89
VMJH	11:59	1.37	3.01	144.58	21.39	2.68	2.89
VMJH	12:29	1.70	3.02	144.02	21.29	2.69	2.88
VMJH	12:59	1.53	3.06	143.92	21.31	2.76	2.84
VMJH	13:29	1.07	3.06	144.45	20.91	2.74	2.92
VMJH	13:59	0.90	2.97	143.81	21.59	2.70	2.86
VMJH	14:29	0.93	2.99	143.99	21.63	2.74	2.91
VMJH	14:59	0.80	2.98	144.41	21.38	2.81	2.89
VMJH	15:29	0.73	3.10	143.99	21.45	2.67	2.92
VMJH	15:59	1.23	3.02	144.23	21.91	2.72	2.90
VMJH	16:29	1.00	2.98	145.00	21.44	2.62	2.88
VMJH	16:59	0.80	2.99	143.95	20.88	2.71	2.87
VMJH	17:29	0.87	3.04	145.13	21.39	2.74	2.88
VMJH	17:59	1.31	2.90	145.52	21.28	2.79	2.82
VMJH	18:29	1.20	2.95	142.97	21.32	2.71	2.90
VMJH	18:59	1.00	3.00	144.01	21.56	2.76	2.92
VMJH	19:29	0.83	2.98	144.15	21.28	2.74	2.93
VMJH	19:59	1.17	3.12	144.68	20.91	2.72	2.87
VMJH	20:29	1.13	2.89	145.11	21.22	2.66	2.89
VMJH	20:59	1.20	3.02	144.41	21.14	2.67	2.87
VMJH	21:29	1.93	2.96	144.39	21.44	2.70	2.90
VMJH	21:59	1.53	2.85	143.78	21.24	2.68	2.89
VMJH	22:29	1.10	2.91	144.24	20.94	2.69	2.87
VMJH	22:45	2.25	3.07	144.06	21.43	2.78	2.89
VMZ		1.27	3.00	144.31	21.29	2.72	2.89

# Valori inregistrate MIR-IS HP-1500

Data:24/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>
	<b>10 30/10</b>	<b>50 200/50</b>	<b>200 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>
VMJH 14:59	1.50	2.93	143.88	21.23	2.66	2.91
VMJH 15:29	1.53	2.96	143.68	21.64	2.70	2.89
VMJH 15:59	1.90	3.10	143.67	21.09	2.76	2.89
VMJH 16:29	1.77	2.98	143.86	20.95	2.75	2.92
VMJH 16:59	1.80	2.98	144.31	21.43	2.70	2.89
VMJH 17:29	2.13	3.08	144.31	21.43	2.66	2.87
VMJH 17:59	1.37	3.00	144.71	21.09	2.68	2.89
VMJH 18:29	1.30	2.95	144.33	21.00	2.76	2.89
VMJH 18:59	1.27	2.93	144.43	21.12	2.73	2.86
VMJH 19:29	1.60	3.00	143.51	21.58	2.67	2.86
VMJH 19:59	1.20	3.25	131.76	21.13	2.23	2.71
VMJH 20:29	1.77	2.98	131.49	20.87	1.99	2.74
VMJH 20:59	1.97	3.27	129.19	21.16	2.10	2.53
VMJH 21:29	0.97	3.09	131.90	21.36	2.02	2.63
VMJH 21:59	1.47	3.04	129.14	21.53	1.99	2.62
VMJH 22:29	1.23	3.24	129.91	21.00	2.05	2.56
VMJH 22:43	1.37	3.19	130.16	20.83	2.14	2.54
VMZ	1.55	3.05	138.75	21.20	2.46	2.78

# Valori inregistrate MIR-IS HP-1500

Data:25/10/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	14:49	1.83	3.01	131.93	21.09	2.11	2.56
VMJH	15:19	2.03	3.00	130.59	21.99	2.01	2.60
VMJH	15:49	1.90	3.29	132.56	20.71	2.25	2.53
VMJH	16:19	1.13	3.35	131.84	21.30	2.05	2.65
VMJH	16:49	1.13	3.31	130.06	21.83	2.08	2.56
VMJH	17:19	1.67	2.96	129.78	21.44	2.04	2.57
VMJH	17:49	1.90	3.16	131.52	20.54	2.10	2.48
VMJH	18:19	1.67	3.11	129.37	21.01	2.05	2.64
VMJH	18:49	1.67	3.13	129.82	20.40	2.07	2.58
VMJH	19:19	2.03	3.04	131.08	21.01	2.12	2.62
VMJH	19:49	2.20	3.07	129.26	21.43	2.09	2.58
VMJH	20:19	2.13	2.90	130.08	21.27	2.05	2.51
VMJH	20:49	1.93	2.92	130.68	20.63	2.18	2.61
VMJH	21:19	1.63	3.18	129.29	20.59	2.02	2.62
VMJH	21:49	1.70	2.95	131.18	20.91	2.05	2.54
VMJH	22:19	2.67	3.05	130.44	20.96	2.04	2.57
VMJH	22:45	2.27	3.01	130.60	21.44	2.06	2.52
VMZ		1.85	3.09	130.59	21.09	2.08	2.57



# Valori inregistrate MIR-IS HP-1500

Data:26/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	14:49	1.90	3.22	131.29	21.52	2.00	2.63
VMJH	15:19	1.73	3.22	132.13	20.90	2.11	2.66
VMJH	15:49	2.33	3.20	129.39	21.51	2.04	2.60
VMJH	16:19	1.73	3.02	132.61	20.96	2.08	2.56
VMJH	16:49	1.57	3.10	130.86	20.60	2.00	2.48
VMJH	17:19	1.77	3.13	131.32	21.67	2.13	2.58
VMJH	17:49	1.87	3.12	130.03	20.79	2.03	2.59
VMJH	18:19	1.53	3.09	129.23	21.23	2.05	2.63
VMJH	18:49	1.87	3.26	128.62	20.13	2.08	2.61
VMJH	19:19	1.40	2.96	130.01	20.88	2.17	2.57
VMJH	19:49	1.47	2.98	129.49	22.02	2.09	2.66
VMJH	20:19	2.60	2.99	128.90	21.89	2.10	2.62
VMJH	20:49	1.50	3.14	130.18	20.87	2.08	2.55
VMJH	21:19	1.67	3.02	129.83	21.19	2.10	2.51
VMJH	21:49	1.43	3.17	131.22	21.09	2.01	2.53
VMJH	22:19	2.53	3.03	132.21	21.21	2.08	2.58
VMJH	22:43	1.67	3.01	131.22	20.93	2.12	2.51
VMZ		1.80	3.10	130.49	21.14	2.07	2.58

# Valori inregistrate MIR-IS HP-1500

Data:27/10/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	15:09	2.60	3.09	131.38	20.90	2.10	2.57					
VMJH	15:39	2.17	3.31	130.32	21.33	2.14	2.60					
VMJH	16:09	2.13	3.02	130.40	21.38	2.19	2.56					
VMJH	16:39	2.50	3.14	131.43	21.06	2.13	2.62					
VMJH	17:09	2.13	3.20	131.99	21.23	1.96	2.53					
VMJH	17:39	2.53	3.31	129.86	19.97	2.12	2.49					
VMJH	18:09	1.80	3.11	132.14	21.21	2.10	2.56					
VMJH	18:39	3.37	3.18	130.50	20.94	2.02	2.61					
VMJH	19:09	2.13	6.06	156.51	21.65	2.47	3.26					
VMJH	19:39	2.57	6.51	159.36	22.74	2.50	3.30					
VMJH	20:09	1.73	6.53	161.31	22.07	2.57	3.28					
VMJH	20:39	1.80	5.67	157.54	22.26	2.54	3.36					
VMJH	21:09	2.33	6.54	158.44	22.06	2.50	3.31					
VMJH	21:39	2.07	6.28	158.00	21.99	2.54	3.34					
VMJH	22:09	2.20	6.73	157.67	21.45	2.48	3.37					
VMJH	22:39	2.27	6.08	158.70	22.28	2.48	3.31					
VMJH	22:44	2.40	4.21	157.01	22.35	2.42	3.41					
VMZ		2.27	4.73	144.87	21.54	2.30	2.95					

# Valori inregistrate MIR-IS HP-1500

Data:30/10/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:12	1.87	6.19	160.22	23.35	2.57	3.29
VMJH	15:42	1.80	6.38	161.12	23.42	2.52	3.31
VMJH	16:12	2.53	6.08	161.18	22.24	2.52	3.26
VMJH	16:42	1.87	6.23	157.76	21.81	2.58	3.32
VMJH	17:12	2.43	5.80	158.31	23.24	2.55	3.36
VMJH	17:42	2.77	6.79	160.49	22.75	2.50	3.32
VMJH	18:12	2.83	6.64	159.71	22.41	2.49	3.32
VMJH	18:42	2.73	6.27	158.52	22.41	2.53	3.30
VMJH	19:12	2.23	6.63	160.26	22.69	2.54	3.30
VMJH	19:42	2.33	6.53	159.34	21.70	2.55	3.30
VMJH	20:12	1.83	6.08	160.54	22.77	2.54	3.31
VMJH	20:42	1.57	6.43	158.14	22.30	2.52	3.34
VMJH	21:12	1.80	6.25	158.96	22.13	2.54	3.34
VMJH	21:42	1.63	6.47	157.33	22.28	2.59	3.27
VMJH	22:12	1.43	6.38	159.51	21.63	2.55	3.33
VMJH	22:30	1.22	6.40	160.19	21.60	2.55	3.42
VMZ		2.08	6.35	159.45	22.44	2.54	3.32



# Valori inregistrate MIR-IS HP-1500

Data:31/10/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	<b>VMA VMJH</b> <b>10 30/10</b>	<b>VMA VMJH</b> <b>50 200/50</b>	<b>VMA VMJH</b> <b>200 400/200</b>	<b>VMA</b> <b>50</b>	<b>VMA VMJH</b> <b>10 20/10</b>	<b>VMA VMJH</b> <b>10 60/10</b>
VMJH 07:29	1.53	6.70	156.60	22.13	2.56	3.33
VMJH 07:59	2.07	6.38	157.80	22.43	2.46	3.33
VMJH 08:29	2.07	6.41	159.29	22.65	2.59	3.29
VMJH 08:59	1.87	6.50	158.68	21.70	2.54	3.28
VMJH 09:29	0.20	6.74	160.09	22.49	2.59	3.33
VMJH 09:59	0.37	6.02	160.43	23.35	2.50	3.33
VMJH 10:29	0.87	6.66	157.56	22.51	2.58	3.29
VMJH 10:59	0.83	6.59	159.14	21.99	2.53	3.33
VMJH 11:29	0.93	6.41	159.62	22.58	2.52	3.35
VMJH 11:59	0.73	6.81	156.35	22.10	2.51	3.29
VMJH 12:29	0.63	6.32	158.87	22.31	2.49	3.27
VMJH 12:59	1.07	6.64	159.39	22.00	2.55	3.29
VMJH 13:29	1.23	5.64	159.74	22.70	2.54	3.32
VMJH 13:59	1.10	5.88	160.24	22.11	2.49	3.32
VMJH 14:29	1.13	6.75	161.04	23.40	2.47	3.33
VMJH 14:36	1.14	5.93	156.71	22.76	2.70	3.37
VMZ	1.11	6.42	158.95	22.44	2.53	3.31

# Valori inregistrate MIR-IS HP-1500

Data:01/11/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	11:39	1.40	2.16	131.50	18.29	1.85	2.61					
VMJH	12:09	1.10	2.08	130.42	17.39	1.83	2.61					
VMJH	12:39	1.37	2.28	131.51	17.96	1.85	2.67					
VMJH	13:09	0.57	2.24	130.26	18.10	1.78	2.63					
VMJH	13:39	1.27	2.12	130.86	17.99	1.82	2.59					
VMJH	14:09	0.90	2.40	132.32	18.14	1.87	2.66					
VMJH	14:39	1.53	2.17	130.51	18.27	1.80	2.60					
VMJH	15:09	1.00	2.21	132.46	17.80	1.80	2.66					
VMJH	15:39	0.80	2.21	130.19	17.83	1.82	2.63					
VMJH	16:09	1.30	2.27	129.86	17.86	1.79	2.64					
VMJH	16:39	1.17	2.34	128.03	18.63	1.85	2.62					
VMJH	17:09	1.23	2.15	133.35	18.12	1.81	2.64					
VMJH	17:39	1.30	2.18	131.94	17.90	1.87	2.63					
VMJH	18:09	0.83	2.12	130.54	17.37	1.82	2.65					
VMJH	18:39	1.13	2.21	129.32	18.06	1.88	2.59					
VMJH	19:09	2.33	2.42	131.80	17.97	1.85	2.62					
VMJH	19:39	1.77	2.19	129.12	17.69	1.83	2.61					
VMJH	20:09	2.10	2.25	131.33	17.69	1.81	2.66					
VMJH	20:39	1.07	2.15	130.42	17.99	1.84	2.66					
VMJH	21:09	2.00	2.40	131.65	17.44	1.83	2.64					
VMJH	21:39	1.47	2.32	129.72	18.18	1.87	2.63					
VMJH	22:09	1.50	2.06	130.60	17.47	1.89	2.63					
VMJH	22:18	1.56	2.02	130.34	17.93	1.92	2.67					
VMZ		1.33	2.22	130.80	17.92	1.84	2.63					

# Valori inregistrate MIR-IS HP-1500

Data:02/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:01	1.70	2.14	130.10	17.52	1.93	2.61
VMJH	15:31	1.50	1.98	130.99	17.86	1.88	2.62
VMJH	16:01	1.20	2.26	132.63	18.35	1.89	2.67
VMJH	16:31	1.30	2.25	132.04	18.14	1.79	2.62
VMJH	17:01	1.50	2.18	130.96	18.10	1.87	2.62
VMJH	17:31	1.50	2.36	131.34	18.11	1.89	2.57
VMJH	18:01	1.60	2.19	132.95	17.75	1.87	2.66
VMJH	18:31	1.27	2.18	129.92	17.68	1.81	2.63
VMJH	19:01	1.67	2.04	131.04	17.31	1.85	2.62
VMJH	19:31	1.60	2.14	130.11	17.69	1.84	2.62
VMJH	20:01	1.30	2.24	130.77	17.99	1.85	2.62
VMJH	20:31	1.43	2.32	130.96	17.98	1.89	2.61
VMJH	21:01	1.83	2.06	130.25	18.20	1.91	2.64
VMJH	21:31	2.00	2.22	129.71	17.52	1.82	2.63
VMJH	22:01	1.10	2.18	131.17	18.08	1.92	2.63
VMJH	22:31	1.13	2.23	131.14	17.77	1.84	2.56
VMJH	22:44	2.15	2.21	132.61	18.66	1.88	2.69
VMZ		1.50	2.19	131.05	17.90	1.87	2.62



# Valori inregistrate MIR-IS HP-1500

Data:03/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.73	2.02	130.23	18.25	1.88	2.58
VMJH	07:59	2.10	2.38	130.37	18.14	1.80	2.64
VMJH	08:29	1.13	2.20	131.57	18.33	1.88	2.64
VMJH	08:59	0.90	2.23	130.13	17.83	1.82	2.61
VMJH	09:29	1.77	2.29	131.21	17.49	1.82	2.64
VMJH	09:59	1.10	2.21	131.11	17.83	1.86	2.61
VMJH	10:29	1.47	2.19	130.59	17.98	1.83	2.61
VMJH	10:59	0.93	2.30	130.76	18.32	1.82	2.70
VMJH	11:29	1.23	2.13	131.40	17.71	1.87	2.63
VMJH	11:59	2.27	3.67	150.38	20.44	2.46	3.03
VMJH	12:29	1.23	4.28	158.42	21.50	2.69	3.14
VMJH	12:59	2.67	4.14	157.77	21.42	2.73	3.15
VMJH	13:29	1.17	4.08	158.17	21.44	2.72	3.14
VMJH	13:59	1.67	4.07	158.86	21.61	2.73	3.15
VMJH	14:29	2.07	3.90	159.53	21.47	2.67	3.15
VMJH	15:00	1.71	3.72	158.53	21.54	2.69	3.16
VMZ		1.57	2.99	142.47	19.46	2.21	2.85

# Valori inregistrate MIR-IS HP-1500

Data:06/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.43	4.13	157.58	21.38	2.69	3.16
VMJH	07:59	1.47	4.24	158.53	21.64	2.70	3.14
VMJH	08:29	1.70	4.34	158.95	21.45	2.72	3.16
VMJH	08:59	1.30	4.16	158.77	21.26	2.74	3.15
VMJH	09:29	1.70	4.02	159.16	21.31	2.73	3.14
VMJH	09:59	2.00	4.05	158.05	21.25	2.67	3.16
VMJH	10:29	1.67	3.89	158.71	21.33	2.67	3.15
VMJH	10:59	1.93	4.06	156.59	21.30	2.76	3.15
VMJH	11:29	2.00	4.22	158.16	21.25	2.72	3.16
VMJH	11:59	1.73	4.14	159.64	21.31	2.77	3.15
VMJH	12:29	1.97	4.06	159.10	21.37	2.76	3.14
VMJH	12:59	1.23	4.12	159.41	21.39	2.69	3.15
VMJH	13:29	1.57	3.94	158.16	21.27	2.77	3.16
VMJH	13:59	1.63	4.13	158.74	21.56	2.73	3.14
VMJH	14:29	1.43	4.29	157.61	21.28	2.72	3.14
VMJH	14:43	2.43	4.04	158.02	21.68	2.72	3.15
VMZ		1.68	4.12	158.46	21.37	2.72	3.15

# Valori inregistrate MIR-IS HP-1500

Data:07/11/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	15:12	1.97	4.22	159.54	21.37	2.74	3.14
VMJH	15:42	1.40	4.11	159.79	21.49	2.67	3.16
VMJH	16:12	1.67	4.05	159.72	21.41	2.70	3.14
VMJH	16:42	1.07	4.13	159.65	21.29	2.70	3.15
VMJH	17:12	0.97	4.10	157.63	21.50	2.70	3.14
VMJH	17:42	1.10	4.30	158.33	21.40	2.73	3.15
VMJH	18:12	1.43	4.30	158.93	21.43	2.72	3.15
VMJH	18:42	1.53	4.00	157.44	21.33	2.76	3.15
VMJH	19:12	1.10	4.22	158.12	21.12	2.73	3.15
VMJH	19:42	0.93	4.06	158.42	21.46	2.70	3.16
VMJH	20:12	1.37	4.09	157.29	21.52	2.74	3.13
VMJH	20:42	1.30	4.05	157.97	21.33	2.69	3.14
VMJH	21:12	1.60	4.06	160.00	21.53	2.74	3.16
VMJH	21:42	0.90	4.18	156.65	21.38	2.73	3.15
VMJH	22:12	1.63	4.08	158.73	21.69	2.73	3.15
VMJH	22:44	1.66	3.97	158.23	21.65	2.70	3.15
VMZ		1.35	4.12	158.53	21.43	2.72	3.15



# Valori inregistrate MIR-IS HP-1500

Data:08/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:09	1.77	4.28	158.38	21.44	2.71	3.15
VMJH	15:39	2.00	4.12	157.96	21.51	2.68	3.15
VMJH	16:09	1.40	4.08	158.09	21.48	2.70	3.16
VMJH	16:39	1.87	4.05	158.85	21.18	2.72	3.16
VMJH	17:09	1.43	4.06	158.61	21.33	2.75	3.14
VMJH	17:39	1.57	4.18	157.50	21.38	2.66	3.14
VMJH	18:09	1.47	3.92	158.27	21.48	2.71	3.17
VMJH	18:39	0.87	4.28	158.40	21.60	2.70	3.14
VMJH	19:09	1.27	4.05	160.59	21.33	2.68	3.15
VMJH	19:39	2.43	3.73	155.03	21.17	2.56	3.07
VMJH	20:09	1.90	3.22	145.78	19.78	2.28	2.88
VMJH	20:39	1.23	3.24	144.78	19.57	2.25	2.89
VMJH	21:09	1.30	3.26	143.53	19.78	2.30	2.90
VMJH	21:39	1.37	3.11	145.30	19.71	2.26	2.89
VMJH	22:09	1.13	3.03	145.08	19.84	2.25	2.90
VMJH	22:39	1.07	3.01	143.87	19.67	2.27	2.88
VMJH	22:43	1.50	3.26	144.56	19.71	2.33	2.89
VMZ		1.50	3.72	153.04	20.76	2.53	3.05

# Valori inregistrate MIR-IS HP-1500

Data:09/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 15:11	1.33	2.94	144.67	19.50	2.26	2.89
VMJH 15:41	1.33	3.29	144.65	19.75	2.29	2.89
VMJH 16:11	1.13	3.36	145.77	19.51	2.27	2.89
VMJH 16:41	1.23	3.15	144.52	19.45	2.28	2.91
VMJH 17:11	1.00	3.18	145.56	19.96	2.25	2.91
VMJH 17:41	0.97	3.19	144.93	19.62	2.28	2.90
VMJH 18:11	1.93	2.96	144.41	19.76	2.28	2.89
VMJH 18:41	1.40	3.07	143.22	19.56	2.30	2.89
VMJH 19:11	1.47	3.14	144.79	19.67	2.30	2.87
VMJH 19:41	1.17	3.27	144.96	19.54	2.28	2.92
VMJH 20:11	1.87	3.18	145.32	19.49	2.31	2.88
VMJH 20:41	1.37	3.08	145.01	19.73	2.26	2.88
VMJH 21:11	0.90	3.13	144.31	19.53	2.29	2.87
VMJH 21:41	0.93	3.32	145.78	19.61	2.30	2.87
VMJH 22:11	0.87	3.19	143.41	19.69	2.26	2.89
VMJH 22:36	1.00	3.28	144.27	19.68	2.31	2.89
VMZ	1.25	3.17	144.71	19.63	2.28	2.89

# Valori inregistrate MIR-IS HP-1500

Data:10/11/2024

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	<b>VMA</b>	<b>VMA VMJH</b>	<b>VMA VMJH</b>	
	<b>10 30/10</b>	<b>50 200/50</b>	<b>100 400/200</b>	<b>50</b>	<b>10 20/10</b>	<b>10 60/10</b>	
VMJH	15:14	1.10	3.36	145.20	19.68	2.25	2.87
VMJH	15:44	1.07	3.17	144.60	19.75	2.24	2.90
VMJH	16:14	0.83	3.19	146.17	19.71	2.28	2.87
VMJH	16:44	1.10	3.16	145.26	19.69	2.30	2.89
VMJH	17:14	1.30	3.17	143.59	19.76	2.22	2.89
VMJH	17:44	1.23	3.26	144.55	19.62	2.34	2.89
VMJH	18:14	0.47	3.30	145.40	19.40	2.29	2.87
VMJH	18:44	1.00	3.12	144.63	19.64	2.26	2.92
VMJH	19:14	1.33	3.29	143.42	19.65	2.30	2.88
VMJH	19:44	1.53	3.16	146.34	19.87	2.31	2.91
VMJH	20:14	1.40	3.14	143.79	19.78	2.29	2.89
VMJH	20:44	1.30	3.17	144.20	19.53	2.30	2.89
VMJH	21:14	1.90	3.19	145.77	19.63	2.27	2.90
VMJH	21:44	1.60	3.17	143.88	19.65	2.24	2.88
VMJH	22:14	0.67	3.03	144.56	19.75	2.32	2.86
VMJH	22:40	1.42	3.09	143.45	19.80	2.29	2.88
VMZ		1.20	3.19	144.69	19.68	2.28	2.89



# Valori inregistrate MIR-IS HP-1500

Data:13/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 12:39	1.47	3.24	145.95	19.63	2.27	2.92
VMJH 13:09	1.70	3.07	144.92	19.50	2.28	2.88
VMJH 13:39	0.70	3.16	144.65	19.83	2.30	2.89
VMJH 14:09	0.80	3.11	145.43	19.67	2.28	2.90
VMJH 14:39	1.60	3.11	145.05	19.54	2.28	2.90
VMJH 15:09	1.03	3.26	144.90	19.55	2.31	2.91
VMJH 15:39	1.47	3.08	145.32	19.64	2.27	2.90
VMJH 16:09	1.83	3.29	144.98	19.59	2.24	2.90
VMJH 16:39	1.63	3.19	145.61	19.54	2.28	2.89
VMJH 17:09	2.27	3.14	145.54	19.73	2.29	2.90
VMJH 17:39	1.67	3.09	145.08	19.48	2.21	2.82
VMJH 18:09	1.67	3.29	145.42	19.41	2.26	2.83
VMJH 18:39	2.00	3.16	145.82	19.28	2.22	2.82
VMJH 19:09	1.37	3.40	145.34	19.57	2.23	2.84
VMJH 19:39	1.57	3.28	145.24	19.48	2.25	2.83
VMJH 20:09	1.27	3.18	146.21	19.52	2.25	2.84
VMJH 20:39	1.30	3.24	146.23	19.52	2.21	2.84
VMJH 21:09	1.40	3.46	145.00	19.39	2.24	2.81
VMJH 21:39	1.83	3.34	147.29	19.69	2.21	2.86
VMJH 22:09	1.77	3.32	144.92	19.67	2.24	2.86
VMJH 22:39	2.27	3.23	146.18	19.14	2.24	2.84
VMJH 22:48	1.56	3.24	146.20	19.41	2.23	2.84
VMZ	1.55	3.22	145.49	19.54	2.25	2.87

# Valori inregistrate MIR-IS HP-1500

Data:14/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:18	2.30	3.31	145.17	19.43	2.27	2.88
VMJH	15:48	1.43	3.18	145.55	19.39	2.27	2.83
VMJH	16:18	1.97	3.28	144.30	19.33	2.26	2.82
VMJH	16:48	1.73	3.34	146.56	19.41	2.23	2.86
VMJH	17:18	2.20	3.20	145.05	19.41	2.24	2.85
VMJH	17:48	1.30	3.27	145.91	19.40	2.25	2.85
VMJH	18:18	1.53	3.08	145.99	19.18	2.26	2.85
VMJH	18:48	1.83	3.24	144.80	19.33	2.24	2.84
VMJH	19:18	1.77	3.23	145.27	19.30	2.24	2.85
VMJH	19:48	1.97	3.25	145.41	19.26	2.22	2.85
VMJH	20:18	1.80	3.20	145.73	19.40	2.25	2.80
VMJH	20:48	1.57	3.28	145.19	19.61	2.24	2.87
VMJH	21:18	2.03	3.21	145.94	19.06	2.26	2.83
VMJH	21:48	1.87	3.35	145.63	19.17	2.20	2.84
VMJH	22:18	1.53	3.12	145.92	19.66	2.24	2.84
VMJH	22:43	0.88	3.23	146.22	19.54	2.22	2.84
VMZ		1.74	3.24	145.53	19.36	2.24	2.84

# Valori inregistrate MIR-IS HP-1500

Data:15/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:06	0.90	3.31	145.59	19.65	2.17	2.84
VMJH	15:36	1.60	3.25	145.35	19.70	2.20	2.84
VMJH	16:06	1.00	3.21	146.54	19.71	2.22	2.83
VMJH	16:36	1.43	3.34	144.85	19.71	2.26	2.88
VMJH	17:06	1.77	3.39	146.42	19.70	2.22	2.87
VMJH	17:36	1.17	3.13	146.61	19.37	2.21	2.85
VMJH	18:06	1.70	3.42	144.15	19.62	2.26	2.86
VMJH	18:36	2.20	3.08	145.56	19.37	2.19	2.82
VMJH	19:06	1.77	3.44	146.10	19.19	2.25	2.84
VMJH	19:36	1.43	3.15	144.00	19.50	2.21	2.83
VMJH	20:06	0.47	3.15	146.53	19.80	2.18	2.86
VMJH	20:36	0.63	3.17	146.15	19.51	2.27	2.83
VMJH	21:06	1.20	3.21	146.30	19.60	2.19	2.84
VMJH	21:36	1.47	3.26	145.10	19.32	2.23	2.85
VMJH	22:06	1.87	3.30	144.67	19.37	2.25	2.83
VMJH	22:36	2.03	3.36	145.02	19.56	2.24	2.85
VMJH	22:44	2.00	3.26	143.74	19.45	2.17	2.80
VMZ		1.43	3.26	145.53	19.54	2.22	2.84



# Valori inregistrate MIR-IS HP-1500

Data16/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.23	3.12	145.90	19.35	2.20	2.87
VMJH	07:59	1.67	3.29	145.01	19.44	2.24	2.88
VMJH	08:29	1.20	3.47	144.32	19.46	2.25	2.84
VMJH	08:59	1.20	3.29	145.25	19.40	2.20	2.86
VMJH	09:29	2.17	3.80	153.04	20.45	2.41	3.01
VMJH	09:59	1.43	4.06	160.28	21.17	2.62	3.15
VMJH	10:29	1.30	4.29	160.11	20.71	2.67	3.15
VMJH	10:59	1.67	4.31	159.43	21.12	2.57	3.16
VMJH	11:29	1.17	4.49	160.45	21.10	2.63	3.16
VMJH	11:59	1.07	4.23	160.51	21.32	2.56	3.14
VMJH	12:29	1.13	4.35	159.70	21.06	2.59	3.15
VMJH	12:59	0.63	4.28	160.10	20.97	2.59	3.14
VMJH	13:29	0.83	4.49	161.88	20.95	2.62	3.14
VMJH	13:59	0.67	4.36	159.03	20.93	2.54	3.13
VMJH	14:29	0.37	4.60	159.05	20.89	2.64	3.15
VMJH	14:59	1.13	4.21	159.38	20.78	2.58	3.16
VMJH	15:29	2.23	4.47	158.91	21.05	2.70	3.15
VMJH	15:59	2.30	4.27	159.93	20.96	2.71	3.16
VMJH	16:29	0.97	4.30	157.87	20.73	2.60	3.14
VMJH	16:59	1.43	4.29	160.01	20.90	2.64	3.17
VMJH	17:29	1.83	4.16	159.31	20.85	2.64	3.15
VMJH	17:59	1.30	4.36	160.20	20.92	2.65	3.15
VMJH	18:29	1.20	4.17	161.93	20.76	2.60	3.15
VMJH	18:59	1.20	4.38	159.19	21.04	2.66	3.15
VMJH	19:29	1.20	4.10	160.90	21.21	2.61	3.14
VMJH	19:59	1.30	4.37	160.37	20.97	2.60	3.15
VMJH	20:29	2.40	4.32	159.30	20.80	2.64	3.15
VMJH	20:59	1.57	4.35	159.63	21.12	2.68	3.15
VMJH	21:29	2.27	3.99	161.05	20.49	2.63	3.14
VMJH	21:59	1.73	4.50	159.29	21.01	2.60	3.15
VMJH	22:29	1.30	4.14	160.49	20.76	2.64	3.16
VMJH	22:57	2.25	4.24	160.36	21.08	2.60	3.16
VMZ		1.42	4.16	157.88	20.74	2.57	3.11

# Valori inregistrate MIR-IS HP-1500

Data 17/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:10	1.00	4.27	161.73	21.28	2.52	3.15
VMJH	15:40	1.50	4.30	159.18	21.19	2.60	3.15
VMJH	16:10	0.97	4.21	161.17	21.12	2.59	3.15
VMJH	16:40	2.03	4.60	159.73	21.13	2.62	3.16
VMJH	17:10	1.17	4.17	160.73	21.32	2.64	3.16
VMJH	17:40	2.43	4.23	160.76	20.87	2.59	3.15
VMJH	18:10	1.50	4.24	159.29	21.32	2.61	3.16
VMJH	18:40	0.90	4.42	160.27	20.64	2.60	3.15
VMJH	19:10	1.33	4.36	159.73	20.80	2.60	3.15
VMJH	19:40	1.53	4.22	158.02	21.27	2.61	3.14
VMJH	20:10	1.70	4.15	160.32	21.21	2.56	3.13
VMJH	20:40	1.17	4.26	161.12	21.13	2.67	3.14
VMJH	21:10	1.10	4.29	159.88	21.15	2.60	3.14
VMJH	21:40	1.87	4.49	159.97	20.80	2.64	3.15
VMJH	22:10	0.97	4.27	159.15	21.10	2.65	3.15
VMJH	22:40	0.87	4.67	159.86	20.91	2.65	3.15
VMJH	22:43	1.67	4.08	163.50	20.72	2.49	3.11
VMZ		1.38	4.32	160.08	21.08	2.61	3.15

# Valori inregistrate MIR-IS HP-1500

Data:20/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH 15:05	1.00	4.17	160.55	20.88	2.54	3.15
VMJH 15:35	1.50	4.46	159.23	20.71	2.61	3.15
VMJH 16:05	0.93	4.48	159.29	21.10	2.67	3.15
VMJH 16:35	1.00	4.20	158.34	21.13	2.55	3.15
VMJH 17:05	1.47	3.13	142.93	19.44	2.21	2.75
VMJH 17:35	1.10	2.05	130.47	18.06	1.83	2.53
VMJH 18:05	0.70	2.19	131.80	17.56	1.89	2.49
VMJH 18:35	0.80	2.31	130.32	17.95	1.88	2.54
VMJH 19:05	1.03	2.16	130.78	17.58	1.85	2.53
VMJH 19:35	1.23	2.27	130.72	18.04	1.88	2.51
VMJH 20:05	1.20	2.13	133.67	18.04	1.90	2.53
VMJH 20:35	0.80	2.32	131.12	17.74	1.83	2.52
VMJH 21:05	2.53	2.37	129.89	17.96	1.87	2.48
VMJH 21:35	1.60	2.31	132.86	18.78	1.89	2.58
VMJH 22:05	1.80	2.07	132.00	17.71	1.87	2.54
VMJH 22:35	2.50	2.18	133.21	17.81	1.85	2.57
VMJH 22:43	2.00	2.16	130.80	17.36	1.77	2.54
VMZ	1.34	2.79	139.05	18.76	2.06	2.70



# Valori inregistrate MIR-IS HP-1500

Data 21/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:29	1.57	2.20	130.76	17.91	1.90	2.57
VMJH	15:59	0.97	2.08	131.61	17.88	1.83	2.48
VMJH	16:29	1.00	2.34	131.52	17.74	1.87	2.57
VMJH	16:59	1.47	2.22	132.07	18.22	1.82	2.51
VMJH	17:29	1.57	2.33	130.67	17.63	1.86	2.54
VMJH	17:59	1.10	2.03	131.09	18.04	1.88	2.53
VMJH	18:29	0.70	2.07	131.40	17.48	1.89	2.58
VMJH	18:59	1.13	2.12	129.25	17.44	1.83	2.55
VMJH	19:29	0.77	2.28	130.59	17.61	1.86	2.51
VMJH	19:59	1.50	2.12	129.87	17.54	1.82	2.51
VMJH	20:29	1.93	2.06	132.73	18.25	1.86	2.54
VMJH	20:59	2.20	2.34	131.59	17.79	1.82	2.54
VMJH	21:29	1.67	2.36	131.07	17.62	1.86	2.55
VMJH	21:59	1.80	2.12	132.05	17.76	1.84	2.48
VMJH	22:29	1.83	2.22	130.06	18.38	1.81	2.54
VMJH	22:44	0.87	2.26	132.22	18.10	1.84	2.56
VMZ		1.40	2.19	131.13	17.83	1.85	2.53

# Valori inregistrate MIR-IS HP-1500

Data22/11/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50		10	20/10	10	60/10
VMJH	11:53	1.37	2.31	129.92	17.81	1.82	2.53					
VMJH	12:23	1.37	2.29	131.03	18.25	1.83	2.54					
VMJH	12:53	1.73	2.10	132.96	18.33	1.86	2.50					
VMJH	13:23	1.93	2.24	129.95	18.15	1.87	2.60					
VMJH	13:53	1.13	2.48	131.89	18.13	1.81	2.56					
VMJH	14:23	1.60	2.16	132.40	17.86	1.83	2.56					
VMJH	14:53	2.03	2.43	128.45	17.94	1.87	2.53					
VMJH	15:23	1.47	1.95	131.35	18.00	1.82	2.50					
VMJH	15:53	1.77	2.28	132.61	17.68	1.86	2.52					
VMJH	16:23	1.73	2.20	129.29	17.73	1.85	2.53					
VMJH	16:53	1.57	2.11	132.16	18.46	1.81	2.58					
VMJH	17:23	1.53	2.10	132.75	18.00	1.87	2.49					
VMJH	17:53	1.70	2.17	131.56	17.76	1.80	2.55					
VMJH	18:23	1.07	2.10	129.78	17.85	1.83	2.54					
VMJH	18:53	1.57	2.12	130.28	17.82	1.85	2.50					
VMJH	19:23	1.27	2.19	130.46	18.19	1.83	2.57					
VMJH	19:53	1.53	1.96	130.20	17.80	1.84	2.55					
VMJH	20:23	1.37	2.26	131.83	18.05	1.90	2.61					
VMJH	20:53	1.37	2.43	128.78	17.84	1.84	2.55					
VMJH	21:23	1.33	2.36	131.10	17.87	1.84	2.58					
VMJH	21:53	0.73	2.28	133.06	18.07	1.90	2.48					
VMJH	22:22	0.92	2.25	133.06	18.19	1.91	2.52					
VMJH	22:28	2.83	2.55	131.33	17.90	2.04	2.50					
VMZ		1.47	2.22	131.13	17.99	1.85	2.54					

# Valori inregistrate MIR-IS HP-1500

Data:23/11/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	14:29	1.33	2.43	131.77	17.78	1.93	2.56
VMJH	14:59	0.77	2.39	133.54	17.66	1.96	2.52
VMJH	15:29	1.13	2.25	133.12	18.20	1.92	2.55
VMJH	15:59	0.90	2.30	133.48	17.96	1.96	2.51
VMJH	16:29	1.57	2.10	134.17	17.64	1.95	2.51
VMJH	16:59	1.07	2.26	133.61	17.92	1.91	2.49
VMJH	17:29	1.30	2.05	133.09	17.73	1.92	2.58
VMJH	17:59	1.47	2.35	132.73	17.83	1.90	2.50
VMJH	18:29	1.50	2.15	132.70	17.97	1.96	2.55
VMJH	18:59	1.30	2.23	133.35	17.94	1.94	2.55
VMJH	19:29	2.03	2.11	134.27	18.06	1.95	2.53
VMJH	19:59	0.37	2.39	132.21	17.89	1.89	2.52
VMJH	20:29	1.67	2.10	131.97	18.50	1.91	2.52
VMJH	20:59	1.47	2.36	133.61	17.65	1.93	2.53
VMJH	21:29	0.93	2.21	132.68	17.15	1.98	2.57
VMJH	21:59	1.83	2.24	134.44	18.10	1.96	2.57
VMJH	22:29	1.20	2.27	131.44	17.75	1.91	2.55
VMJH	22:37	2.13	2.28	133.57	18.07	1.95	2.52
VMZ		1.30	2.25	133.08	17.87	1.93	2.54



# Valori inregistrate MIR-IS HP-1500

Data:24/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	15:05	1.53	2.19	133.31	17.64	1.89	2.52
VMJH	15:35	1.47	2.30	132.96	18.00	1.93	2.48
VMJH	16:05	1.00	2.32	133.45	17.95	1.90	2.51
VMJH	16:35	1.73	2.18	132.88	17.81	1.92	2.54
VMJH	17:05	1.00	2.36	134.46	17.62	1.92	2.52
VMJH	17:35	1.83	2.08	133.70	18.35	1.92	2.50
VMJH	18:05	1.80	2.25	133.46	17.68	1.91	2.57
VMJH	18:35	0.77	2.31	134.39	17.56	1.90	2.50
VMJH	19:05	2.03	2.37	133.26	17.92	1.95	2.55
VMJH	19:35	1.83	2.20	133.04	18.45	1.98	2.58
VMJH	20:05	1.87	1.90	132.93	18.09	1.96	2.56
VMJH	20:35	1.30	2.11	133.82	17.86	1.89	2.54
VMJH	21:05	0.73	2.33	133.38	18.18	1.88	2.57
VMJH	21:20	0.87	2.24	132.22	18.25	1.86	2.51
VMZ		1.43	2.22	133.42	17.94	1.92	2.53

# Valori inregistrate MIR-IS HP-1500

Data:27/11/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3		
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA VMJH	VMA VMJH		
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	15:12	1.63	2.24	133.25	18.42	1.95	2.51				
VMJH	15:42	1.97	2.01	135.40	17.98	1.94	2.47				
VMJH	16:12	0.70	2.18	134.29	18.03	1.89	2.59				
VMJH	16:42	2.20	2.22	132.50	18.39	1.92	2.58				
VMJH	17:12	0.97	2.33	133.47	17.96	1.99	2.51				
VMJH	17:42	1.07	2.11	133.91	17.78	1.94	2.55				
VMJH	18:12	1.77	2.14	133.46	17.97	1.93	2.54				
VMJH	18:42	2.27	2.16	132.58	17.71	1.90	2.56				
VMJH	19:12	1.77	2.30	134.28	17.80	1.91	2.50				
VMJH	19:42	1.23	2.26	132.74	18.30	1.91	2.46				
VMJH	20:12	1.30	2.08	133.16	18.40	1.92	2.53				
VMJH	20:42	0.90	2.26	134.95	17.66	1.96	2.52				
VMJH	21:12	1.47	2.24	134.00	17.19	1.95	2.56				
VMJH	21:42	0.93	2.18	134.19	18.31	1.93	2.60				
VMJH	22:12	1.07	2.29	133.65	18.24	1.94	2.58				
VMJH	22:36	0.83	2.25	133.53	18.02	1.94	2.53				
VMZ		1.39	2.20	133.71	18.01	1.93	2.54				

# Valori inregistrate MIR-IS HP-1500

Data:28/11/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	0.57	4.79	161.63	20.31	2.65	3.28
VMJH	07:59	1.27	4.91	161.63	20.44	2.69	3.28
VMJH	08:29	1.43	4.78	161.01	20.89	2.64	3.28
VMJH	08:59	1.00	4.68	159.24	20.63	2.65	3.29
VMJH	09:29	1.47	4.76	161.51	20.80	2.65	3.29
VMJH	09:59	0.90	4.89	160.77	20.69	2.65	3.27
VMJH	10:29	0.90	4.85	162.16	20.88	2.64	3.24
VMJH	10:59	1.80	4.98	160.84	21.13	2.64	3.26
VMJH	11:29	0.90	4.66	160.38	20.78	2.70	3.28
VMJH	11:59	1.47	5.06	162.30	20.14	2.66	3.28
VMJH	12:29	2.60	4.86	160.75	20.63	2.61	3.24
VMJH	12:59	1.47	4.82	160.89	20.77	2.64	3.29
VMJH	13:29	1.57	4.98	162.26	20.78	2.70	3.31
VMJH	13:59	2.77	4.98	159.72	20.61	2.68	3.28
VMJH	14:29	1.50	5.01	160.85	20.83	2.67	3.27
VMJH	14:59	1.00	4.34	160.46	20.10	2.68	3.25
VMJH	15:29	0.90	4.73	162.62	20.19	2.77	3.27
VMJH	15:59	0.67	5.03	161.65	20.51	2.66	3.26
VMJH	16:29	1.47	4.73	160.90	20.70	2.73	3.29
VMJH	16:59	2.03	4.55	160.27	20.90	2.68	3.27
VMJH	17:29	2.50	5.11	161.88	20.41	2.61	3.27
VMJH	17:59	2.23	4.62	160.73	20.85	2.68	3.32
VMJH	18:29	1.43	4.80	161.06	20.56	2.66	3.27
VMJH	18:59	2.50	4.58	161.96	20.60	2.68	3.26
VMJH	19:29	1.17	5.04	162.22	20.60	2.59	3.26
VMJH	19:59	2.13	4.58	161.92	20.82	2.66	3.26
VMJH	20:29	1.30	4.64	160.40	20.42	2.76	3.30
VMJH	20:59	1.57	4.88	161.42	20.46	2.68	3.25
VMJH	21:29	2.57	4.76	161.78	20.91	2.69	3.26
VMJH	21:59	1.27	4.60	161.00	20.44	2.56	3.25
VMJH	22:29	1.50	4.79	162.28	20.51	2.64	3.24
VMJH	22:44	0.73	4.56	161.35	20.34	2.71	3.26
VMZ		1.53	4.80	161.24	20.62	2.67	3.27



# Valori inregistrate MIR-IS HP-1500

Data:29/11/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3	COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10
VMJH	06:29	1.20	4.76	161.89	20.41	2.60	3.28				
VMJH	06:59	1.80	4.65	161.61	20.51	2.72	3.25				
VMJH	07:29	1.33	4.81	161.07	20.86	2.70	3.26				
VMJH	07:59	2.40	4.99	161.00	20.68	2.57	3.29				
VMJH	08:29	1.17	4.94	162.08	20.38	2.68	3.27				
VMJH	08:59	1.00	4.71	159.71	20.65	2.62	3.29				
VMJH	09:29	2.43	4.65	160.44	20.46	2.66	3.29				
VMJH	09:59	1.67	5.00	160.55	20.90	2.70	3.29				
VMJH	10:29	2.23	4.90	161.76	20.43	2.70	3.26				
VMJH	10:59	1.30	4.66	159.54	20.45	2.65	3.27				
VMJH	11:29	3.70	4.68	161.03	20.30	2.68	3.27				
VMJH	11:59	0.77	4.81	162.29	20.36	2.70	3.30				
VMJH	12:29	2.57	4.59	158.97	20.58	2.66	3.31				
VMJH	12:59	2.43	5.00	160.42	20.32	2.68	3.23				
VMJH	13:29	3.33	4.84	160.03	20.11	2.75	3.24				
VMJH	13:59	2.13	4.64	159.75	20.54	2.62	3.26				
VMJH	14:29	2.87	4.19	154.30	19.80	2.52	3.09				
VMJH	14:59	2.40	3.55	147.25	19.34	2.30	2.90				
VMJH	15:29	1.73	3.60	146.84	19.26	2.30	2.91				
VMJH	15:59	2.10	3.66	146.54	19.16	2.31	2.91				
VMJH	16:29	1.70	3.52	146.84	19.42	2.28	2.92				
VMJH	16:59	1.47	3.56	147.18	19.46	2.31	2.90				
VMJH	17:29	1.77	3.45	148.26	19.08	2.29	2.88				
VMJH	17:59	1.60	3.52	147.27	19.54	2.28	2.86				
VMJH	18:29	1.80	3.54	147.27	19.34	2.30	2.93				
VMJH	18:59	1.83	3.58	146.70	19.28	2.27	2.89				
VMJH	19:29	2.37	3.53	147.12	18.88	2.31	2.91				
VMJH	19:59	1.57	3.47	146.77	19.50	2.27	2.91				
VMJH	20:29	1.37	3.65	147.87	19.43	2.34	2.91				
VMJH	20:59	1.40	3.69	147.17	19.27	2.25	2.91				
VMJH	21:29	1.60	3.44	145.72	19.63	2.30	2.90				
VMJH	21:59	1.03	3.47	146.92	19.07	2.30	2.89				
VMJH	22:15	0.63	3.42	146.71	18.71	2.34	2.92				
VMZ		1.86	4.18	154.01	19.90	2.49	3.09				

# Valori inregistrate MIR-IS HP-1500

Data:04/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	08:39	1.23	2.84	132.89	16.41	1.92	2.49
VMJH	09:09	0.83	2.88	133.35	17.04	1.95	2.50
VMJH	09:39	0.80	2.80	132.04	16.21	1.90	2.51
VMJH	10:09	0.33	2.84	131.02	17.02	1.90	2.55
VMJH	10:39	1.17	2.75	132.20	16.17	1.92	2.56
VMJH	11:09	1.13	2.85	133.56	16.73	1.91	2.53
VMJH	11:39	1.43	2.88	132.44	16.02	1.96	2.50
VMJH	12:09	0.93	2.84	131.71	16.20	1.91	2.49
VMJH	12:39	1.23	2.86	132.21	17.14	1.94	2.50
VMJH	13:09	1.50	2.92	133.64	16.56	1.93	2.53
VMJH	13:39	0.80	2.88	132.35	17.22	1.91	2.52
VMJH	14:09	0.77	2.87	132.37	16.72	1.91	2.49
VMJH	14:39	0.80	2.82	133.31	16.21	1.88	2.49
VMJH	15:09	1.03	2.82	132.05	16.62	1.97	2.59
VMJH	15:39	0.37	2.89	133.12	16.68	1.89	2.54
VMJH	16:09	0.57	2.85	131.39	16.65	1.96	2.56
VMJH	16:39	0.97	2.83	132.71	16.21	1.90	2.54
VMJH	17:09	0.90	2.76	132.36	16.66	1.89	2.52
VMJH	17:39	0.60	2.84	132.77	16.89	1.94	2.50
VMJH	18:09	0.93	2.82	132.37	16.80	1.88	2.57
VMJH	18:39	0.90	2.85	132.68	17.26	1.97	2.54
VMJH	19:09	1.07	2.88	133.29	16.64	1.99	2.58
VMJH	19:39	1.57	2.89	133.73	16.19	1.92	2.53
VMJH	20:09	0.83	2.83	132.85	16.57	1.94	2.50
VMJH	20:39	0.40	2.85	132.86	16.71	1.94	2.57
VMJH	21:09	0.50	2.83	133.71	16.69	1.93	2.53
VMJH	21:39	0.60	2.85	131.58	17.43	1.91	2.59
VMJH	22:09	0.83	2.86	130.51	17.07	1.92	2.55
VMJH	22:32	0.52	2.86	132.86	16.84	1.90	2.55
VMZ		0.88	2.85	132.55	16.67	1.92	2.53



# Valori inregistrate MIR-IS HP-1500

Data:05/12/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	3.27	2.86	132.65	16.64	1.95	2.48
VMJH	07:59	2.23	2.85	132.65	16.45	1.93	2.53
VMJH	08:29	2.60	2.77	131.77	16.78	1.93	2.54
VMJH	08:59	2.47	2.82	133.10	16.08	1.95	2.54
VMJH	09:29	2.60	2.86	133.81	16.90	1.90	2.56
VMJH	09:59	2.60	2.80	131.91	16.88	1.92	2.52
VMJH	10:29	2.20	2.83	132.39	16.53	1.91	2.52
VMJH	10:59	2.67	2.85	132.40	16.29	1.89	2.51
VMJH	11:29	2.63	2.86	132.26	16.13	1.93	2.47
VMJH	11:59	2.97	2.79	132.57	17.01	1.92	2.51
VMJH	12:29	2.20	2.85	133.92	16.95	1.90	2.47
VMJH	12:59	2.57	2.86	131.71	16.58	1.96	2.55
VMJH	13:29	2.20	2.79	131.77	16.99	1.91	2.58
VMJH	13:59	2.20	2.88	132.94	15.81	1.95	2.52
VMJH	14:29	2.23	2.92	132.67	15.63	1.92	2.50
VMJH	14:59	2.43	2.82	131.75	17.09	1.96	2.52
VMJH	15:29	1.93	3.74	149.73	18.10	2.22	2.95
VMJH	15:59	2.57	4.97	165.34	20.75	2.61	3.31
VMJH	16:29	2.63	4.89	163.17	20.53	2.55	3.32
VMJH	16:59	2.63	4.59	164.21	20.88	2.63	3.31
VMJH	17:29	2.27	4.82	162.84	20.31	2.54	3.35
VMJH	17:59	2.43	4.81	165.80	20.41	2.58	3.32
VMJH	18:29	2.20	4.73	163.82	20.98	2.58	3.32
VMJH	18:59	2.10	4.77	164.25	20.43	2.58	3.29
VMJH	19:29	1.97	4.68	162.40	20.67	2.54	3.34
VMJH	19:59	1.73	4.99	162.99	20.51	2.49	3.28
VMJH	20:29	1.73	4.43	164.20	20.59	2.59	3.31
VMJH	20:59	1.23	4.72	163.83	20.86	2.47	3.31
VMJH	21:29	1.60	4.87	163.18	20.66	2.47	3.27
VMJH	21:59	1.47	4.52	161.91	20.67	2.61	3.30
VMJH	22:32	2.00	4.42	162.65	20.54	2.57	3.31
VMZ		2.28	3.72	147.16	18.45	2.22	2.89



# Valori inregistrate MIR-IS HP-1500

Data:06/12/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.43	4.78	164.44	20.64	2.48	3.33
VMJH	07:59	3.47	4.61	165.39	20.69	2.54	3.28
VMJH	08:29	2.70	4.70	163.11	21.04	2.54	3.31
VMJH	08:59	2.73	4.62	163.92	20.71	2.48	3.32
VMJH	09:29	2.10	5.05	162.58	20.75	2.43	3.31
VMJH	09:59	3.83	4.70	161.00	20.58	2.44	3.27
VMJH	10:29	2.37	4.45	164.24	20.56	2.54	3.33
VMJH	10:59	1.37	4.61	163.58	20.20	2.47	3.31
VMJH	11:29	3.53	4.91	162.33	20.25	2.57	3.29
VMJH	11:59	2.50	4.70	164.53	20.71	2.50	3.32
VMJH	12:29	2.37	5.07	163.84	20.80	2.54	3.28
VMJH	12:59	1.60	4.66	163.22	20.78	2.46	3.33
VMJH	13:29	1.53	5.04	162.44	20.55	2.50	3.32
VMJH	13:59	2.77	4.71	163.92	20.34	2.54	3.30
VMJH	14:29	2.00	5.02	164.20	20.31	2.53	3.32
VMJH	14:59	3.00	4.67	165.79	20.56	2.59	3.34
VMJH	15:29	2.80	4.81	165.40	20.67	2.55	3.29
VMJH	15:59	2.83	4.46	163.44	20.55	2.55	3.27
VMJH	16:29	1.67	4.96	164.14	20.62	2.57	3.28
VMJH	16:59	0.50	5.08	165.73	20.63	2.50	3.30
VMJH	17:29	0.83	4.90	161.95	20.26	2.54	3.32
VMJH	17:59	0.47	4.85	164.60	20.36	2.43	3.29
VMJH	18:29	1.07	4.73	161.89	20.50	2.57	3.31
VMJH	18:59	0.73	4.72	164.55	20.38	2.59	3.34
VMJH	19:29	1.07	4.86	164.80	20.53	2.58	3.29
VMJH	19:59	0.97	4.64	162.82	20.41	2.57	3.32
VMJH	20:29	1.00	4.74	162.67	20.51	2.59	3.30
VMJH	20:59	0.90	4.89	164.62	20.55	2.64	3.34
VMJH	21:29	1.03	4.84	164.22	20.74	2.53	3.28
VMJH	21:59	0.47	4.62	161.00	20.71	2.66	3.31
VMJH	22:20	0.81	4.81	163.35	19.57	2.55	3.33
VMZ		1.83	4.78	163.67	20.54	2.53	3.31

# Valori inregistrate MIR-IS HP-1500

Data:07/12/2023

	Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.97	5.02	164.90	20.46	2.39	3.31
VMJH	07:59	2.20	4.59	165.31	20.75	2.56	3.31
VMJH	08:29	3.20	4.33	158.72	20.45	2.50	3.20
VMJH	08:59	1.57	3.84	148.67	18.62	2.24	2.89
VMJH	09:29	1.50	3.80	148.69	18.83	2.27	2.89
VMJH	09:59	2.67	3.74	147.49	18.47	2.23	2.93
VMJH	10:29	2.70	3.77	147.92	18.55	2.22	2.96
VMJH	10:59	1.90	3.85	148.44	18.29	2.26	2.94
VMJH	11:29	1.83	3.72	148.42	18.65	2.26	2.93
VMJH	11:59	1.57	3.86	148.27	18.36	2.24	2.88
VMJH	12:29	2.00	3.78	147.91	18.74	2.27	2.92
VMJH	12:59	2.33	3.88	147.26	18.71	2.17	2.89
VMJH	13:29	0.43	3.76	148.51	18.55	2.27	2.92
VMJH	13:59	0.37	3.71	148.71	19.15	2.20	2.90
VMJH	14:29	1.30	3.97	147.64	18.29	2.18	2.89
VMJH	14:59	0.57	3.58	147.57	18.70	2.24	2.91
VMJH	15:29	1.37	3.70	146.87	18.62	2.29	2.94
VMJH	15:59	1.13	3.67	148.91	18.71	2.20	2.93
VMJH	16:29	0.60	3.87	148.66	18.60	2.22	2.92
VMJH	16:59	0.63	3.72	147.90	18.58	2.21	2.91
VMJH	17:29	0.83	3.67	147.33	18.73	2.22	2.93
VMJH	17:59	0.50	3.92	148.18	18.96	2.20	2.92
VMJH	18:29	0.77	3.82	147.14	18.69	2.12	2.92
VMJH	18:59	0.77	3.67	148.08	19.02	2.25	2.92
VMJH	19:29	0.70	3.74	149.07	18.23	2.24	2.94
VMJH	19:59	0.80	3.85	147.48	18.20	2.23	2.90
VMJH	20:29	0.40	3.73	148.78	18.52	2.23	2.93
VMJH	20:59	0.53	4.01	148.75	18.79	2.26	2.91
VMJH	21:29	0.67	3.76	147.29	18.81	2.19	2.93
VMJH	21:59	0.93	3.94	147.50	18.94	2.21	2.95
VMJH	22:11	0.42	3.88	147.47	18.98	2.21	2.93
VMZ		1.28	3.88	149.52	18.83	2.25	2.95



# Valori inregistrate MIR-IS HP-1500

Data:08/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	100 400/200	50	10 20/10	10 60/10	
VMJH	10:41	2.23	3.81	147.91	18.74	2.22	2.93
VMJH	11:11	1.67	3.83	148.36	18.51	2.22	2.94
VMJH	11:41	1.50	3.82	148.69	18.50	2.26	2.92
VMJH	12:11	2.13	3.77	148.94	18.33	2.22	2.93
VMJH	12:41	1.00	3.72	147.33	18.67	2.24	2.89
VMJH	13:11	2.03	3.94	149.11	18.54	2.24	2.91
VMJH	13:41	3.30	3.90	148.62	18.58	2.21	2.92
VMJH	14:11	3.07	3.81	147.59	18.23	2.24	2.92
VMJH	14:41	2.47	3.89	148.45	18.79	2.17	2.92
VMJH	15:11	2.93	3.73	147.46	18.54	2.24	2.93
VMJH	15:41	2.50	3.80	148.56	18.59	2.26	2.91
VMJH	16:11	1.33	3.88	148.32	18.20	2.22	2.92
VMJH	16:41	1.43	3.71	147.36	18.41	2.29	2.90
VMJH	17:11	1.23	3.71	148.57	18.91	2.24	2.91
VMJH	17:41	2.47	3.94	148.41	18.49	2.26	2.88
VMJH	18:11	2.60	3.85	147.95	18.82	2.26	2.95
VMJH	18:41	1.80	3.73	146.75	18.74	2.27	2.95
VMJH	19:11	0.57	3.81	148.67	17.72	2.22	2.89
VMJH	19:41	0.90	3.99	148.42	18.36	2.17	2.93
VMJH	20:11	1.17	3.69	148.07	18.93	2.31	2.91
VMJH	20:41	0.80	3.86	148.94	18.48	2.27	2.95
VMJH	21:11	1.93	4.04	150.40	18.46	2.30	2.93
VMJH	21:41	1.87	3.99	150.02	18.23	2.25	2.95
VMJH	22:11	1.10	3.90	149.95	18.39	2.29	2.95
VMJH	22:41	1.23	3.88	149.44	17.85	2.30	2.97
VMJH	22:45	0.75	3.67	151.46	17.93	2.35	2.95
VMZ		1.80	3.84	148.51	18.48	2.25	2.92



# Valori inregistrate MIR-IS HP-1500

Data:11/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	15:39	2.60	3.97	150.89	18.16	2.25	2.98
VMJH	16:09	2.23	4.04	149.38	17.78	2.34	2.96
VMJH	16:39	1.63	4.12	148.78	18.11	2.28	2.94
VMJH	17:09	2.13	4.00	150.43	18.08	2.25	2.93
VMJH	17:39	2.67	4.05	150.02	18.61	2.25	2.93
VMJH	18:09	2.23	4.05	150.39	17.83	2.34	2.94
VMJH	18:39	2.67	4.05	150.18	18.18	2.35	2.94
VMJH	19:09	1.37	3.93	150.51	18.18	2.36	2.91
VMJH	19:39	2.23	4.05	151.80	18.01	2.32	2.94
VMJH	20:09	2.43	3.98	150.86	18.03	2.34	2.95
VMJH	20:39	2.63	3.96	150.51	17.52	2.29	2.91
VMJH	21:09	3.00	4.09	150.64	17.79	2.26	2.94
VMJH	21:39	1.93	4.12	150.06	18.57	2.32	2.99
VMJH	22:09	1.80	4.01	149.53	18.26	2.25	2.98
VMJH	22:36	2.26	4.01	149.94	18.19	2.29	2.96
VMZ		2.26	4.03	150.26	18.09	2.30	2.95

# Valori inregistrate MIR-IS HP-1500

Data:12/12/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.67	3.84	150.07	17.93	2.31	2.93
VMJH	07:59	2.87	4.00	149.92	17.65	2.29	2.91
VMJH	08:29	1.43	4.15	150.11	18.28	2.29	2.99
VMJH	08:59	2.47	4.04	150.98	18.22	2.27	2.92
VMJH	09:29	1.37	4.17	149.55	17.91	2.25	2.93
VMJH	09:59	1.00	3.86	149.27	17.97	2.31	2.96
VMJH	10:29	1.00	3.86	149.96	18.42	2.27	2.94
VMJH	10:59	2.47	3.96	149.60	18.02	2.34	2.93
VMJH	11:29	2.23	3.96	150.58	18.41	2.32	2.97
VMJH	11:59	2.17	3.89	149.98	17.62	2.33	2.94
VMJH	12:29	1.60	3.95	149.63	18.54	2.31	2.94
VMJH	12:59	1.57	4.06	150.45	18.05	2.32	2.97
VMJH	13:29	2.40	4.11	149.81	17.56	2.27	2.93
VMJH	13:59	2.67	3.94	148.66	18.07	2.30	2.92
VMJH	14:29	2.70	4.01	149.82	18.20	2.30	2.99
VMJH	14:59	1.30	3.97	149.04	18.37	2.27	2.97
VMJH	15:29	0.60	4.00	150.35	17.94	2.29	2.95
VMJH	15:59	0.80	4.02	150.61	18.24	2.30	2.93
VMJH	16:29	0.73	4.05	149.49	17.66	2.31	2.93
VMJH	16:59	0.70	3.90	149.20	18.25	2.33	2.93
VMJH	17:29	1.77	4.13	149.31	17.98	2.26	2.98
VMJH	17:59	0.83	3.79	149.64	18.45	2.33	2.94
VMJH	18:29	1.70	3.79	149.12	17.91	2.33	2.97
VMJH	18:59	0.93	4.01	150.98	17.80	2.39	2.95
VMJH	19:29	0.53	4.00	148.96	17.87	2.26	2.95
VMJH	19:59	0.67	4.03	149.64	18.32	2.19	2.97
VMJH	20:29	0.90	4.00	149.53	17.80	2.36	2.91
VMJH	20:59	0.33	3.87	150.10	18.47	2.31	2.97
VMJH	21:29	0.53	4.59	159.85	19.24	2.48	3.21
VMJH	21:59	0.90	4.73	164.85	19.50	2.54	3.30
VMJH	22:29	1.10	4.71	162.69	19.88	2.48	3.30
VMJH	22:44	2.13	4.68	165.48	19.64	2.63	3.32
VMZ		1.43	4.05	151.26	18.23	2.32	2.98

# Valori inregistrate MIR-IS HP-1500

Data:13/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	2.47	4.51	162.91	19.66	2.52	3.32
VMJH	07:59	2.30	4.42	163.26	19.21	2.47	3.28
VMJH	08:29	2.07	4.53	164.64	19.07	2.58	3.32
VMJH	08:59	1.17	4.93	160.66	19.48	2.52	3.30
VMJH	09:29	2.43	4.91	164.04	19.04	2.50	3.29
VMJH	09:59	2.40	4.75	163.09	19.74	2.47	3.32
VMJH	10:29	0.50	5.02	163.04	19.35	2.44	3.31
VMJH	10:59	0.43	4.81	163.94	19.80	2.69	3.30
VMJH	11:29	1.13	4.65	165.16	19.59	2.64	3.30
VMJH	11:59	1.43	4.73	164.69	19.55	2.48	3.30
VMJH	12:29	0.67	4.78	166.36	18.82	2.51	3.31
VMJH	12:59	1.77	4.57	164.86	19.52	2.61	3.29
VMJH	13:29	2.33	4.94	165.23	18.65	2.57	3.31
VMJH	13:59	3.17	4.79	163.71	19.58	2.49	3.29
VMJH	14:29	1.27	4.90	162.45	20.21	2.55	3.33
VMJH	14:59	1.10	5.09	164.87	19.74	2.44	3.32
VMJH	15:29	2.07	4.44	163.01	19.89	2.56	3.31
VMJH	15:59	2.80	4.49	163.40	19.42	2.51	3.35
VMJH	16:29	1.10	4.83	163.54	18.83	2.42	3.31
VMJH	16:59	1.83	5.10	164.48	19.72	2.56	3.32
VMJH	17:29	2.07	4.65	164.72	19.65	2.50	3.29
VMJH	17:59	1.07	4.69	161.58	19.04	2.47	3.29
VMJH	18:29	1.27	4.39	162.26	19.66	2.54	3.29
VMJH	18:59	2.13	4.50	162.63	19.82	2.54	3.29
VMJH	19:29	2.03	4.87	163.78	19.28	2.53	3.30
VMJH	19:59	0.90	4.52	163.35	19.83	2.55	3.32
VMJH	20:29	0.87	4.54	163.74	19.54	2.61	3.32
VMJH	20:59	0.97	4.64	163.87	20.16	2.63	3.30
VMJH	21:29	1.17	4.93	163.61	19.35	2.54	3.32
VMJH	21:59	0.17	4.66	161.12	19.36	2.45	3.32
VMJH	22:30	1.71	4.73	164.17	19.19	2.56	3.30
VMZ		1.57	4.72	163.62	19.48	2.53	3.31



# Valori inregistrate MIR-IS HP-1500

Data:14/12/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	100	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.60	4.69	161.97	19.28	2.54	3.32						
VMJH	07:59	2.00	4.77	162.15	19.88	2.45	3.31						
VMJH	08:29	2.00	4.76	165.11	19.43	2.59	3.31						
VMJH	08:59	2.23	4.82	163.80	19.13	2.51	3.31						
VMJH	09:29	2.80	4.56	162.83	19.40	2.54	3.30						
VMJH	09:59	2.03	4.81	160.38	19.39	2.51	3.31						
VMJH	10:29	1.80	4.62	162.03	19.82	2.48	3.31						
VMJH	10:59	1.43	4.28	161.76	20.21	2.69	3.30						
VMJH	11:29	1.23	4.62	164.37	19.48	2.65	3.32						
VMJH	11:59	2.63	4.65	163.15	19.99	2.53	3.31						
VMJH	12:29	1.57	4.59	161.81	19.71	2.40	3.35						
VMJH	12:59	2.03	4.67	164.32	19.50	2.54	3.32						
VMJH	13:29	1.37	4.66	162.38	19.46	2.49	3.29						
VMJH	13:59	1.00	4.23	158.72	19.20	2.48	3.13						
VMJH	14:29	1.40	3.38	136.61	17.30	2.02	2.59						
VMJH	14:59	2.03	3.26	136.09	17.00	2.04	2.52						
VMJH	15:29	1.03	3.20	137.42	16.75	2.02	2.63						
VMJH	15:59	1.43	3.29	136.09	16.72	2.03	2.60						
VMJH	16:29	0.83	3.37	135.90	16.27	2.09	2.64						
VMJH	16:59	2.03	3.40	136.92	16.98	2.06	2.60						
VMJH	17:29	1.17	3.20	136.48	16.57	2.05	2.62						
VMJH	17:59	0.33	3.30	136.62	16.96	2.04	2.58						
VMJH	18:29	1.17	3.27	137.25	17.20	2.10	2.57						
VMJH	18:59	1.87	3.16	136.39	17.15	2.01	2.54						
VMJH	19:29	0.87	3.29	136.64	16.12	2.05	2.54						
VMJH	19:59	1.83	3.26	136.47	16.91	2.12	2.60						
VMJH	20:29	1.10	3.36	136.07	17.01	2.16	2.54						
VMJH	20:59	0.80	3.16	137.11	16.50	2.07	2.57						
VMJH	21:29	1.37	3.31	136.56	16.51	2.08	2.58						
VMJH	21:59	1.17	3.18	135.79	16.33	2.00	2.55						
VMJH	22:15	0.56	3.28	136.51	16.23	2.04	2.55						
VMZ		1.52	3.89	148.42	18.04	2.27	2.91						

# Valori inregistrate MIR-IS HP-1500

Data:15/12/2023

	Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1
		mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3
		VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH
		10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10
VMJH	07:29	1.80	3.29	136.97	16.85	2.11	2.66
VMJH	07:59	2.50	3.23	136.18	16.79	2.06	2.62
VMJH	08:29	1.37	3.26	136.22	16.57	2.08	2.62
VMJH	08:59	1.37	3.28	136.57	16.13	2.07	2.54
VMJH	09:29	1.77	3.31	136.70	16.60	2.13	2.51
VMJH	09:59	1.63	3.23	136.56	16.95	2.06	2.64
VMJH	10:29	1.23	3.42	136.77	17.18	1.97	2.54
VMJH	10:59	1.83	3.34	136.49	16.43	2.11	2.58
VMJH	11:29	2.27	3.23	136.21	16.61	2.09	2.63
VMJH	11:59	2.33	3.28	136.98	16.46	2.02	2.59
VMJH	12:29	2.10	3.34	136.25	16.69	2.11	2.57
VMJH	12:59	1.73	3.18	136.79	16.71	2.06	2.60
VMJH	13:29	0.80	3.27	136.39	16.34	2.11	2.55
VMJH	13:59	1.23	3.30	136.31	16.95	2.03	2.60
VMJH	14:29	1.13	3.39	136.72	16.15	2.04	2.62
VMJH	14:59	2.40	3.24	136.60	16.50	2.05	2.54
VMJH	15:29	2.20	3.26	136.09	16.53	2.08	2.58
VMJH	15:59	1.53	3.22	135.97	16.94	2.09	2.62
VMJH	16:29	1.47	3.28	136.10	17.31	2.01	2.66
VMJH	16:59	1.33	3.32	136.46	16.05	2.04	2.57
VMJH	17:29	0.67	3.28	136.72	17.33	2.04	2.53
VMJH	17:59	0.97	3.24	137.35	16.40	2.13	2.57
VMJH	18:29	1.30	3.20	136.74	16.68	2.04	2.57
VMJH	18:59	1.23	3.48	136.13	16.62	2.07	2.64
VMJH	19:29	0.83	3.16	136.85	16.79	2.09	2.62
VMJH	19:59	1.63	3.24	136.36	16.07	2.04	2.60
VMJH	20:29	1.33	3.33	136.94	15.98	2.10	2.61
VMJH	20:59	1.47	3.40	136.82	15.67	2.08	2.60
VMJH	21:29	1.00	3.34	135.78	17.13	2.00	2.58
VMJH	21:59	1.23	3.25	135.99	16.22	2.10	2.55
VMJH	22:29	1.97	3.15	136.49	17.03	2.06	2.61
VMJH	23:00	1.84	2.68	134.42	17.20	2.22	2.89
VMZ		1.55	3.26	136.43	16.62	2.07	2.60



# Valori inregistrate MIR-IS HP-1500

Data:18/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	08:04	2.57	2.57	133.61	17.56	2.29	2.94
VMJH	08:34	2.47	2.66	133.04	17.29	2.27	2.99
VMJH	09:04	2.07	2.57	134.12	16.70	2.26	2.94
VMJH	09:34	1.63	2.63	133.65	16.98	2.32	2.98
VMJH	10:04	1.50	2.48	133.89	16.56	2.25	2.99
VMJH	10:34	2.20	2.56	134.69	17.17	2.23	2.98
VMJH	11:04	1.73	2.59	133.89	17.28	2.33	2.98
VMJH	11:34	1.63	2.69	133.56	17.39	2.27	3.00
VMJH	12:04	1.77	2.65	133.51	16.56	2.31	3.00
VMJH	12:34	1.87	2.43	133.53	16.70	2.38	2.95
VMJH	13:04	2.03	2.56	133.94	16.88	2.28	2.93
VMJH	13:34	2.43	2.58	134.13	17.05	2.27	2.94
VMJH	14:04	2.33	2.67	133.00	16.93	2.29	2.99
VMJH	14:34	1.97	2.44	132.81	17.10	2.26	2.97
VMJH	15:04	1.50	2.61	134.27	17.12	2.31	3.00
VMJH	15:34	0.33	2.52	133.20	16.66	2.31	2.96
VMJH	16:04	0.47	2.59	134.39	16.66	2.33	2.95
VMJH	16:34	0.87	2.40	132.54	17.54	2.30	3.00
VMJH	17:04	0.67	2.55	133.76	17.37	2.38	2.97
VMJH	17:34	0.93	2.57	133.69	16.23	2.44	3.00
VMJH	18:04	0.63	2.53	131.82	17.49	2.27	2.97
VMJH	18:34	1.20	2.61	132.31	16.53	2.45	2.95
VMJH	19:04	1.60	2.74	133.97	16.97	2.33	2.99
VMJH	19:34	0.93	2.52	133.37	17.01	2.32	2.93
VMJH	20:04	1.47	2.46	133.50	17.35	2.33	2.96
VMJH	20:34	1.77	2.58	132.93	16.59	2.34	2.98
VMJH	21:04	0.97	2.64	133.97	17.57	2.33	2.94
VMJH	21:34	0.80	2.64	133.10	16.87	2.28	2.93
VMJH	22:04	0.93	2.54	132.32	17.25	2.32	2.99
VMJH	22:34	0.80	2.52	134.02	17.01	2.37	2.94
VMJH	23:04	1.07	2.59	133.81	16.88	2.37	3.01
VMJH	23:12	0.63	2.55	133.18	16.77	2.26	2.91
VMZ		1.45	2.57	133.49	17.01	2.32	2.97



# Valori inregistrate MIR-IS HP-1500

Data:19/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:59	2.17	2.47	133.94	17.21	2.38	2.99
VMJH	08:29	2.30	2.43	132.99	17.37	2.31	3.00
VMJH	08:59	2.10	2.53	133.04	17.23	2.38	2.95
VMJH	09:29	2.03	2.65	133.85	17.11	2.36	2.98
VMJH	09:59	1.90	2.54	133.13	16.46	2.37	2.94
VMJH	10:29	1.97	2.46	134.42	16.65	2.33	2.90
VMJH	10:59	2.17	2.57	134.07	17.45	2.39	2.95
VMJH	11:29	2.13	2.70	134.38	16.53	2.35	2.96
VMJH	11:59	2.87	2.55	132.64	17.14	2.37	2.95
VMJH	12:29	2.40	2.50	133.20	17.28	2.38	2.95
VMJH	12:59	2.10	2.72	133.90	17.73	2.35	3.00
VMJH	13:29	2.87	2.62	133.71	16.88	2.34	3.05
VMJH	13:59	2.77	2.64	134.24	17.36	2.30	2.96
VMJH	14:29	1.93	2.41	133.69	17.20	2.23	2.98
VMJH	14:59	2.00	2.38	133.05	17.62	2.35	3.02
VMJH	15:29	1.83	2.82	136.29	16.68	2.39	3.03
VMJH	15:59	1.23	4.71	163.91	20.05	2.51	3.30
VMJH	16:29	1.27	4.57	164.07	19.58	2.55	3.33
VMJH	16:59	1.00	4.87	162.95	18.20	2.53	3.33
VMJH	17:29	1.07	4.96	164.99	19.39	2.57	3.30
VMJH	17:59	1.10	4.73	163.34	19.31	2.55	3.32
VMJH	18:29	1.63	4.82	163.02	19.80	2.60	3.35
VMJH	18:59	0.63	5.14	163.03	19.23	2.55	3.31
VMJH	19:29	0.63	4.64	161.96	19.61	2.64	3.33
VMJH	19:59	0.43	4.54	162.34	18.90	2.69	3.33
VMJH	20:29	0.60	4.41	162.53	19.81	2.71	3.32
VMJH	20:59	0.43	4.98	163.82	18.82	2.57	3.32
VMJH	21:29	0.40	4.79	164.67	19.25	2.52	3.31
VMJH	21:59	0.67	4.81	163.93	19.25	2.74	3.30
VMJH	22:29	1.87	4.73	163.42	19.34	2.51	3.29
VMJH	22:43	1.07	4.71	161.15	18.69	2.59	3.28
VMZ		1.61	3.61	147.83	18.16	2.46	3.14

# Valori inregistrate MIR-IS HP-1500

Data:20/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.93	4.72	163.66	19.25	2.42	3.30
VMJH	07:59	2.63	4.72	161.89	20.10	2.59	3.32
VMJH	08:29	2.80	5.00	164.03	18.98	2.60	3.31
VMJH	08:59	2.10	4.87	163.13	19.53	2.50	3.31
VMJH	09:29	1.90	5.14	163.78	19.45	2.59	3.29
VMJH	09:59	2.63	4.99	164.19	19.81	2.54	3.27
VMJH	10:29	2.47	4.63	161.99	18.97	2.59	3.31
VMJH	10:59	1.83	4.88	165.42	19.52	2.62	3.30
VMJH	11:29	2.33	4.91	164.26	20.07	2.61	3.33
VMJH	11:59	2.20	4.75	162.82	19.29	2.52	3.34
VMJH	12:29	1.70	4.74	164.83	19.51	2.49	3.33
VMJH	12:59	1.67	4.71	165.97	19.17	2.65	3.31
VMJH	13:29	2.43	4.76	165.47	19.45	2.38	3.33
VMJH	13:59	1.87	4.53	164.04	20.06	2.63	3.30
VMJH	14:29	1.13	5.25	163.57	19.52	2.51	3.31
VMJH	14:59	1.30	4.63	164.19	19.45	2.52	3.33
VMJH	15:29	1.40	4.80	163.88	19.24	2.53	3.33
VMJH	15:59	1.27	4.70	165.74	19.21	2.40	3.31
VMJH	16:29	1.00	4.98	163.00	19.85	2.56	3.35
VMJH	16:59	0.80	4.68	163.45	20.04	2.52	3.29
VMJH	17:29	0.73	4.99	164.19	19.06	2.49	3.30
VMJH	17:59	0.67	4.96	164.19	18.95	2.43	3.29
VMJH	18:29	0.43	5.01	163.79	19.72	2.59	3.31
VMJH	18:59	1.13	4.82	163.80	19.68	2.38	3.27
VMJH	19:29	0.97	5.12	162.02	18.96	2.62	3.30
VMJH	19:59	0.67	4.70	163.36	19.01	2.57	3.34
VMJH	20:29	1.23	4.79	164.90	19.53	2.53	3.29
VMJH	20:59	0.93	4.49	164.90	19.42	2.46	3.30
VMJH	21:29	0.87	4.79	161.54	18.92	2.56	3.29
VMJH	21:59	1.03	4.96	164.70	18.94	2.57	3.30
VMJH	22:24	0.52	5.33	165.50	19.77	2.65	3.31
VMZ		1.51	4.85	163.93	19.43	2.54	3.31



# Valori inregistrate MIR-IS HP-1500

Data:21/12/2023

	Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
		VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
		10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.83		3.71		149.12		18.45		2.43		3.12	
VMJH	07:59	1.30		3.83		148.16		18.37		2.43		3.15	
VMJH	08:29	1.80		3.56		148.66		18.02		2.46		3.14	
VMJH	08:59	1.73		3.76		149.68		18.30		2.43		3.16	
VMJH	09:29	1.73		3.59		148.94		17.98		2.42		3.14	
VMJH	09:59	1.60		3.67		147.81		18.82		2.44		3.18	
VMJH	10:29	1.47		3.59		148.27		18.47		2.40		3.13	
VMJH	10:59	1.40		3.86		149.45		17.91		2.48		3.12	
VMJH	11:29	1.67		3.68		148.54		17.95		2.38		3.13	
VMJH	11:59	1.57		3.74		148.88		18.12		2.44		3.11	
VMJH	12:29	1.27		3.70		149.10		18.47		2.41		3.10	
VMJH	12:59	2.07		3.88		147.87		17.91		2.48		3.13	
VMJH	13:29	1.23		3.67		148.56		18.08		2.45		3.14	
VMJH	13:59	1.63		3.62		148.96		18.35		2.45		3.12	
VMJH	14:29	0.90		3.45		148.91		18.47		2.42		3.14	
VMJH	14:59	0.70		3.85		147.81		17.79		2.44		3.16	
VMJH	15:29	0.43		3.85		149.44		18.37		2.46		3.12	
VMJH	15:59	0.43		3.74		149.46		18.22		2.41		3.16	
VMJH	16:29	0.93		3.68		147.21		18.67		2.41		3.19	
VMJH	16:59	1.03		3.56		149.94		18.09		2.42		3.13	
VMJH	17:29	1.37		2.89		136.33		17.32		2.43		3.00	
VMJH	17:59	1.33		2.67		133.36		17.02		2.46		2.91	
VMJH	18:29	1.40		2.45		133.56		16.22		2.27		3.00	
VMJH	18:59	1.27		2.40		133.96		16.76		2.42		2.96	
VMJH	19:29	1.60		2.72		132.41		16.44		2.38		2.96	
VMJH	19:59	2.03		2.58		133.33		16.85		2.26		2.94	
VMJH	20:29	1.37		2.56		134.06		17.38		2.31		3.01	
VMJH	20:59	1.90		2.67		133.44		16.51		2.36		2.97	
VMJH	21:29	2.10		2.53		132.25		17.25		2.38		3.02	
VMJH	21:59	1.90		2.49		132.68		16.55		2.39		3.05	
VMJH	22:29	2.00		2.60		133.76		16.89		2.31		2.97	
VMJH	22:43	0.50		2.71		133.49		17.13		2.39		2.94	
VMZ		1.44		3.30		143.20		17.73		2.41		3.08	



# Valori inregistrate MIR-IS HP-1500

Data:22/12/2023

Ora	Pulberi mg/Nm2		SO2 L1 mg/Nm3		NOx L1 mg/Nm3		CO L1 mg/Nm3		COT L1 mg/Nm3		HCL L1 mg/Nm3	
	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH	VMA	VMJH
	10	30/10	50	200/50	200	400/200	50	10	20/10	10	60/10	
VMJH	07:29	1.20	4.73	161.83	19.38	2.51	3.33					
VMJH	07:59	1.07	4.79	165.50	19.61	2.53	3.30					
VMJH	08:29	1.67	4.23	157.25	19.02	2.43	3.26					
VMJH	08:59	1.70	3.66	149.91	18.67	2.42	3.12					
VMJH	09:29	1.90	3.72	148.45	18.49	2.41	3.15					
VMJH	09:59	0.93	3.71	148.26	17.52	2.43	3.15					
VMJH	10:29	0.90	3.71	149.19	18.12	2.40	3.14					
VMJH	10:59	0.93	3.73	148.75	18.33	2.43	3.14					
VMJH	11:29	0.90	3.68	148.44	17.90	2.39	3.16					
VMJH	11:59	0.90	3.75	148.44	18.39	2.42	3.15					
VMJH	12:29	0.87	3.60	147.22	18.47	2.48	3.17					
VMJH	12:59	1.13	3.66	148.72	18.02	2.51	3.16					
VMJH	13:29	1.63	3.50	148.19	18.27	2.48	3.16					
VMJH	13:59	1.03	3.72	148.68	17.66	2.45	3.12					
VMJH	14:29	1.50	3.74	149.67	18.12	2.46	3.13					
VMJH	14:59	1.23	3.60	148.80	18.19	2.50	3.14					
VMJH	15:29	0.77	3.73	147.44	18.24	2.39	3.13					
VMJH	15:59	0.90	3.66	148.79	17.83	2.35	3.15					
VMJH	16:29	1.00	3.60	147.00	18.58	2.44	3.15					
VMJH	16:59	0.63	3.78	149.30	17.92	2.50	3.13					
VMJH	17:29	1.83	3.62	148.12	18.25	2.36	3.15					
VMJH	17:59	1.30	3.77	148.97	18.45	2.50	3.15					
VMJH	18:29	1.47	3.81	148.59	18.26	2.48	3.11					
VMJH	18:59	0.87	3.61	147.63	18.16	2.44	3.14					
VMJH	19:29	0.93	3.69	148.06	17.86	2.50	3.14					
VMJH	19:59	0.70	3.76	148.91	18.59	2.51	3.14					
VMJH	20:29	0.37	3.76	148.61	18.36	2.43	3.17					
VMJH	20:59	0.97	3.62	148.90	18.05	2.44	3.12					
VMJH	21:29	0.63	3.66	149.98	17.86	2.43	3.15					
VMJH	21:59	1.57	3.62	148.94	18.72	2.44	3.16					
VMJH	22:12	1.77	3.62	148.56	18.33	2.33	3.09					
VMZ		1.12	3.77	149.87	18.31	2.45	3.16					

# Valori inregistrate MIR-IS HP-1500

Data:27/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	12:14	1.03	2.53	133.82	17.25	2.30	2.99
VMJH	12:44	0.90	2.56	133.71	17.21	2.35	2.95
VMJH	13:14	1.10	2.52	133.70	16.41	2.32	2.95
VMJH	13:44	0.77	2.58	132.96	16.16	2.35	2.94
VMJH	14:14	1.33	2.52	133.47	16.39	2.31	2.99
VMJH	14:44	1.20	2.53	133.81	17.43	2.32	3.01
VMJH	15:14	0.93	2.66	132.57	16.70	2.36	3.01
VMJH	15:44	1.00	2.68	134.49	16.24	2.39	3.02
VMJH	16:14	1.13	2.53	133.27	17.38	2.40	3.01
VMJH	16:44	1.30	2.54	133.53	17.30	2.39	2.95
VMJH	17:14	1.63	2.67	133.80	17.25	2.30	3.01
VMJH	17:44	1.80	2.57	132.89	17.31	2.33	2.98
VMJH	18:14	1.13	2.55	133.51	17.53	2.30	2.97
VMJH	18:44	1.30	2.59	133.53	16.92	2.36	3.00
VMJH	19:14	1.50	2.55	132.87	16.88	2.37	3.06
VMJH	19:44	1.43	2.53	132.40	16.65	2.32	2.96
VMJH	20:14	1.47	2.58	133.69	17.32	2.40	2.98
VMJH	20:44	0.70	2.61	133.50	17.34	2.29	2.96
VMJH	21:14	0.97	2.56	133.51	16.71	2.36	2.98
VMJH	21:44	1.10	2.63	133.50	17.02	2.31	2.91
VMJH	22:14	1.17	2.65	133.94	17.04	2.37	2.96
VMJH	22:44	1.67	2.57	133.69	17.71	2.30	2.98
VMZ		1.21	2.58	133.46	17.01	2.34	2.98

# Valori inregistrate MIR-IS HP-1500

Data:28/12/2023

Ora	Pulberi	SO2 L1	NOx L1	CO L1	COT L1	HCL L1	
	mg/Nm2	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	1.10	2.66	133.20	16.93	2.36	2.94
VMJH	07:59	1.63	2.51	133.72	17.08	2.26	2.96
VMJH	08:29	0.87	2.49	134.10	16.89	2.35	2.98
VMJH	08:59	1.10	2.60	133.68	17.56	2.22	3.01
VMJH	09:29	1.23	2.61	133.71	16.83	2.29	2.97
VMJH	09:59	0.90	2.51	133.60	16.56	2.31	2.98
VMJH	10:29	1.07	2.55	133.15	16.59	2.25	3.03
VMJH	10:59	0.67	2.51	134.14	15.97	2.36	2.95
VMJH	11:29	1.17	2.54	133.73	16.09	2.32	2.95
VMJH	11:59	0.97	2.38	133.42	16.83	2.28	2.95
VMJH	12:29	0.93	2.50	133.57	16.76	2.28	2.96
VMJH	12:59	0.90	2.47	133.52	16.53	2.30	2.92
VMJH	13:29	1.23	2.60	133.37	17.57	2.34	2.99
VMJH	13:59	0.93	2.61	133.63	16.93	2.43	2.92
VMJH	14:29	0.83	3.17	141.88	17.64	2.54	3.14
VMJH	14:59	1.10	4.58	158.72	20.15	3.18	3.31
VMJH	15:29	0.97	4.59	158.90	20.18	3.12	3.34
VMJH	15:59	0.93	4.61	159.18	20.15	3.21	3.35
VMJH	16:29	1.03	4.48	158.03	19.83	3.25	3.33
VMJH	16:59	0.60	4.72	158.73	20.25	3.23	3.28
VMJH	17:29	1.07	4.65	158.24	20.72	3.21	3.40
VMJH	17:59	0.53	4.53	158.26	19.95	3.22	3.32
VMJH	18:29	0.77	4.57	159.35	19.95	3.16	3.29
VMJH	18:59	0.77	4.62	158.77	19.93	3.24	3.37
VMJH	19:29	0.80	4.41	159.50	19.88	3.28	3.28
VMJH	19:59	0.83	4.30	159.28	20.50	3.23	3.40
VMJH	20:29	0.97	4.53	156.87	20.25	3.26	3.37
VMJH	20:59	0.63	4.63	158.05	19.84	3.23	3.29
VMJH	21:29	0.47	4.53	158.35	20.58	3.25	3.36
VMJH	21:59	0.63	4.43	157.82	20.66	3.16	3.36
VMJH	22:23	0.54	4.63	156.83	19.84	3.19	3.29
VMZ		0.91	3.59	146.62	18.55	2.78	3.16



# Valori inregistrate MIR-IS HP-1500

Data:29/12/2023

Ora	Pulberi mg/Nm2	SO2 L1 mg/Nm3	NOx L1 mg/Nm3	CO L1 mg/Nm3	COT L1 mg/Nm3	HCL L1 mg/Nm3	
	VMA VMJH	VMA VMJH	VMA VMJH	VMA	VMA VMJH	VMA VMJH	
	10 30/10	50 200/50	200 400/200	50	10 20/10	10 60/10	
VMJH	07:29	0.13	4.25	160.11	19.97	3.22	3.37
VMJH	07:59	0.77	4.56	158.83	19.93	3.21	3.35
VMJH	08:29	2.30	4.49	158.13	19.89	3.10	3.29
VMJH	08:59	1.80	4.63	159.85	19.76	3.23	3.26
VMJH	09:29	1.40	4.47	159.28	20.02	3.18	3.40
VMJH	09:59	0.60	4.46	157.63	20.55	3.27	3.35
VMJH	10:29	0.83	4.47	159.34	20.65	3.26	3.35
VMJH	10:59	0.93	4.31	158.49	20.08	3.23	3.30
VMJH	11:29	0.20	4.54	158.45	20.50	3.16	3.31
VMJH	11:59	0.10	4.50	158.70	20.15	3.24	3.38
VMJH	12:29	1.17	4.44	160.47	20.31	3.22	3.23
VMJH	12:59	0.73	4.43	159.22	19.75	3.17	3.20
VMJH	13:29	1.03	4.59	159.63	20.25	3.22	3.40
VMJH	13:59	0.93	4.51	158.57	20.74	3.15	3.40
VMJH	14:29	1.23	4.42	158.56	20.30	3.21	3.32
VMJH	14:59	1.20	4.57	159.55	19.21	3.23	3.27
VMJH	15:29	1.43	4.31	158.71	20.41	3.30	3.26
VMJH	15:59	1.50	4.66	159.58	20.11	3.30	3.33
VMJH	16:29	1.07	4.74	159.05	20.43	3.19	3.37
VMJH	16:59	1.63	4.44	159.55	20.00	3.26	3.29
VMJH	17:29	1.30	4.54	158.35	20.05	3.13	3.30
VMJH	17:59	2.67	4.26	159.91	19.90	3.23	3.36
VMJH	18:29	2.37	4.66	158.67	19.61	3.15	3.32
VMJH	18:59	1.53	4.41	158.97	20.35	3.22	3.39
VMJH	19:29	1.67	4.61	158.31	20.14	3.21	3.33
VMJH	19:59	1.80	4.44	159.59	20.56	3.19	3.34
VMJH	20:29	0.23	4.50	159.56	20.28	3.33	3.30
VMJH	20:59	0.53	4.54	158.43	19.81	3.18	3.28
VMJH	21:29	0.43	4.60	158.41	20.41	3.20	3.40
VMJH	21:59	0.87	4.50	159.45	20.08	3.21	3.39
VMJH	22:29	0.70	4.66	160.24	20.16	3.20	3.28
VMJH	22:43	0.50	4.15	158.02	20.40	3.30	3.33
VMZ		1.12	4.49	159.07	20.15	3.21	3.33